

October 26, 2016

Pete Zwack  
Scotia-Glenville CSD  
900 Preddice Parkway  
Scotia, NY 12302

RE: Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

Dear Pete Zwack:

Enclosed are the analytical results for sample(s) received by the laboratory on October 17, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht  
amanda.albrecht@pacelabs.com  
Project Manager

Enclosures

cc: Barbara Cintron, Scotia-Glenville CSD



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## CERTIFICATIONS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

---

### Minnesota Certification IDs

1700 Elm Street SE Suite 200, Minneapolis, MN 55414

Alaska Certification UST-107

525 N 8th Street, Salina, KS 67401

A2LA Certification #: 2926.01

Alaska Certification #: UST-078

Alaska Certification #MN00064

Alabama Certification #40770

Arizona Certification #: AZ-0014

Arkansas Certification #: 88-0680

California Certification #: 01155CA

Colorado Certification #Pace

Connecticut Certification #: PH-0256

EPA Region 8 Certification #: 8TMS-L

Florida/NELAP Certification #: E87605

Guam Certification #:14-008r

Georgia Certification #: 959

Georgia EPD #: Pace

Idaho Certification #: MN00064

Hawaii Certification #MN00064

Illinois Certification #: 200011

Indiana Certification#C-MN-01

Iowa Certification #: 368

Kansas Certification #: E-10167

Kentucky Dept of Envi. Protection - DW #90062

Kentucky Dept of Envi. Protection - WW #:90062

Louisiana DEQ Certification #: 3086

Louisiana DHH #: LA140001

Maine Certification #: 2013011

Maryland Certification #: 322

Michigan DEPH Certification #: 9909

Minnesota Certification #: 027-053-137

Mississippi Certification #: Pace

Montana Certification #: MT0092

Nevada Certification #: MN\_00064

Nebraska Certification #: Pace

New Jersey Certification #: MN-002

New York Certification #: 11647

North Carolina Certification #: 530

North Carolina State Public Health #: 27700

North Dakota Certification #: R-036

Ohio EPA #: 4150

Ohio VAP Certification #: CL101

Oklahoma Certification #: 9507

Oregon Certification #: MN200001

Oregon Certification #: MN300001

Pennsylvania Certification #: 68-00563

Puerto Rico Certification

Saipan (CNMI) #:MP0003

South Carolina #:74003001

Texas Certification #: T104704192

Tennessee Certification #: 02818

Utah Certification #: MN000642013-4

Virginia DGS Certification #: 251

Virginia/VELAP Certification #: Pace

Washington Certification #: C486

West Virginia Certification #: 382

West Virginia DHHR #:9952C

Wisconsin Certification #: 999407970

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## SAMPLE SUMMARY

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10366694001	Librarians office sink	Water	09/25/16 06:09	10/17/16 09:45
10366694002	Library bathroom sink	Water	09/25/16 06:10	10/17/16 09:45
10366694003	Rm. 92 sink	Water	09/25/16 06:13	10/17/16 09:45
10366694004	Rm. 92 bathroom sink	Water	09/25/16 06:13	10/17/16 09:45
10366694005	Rm. 94 sink	Water	09/25/16 06:17	10/17/16 09:45
10366694006	Rm. 94 Bathroom sink	Water	09/25/16 06:17	10/17/16 09:45
10366694007	Rm. 93 sink	Water	09/25/16 06:22	10/17/16 09:45
10366694008	Rm. 93 bathroom sink	Water	09/25/16 06:22	10/17/16 09:45
10366694009	Rm. 94 fountain	Water	09/25/16 06:22	10/17/16 09:45
10366694010	Rm. 95 sink	Water	09/25/16 06:25	10/17/16 09:45
10366694011	Rm. 95 bathroom sink	Water	09/25/16 06:25	10/17/16 09:45
10366694012	Rm. 96 sink	Water	09/25/16 06:29	10/17/16 09:45
10366694013	Rm. 96 bathroom sink	Water	09/25/16 06:29	10/17/16 09:45
10366694014	Rm. 96 fountain	Water	09/25/16 06:29	10/17/16 09:45
10366694015	Rm. 97 bathroom sink	Water	09/25/16 06:33	10/17/16 09:45
10366694016	Rm. 97 fountain	Water	09/25/16 06:34	10/17/16 09:45
10366694017	Rm. 97 sink	Water	09/25/16 06:34	10/17/16 09:45
10366694018	Rm. 98 bathroom sink	Water	09/25/16 06:34	10/17/16 09:45
10366694019	Rm. 98 fountain	Water	09/25/16 06:39	10/17/16 09:45
10366694020	Rm. 98 sink	Water	09/25/16 06:40	10/17/16 09:45
10366694021	Rm. 99 sink	Water	09/25/16 06:48	10/17/16 09:45
10366694022	Rm. 99 bathroom sink	Water	09/25/16 06:48	10/17/16 09:45
10366694023	Rm. 99 fountain	Water	09/25/16 06:49	10/17/16 09:45
10366694024	Rm. 100 bathroom sink	Water	09/25/16 06:55	10/17/16 09:45
10366694025	Rm. 100 sink	Water	09/25/16 06:56	10/17/16 09:45
10366694026	Rm. 101 sink	Water	09/25/16 06:59	10/17/16 09:45
10366694027	Rm. 101 bathroom sink	Water	09/25/16 06:59	10/17/16 09:45
10366694028	Rm. 102 sink	Water	09/25/16 07:04	10/17/16 09:45
10366694029	Rm. 102 bathroom sink	Water	09/25/16 07:05	10/17/16 09:45
10366694030	Rm. 103 bathroom sink	Water	09/25/16 07:10	10/17/16 09:45
10366694031	Rm. 103 sink	Water	09/25/16 07:10	10/17/16 09:45
10366694032	Rm. 104 sink	Water	09/25/16 07:14	10/17/16 09:45
10366694033	Rm. 104 bathroom sink	Water	09/25/16 07:15	10/17/16 09:45
10366694034	Water fountain across library	Water	09/25/16 07:17	10/17/16 09:45
10366694035	Rm. 105 sink	Water	09/25/16 07:20	10/17/16 09:45
10366694036	Rm. 105 bathroom sink	Water	09/25/16 07:21	10/17/16 09:45
10366694037	Rm. 106 sink	Water	09/25/16 07:25	10/17/16 09:45

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## SAMPLE SUMMARY

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10366694038	Rm. 106 bathroom sink	Water	09/25/16 07:25	10/17/16 09:45
10366694039	Center foyer womens bath. sink	Water	09/25/16 07:30	10/17/16 09:45
10366694040	Center foyer mens bath. sink	Water	09/25/16 07:32	10/17/16 09:45
10366694041	Gym office sink	Water	09/25/16 07:34	10/17/16 09:45
10366694042	Center foyer fountain	Water	09/25/16 07:35	10/17/16 09:45
10366694043	Womens bathrrom adj. to gym si	Water	09/25/16 07:40	10/17/16 09:45
10366694044	Mid-north corridor mens br sin	Water	09/25/16 07:45	10/17/16 09:45
10366694045	Mid-north corridor womens br	Water	09/25/16 07:46	10/17/16 09:45
10366694046	Mid-north corridor mens br sin	Water	09/25/16 07:45	10/17/16 09:45
10366694047	Mid-north corridor womens br	Water	09/25/16 07:46	10/17/16 09:45
10366694048	Rm. 107 sink	Water	09/25/16 07:52	10/17/16 09:45
10366694049	Rm. 108 sink	Water	09/25/16 08:00	10/17/16 09:45
10366694050	Rm. 109 sink	Water	09/25/16 08:02	10/17/16 09:45
10366694051	Rm. 110 sink	Water	09/25/16 08:05	10/17/16 09:45
10366694052	Rm. 111 sink	Water	09/25/16 08:07	10/17/16 09:45
10366694053	Far-north corridor mens br lef	Water	09/25/16 08:10	10/17/16 09:45
10366694054	Far-north corridor mens br rig	Water	09/25/16 08:11	10/17/16 09:45
10366694055	Rm. 112 sink	Water	09/25/16 08:13	10/17/16 09:45
10366694056	Far-north corridor womens br l	Water	09/25/16 08:15	10/17/16 09:45
10366694057	Far-north corridor womens br r	Water	09/25/16 08:16	10/17/16 09:45
10366694058	Far-north custodial sink	Water	09/25/16 08:22	10/17/16 09:45
10366694059	Rm. 113 sink	Water	09/25/16 08:25	10/17/16 09:45
10366694060	Center north corridor cutodial	Water	09/25/16 08:28	10/17/16 09:45
10366694061	North corridor fountain	Water	09/25/16 08:32	10/17/16 09:45
10366694062	Rm 114 sink	Water	09/25/16 08:35	10/17/16 09:45
10366694063	Rm 115 sink	Water	09/25/16 08:37	10/17/16 09:45
10366694064	Staff lounge mens br sink	Water	09/25/16 08:40	10/17/16 09:45
10366694065	Staff lounge womens br sink	Water	09/25/16 08:41	10/17/16 09:45
10366694066	Staff lounge sink	Water	09/25/16 08:42	10/17/16 09:45
10366694067	Kitchen Handsink Left	Water	09/25/16 08:45	10/17/16 09:45
10366694068	Kitchen Doublesink Left	Water	09/25/16 08:47	10/17/16 09:45
10366694069	Kitchen Doublesink Right	Water	09/25/16 08:49	10/17/16 09:45
10366694070	Kitchen Handsink Right	Water	09/25/16 08:51	10/17/16 09:45
10366694071	Cafeteria Fountain	Water	09/25/16 08:52	10/17/16 09:45
10366694072	Central foyer custodial sink	Water	09/25/16 08:55	10/17/16 09:45
10366694073	Room 206 Bathroom Sink	Water	09/25/16 08:59	10/17/16 09:45
10366694074	Nurses office sink	Water	09/25/16 09:02	10/17/16 09:45

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## SAMPLE SUMMARY

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10366694075	Nurses office bathroom sink	Water	09/25/16 09:03	10/17/16 09:45
10366694076	South corridor custodial sink	Water	09/25/16 09:07	10/17/16 09:45
10366694077	South corridor exterior spigot	Water	09/25/16 09:10	10/17/16 09:45
10366694078	North corridor exterior spigot	Water	09/25/16 09:12	10/17/16 09:45
10366694079	Cafeteria exterior spigot	Water	09/25/16 09:15	10/17/16 09:45
10366694080	Basement custodial sink	Water	09/25/16 09:18	10/17/16 09:45

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### SAMPLE ANALYTE COUNT

Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10366694001	Librarians office sink	EPA 200.8	RJS	1	PASI-M
10366694002	Library bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694003	Rm. 92 sink	EPA 200.8	RJS	1	PASI-M
10366694004	Rm. 92 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694005	Rm. 94 sink	EPA 200.8	RJS	1	PASI-M
10366694006	Rm. 94 Bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694007	Rm. 93 sink	EPA 200.8	RJS	1	PASI-M
10366694008	Rm. 93 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694009	Rm. 94 fountain	EPA 200.8	RJS	1	PASI-M
10366694010	Rm. 95 sink	EPA 200.8	RJS	1	PASI-M
10366694011	Rm. 95 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694012	Rm. 96 sink	EPA 200.8	RJS	1	PASI-M
10366694013	Rm. 96 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694014	Rm. 96 fountain	EPA 200.8	RJS	1	PASI-M
10366694015	Rm. 97 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694016	Rm. 97 fountain	EPA 200.8	RJS	1	PASI-M
10366694017	Rm. 97 sink	EPA 200.8	RJS	1	PASI-M
10366694018	Rm. 98 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694019	Rm. 98 fountain	EPA 200.8	RJS	1	PASI-M
10366694020	Rm. 98 sink	EPA 200.8	RJS	1	PASI-M
10366694021	Rm. 99 sink	EPA 200.8	RJS	1	PASI-M
10366694022	Rm. 99 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694023	Rm. 99 fountain	EPA 200.8	RJS	1	PASI-M
10366694024	Rm. 100 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694025	Rm. 100 sink	EPA 200.8	RJS	1	PASI-M
10366694026	Rm. 101 sink	EPA 200.8	RJS	1	PASI-M
10366694027	Rm. 101 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694028	Rm. 102 sink	EPA 200.8	RJS	1	PASI-M
10366694029	Rm. 102 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694030	Rm. 103 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694031	Rm. 103 sink	EPA 200.8	RJS	1	PASI-M
10366694032	Rm. 104 sink	EPA 200.8	RJS	1	PASI-M
10366694033	Rm. 104 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694034	Water fountain across library	EPA 200.8	RJS	1	PASI-M
10366694035	Rm. 105 sink	EPA 200.8	RJS	1	PASI-M
10366694036	Rm. 105 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694037	Rm. 106 sink	EPA 200.8	RJS	1	PASI-M

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### SAMPLE ANALYTE COUNT

Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10366694038	Rm. 106 bathroom sink	EPA 200.8	RJS	1	PASI-M
10366694039	Center foyer womens bath. sink	EPA 200.8	RJS	1	PASI-M
10366694040	Center foyer mens bath. sink	EPA 200.8	RJS	1	PASI-M
10366694041	Gym office sink	EPA 200.8	TT3	1	PASI-M
10366694042	Center foyer fountain	EPA 200.8	TT3	1	PASI-M
10366694043	Womens bathrrom adj. to gym si	EPA 200.8	TT3	1	PASI-M
10366694044	Mid-north corridor mens br sin	EPA 200.8	TT3	1	PASI-M
10366694045	Mid-north corridor womens br	EPA 200.8	TT3	1	PASI-M
10366694046	Mid-north corridor mens br sin	EPA 200.8	TT3	1	PASI-M
10366694047	Mid-north corridor womens br	EPA 200.8	TT3	1	PASI-M
10366694048	Rm. 107 sink	EPA 200.8	TT3	1	PASI-M
10366694049	Rm. 108 sink	EPA 200.8	TT3	1	PASI-M
10366694050	Rm. 109 sink	EPA 200.8	TT3	1	PASI-M
10366694051	Rm. 110 sink	EPA 200.8	TT3	1	PASI-M
10366694052	Rm. 111 sink	EPA 200.8	TT3	1	PASI-M
10366694053	Far-north corridor mens br lef	EPA 200.8	TT3	1	PASI-M
10366694054	Far-north corridor mens br rig	EPA 200.8	TT3	1	PASI-M
10366694055	Rm. 112 sink	EPA 200.8	TT3	1	PASI-M
10366694056	Far-north corridor womens br l	EPA 200.8	TT3	1	PASI-M
10366694057	Far-north corridor womens br r	EPA 200.8	TT3	1	PASI-M
10366694058	Far-north custodial sink	EPA 200.8	TT3	1	PASI-M
10366694059	Rm. 113 sink	EPA 200.8	TT3	1	PASI-M
10366694060	Center north corridor cutodial	EPA 200.8	TT3	1	PASI-M
10366694061	North corridor fountain	EPA 200.8	WBS	1	PASI-M
10366694062	Rm 114 sink	EPA 200.8	WBS	1	PASI-M
10366694063	Rm 115 sink	EPA 200.8	WBS	1	PASI-M
10366694064	Staff lounge mens br sink	EPA 200.8	WBS	1	PASI-M
10366694065	Staff lounge womens br sink	EPA 200.8	WBS	1	PASI-M
10366694066	Staff lounge sink	EPA 200.8	WBS	1	PASI-M
10366694067	Kitchen Handsink Left	EPA 200.8	WBS	1	PASI-M
10366694068	Kitchen Doublesink Left	EPA 200.8	WBS	1	PASI-M
10366694069	Kitchen Doublesink Right	EPA 200.8	WBS	1	PASI-M
10366694070	Kitchen Handsink Right	EPA 200.8	WBS	1	PASI-M
10366694071	Cafeteria Fountain	EPA 200.8	WBS	1	PASI-M
10366694072	Central foyer custodial sink	EPA 200.8	WBS	1	PASI-M
10366694073	Room 206 Bathroom Sink	EPA 200.8	WBS	1	PASI-M
10366694074	Nurses office sink	EPA 200.8	WBS	1	PASI-M

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### SAMPLE ANALYTE COUNT

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10366694075	Nurses office bathroom sink	EPA 200.8	WBS	1	PASI-M
10366694076	South corridor custodial sink	EPA 200.8	WBS	1	PASI-M
10366694077	South corridor exterior spigot	EPA 200.8	WBS	1	PASI-M
10366694078	North corridor exterior spigot	EPA 200.8	WBS	1	PASI-M
10366694079	Cafeteria exterior spigot	EPA 200.8	WBS	1	PASI-M
10366694080	Basement custodial sink	EPA 200.8	WBS	1	PASI-M

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

Sample: Librarians office sink		Lab ID: 10366694001	Collected: 09/25/16 06:09	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	7.1	ug/L	0.10	1		10/24/16 22:05	7439-92-1	
Sample: Library bathroom sink		Lab ID: 10366694002	Collected: 09/25/16 06:10	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	7.0	ug/L	0.10	1		10/24/16 22:17	7439-92-1	
Sample: Rm. 92 sink		Lab ID: 10366694003	Collected: 09/25/16 06:13	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	29.8	ug/L	0.10	1		10/24/16 22:20	7439-92-1	
Sample: Rm. 92 bathroom sink		Lab ID: 10366694004	Collected: 09/25/16 06:13	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	11.6	ug/L	0.10	1		10/24/16 22:23	7439-92-1	
Sample: Rm. 94 sink		Lab ID: 10366694005	Collected: 09/25/16 06:17	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	13.7	ug/L	0.10	1		10/24/16 22:26	7439-92-1	
Sample: Rm. 94 Bathroom sink		Lab ID: 10366694006	Collected: 09/25/16 06:17	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	17.1	ug/L	0.10	1		10/24/16 22:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

Sample: Rm. 93 sink		Lab ID: 10366694007	Collected: 09/25/16 06:22	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>9.3</b>	ug/L	0.10	1		10/24/16 22:37	7439-92-1	
Sample: Rm. 93 bathroom sink		Lab ID: 10366694008	Collected: 09/25/16 06:22	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>30.3</b>	ug/L	0.10	1		10/24/16 22:40	7439-92-1	
Sample: Rm. 94 fountain		Lab ID: 10366694009	Collected: 09/25/16 06:22	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>10.2</b>	ug/L	0.10	1		10/24/16 22:43	7439-92-1	
Sample: Rm. 95 sink		Lab ID: 10366694010	Collected: 09/25/16 06:25	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>6.9</b>	ug/L	0.10	1		10/24/16 22:46	7439-92-1	
Sample: Rm. 95 bathroom sink		Lab ID: 10366694011	Collected: 09/25/16 06:25	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>8.9</b>	ug/L	0.10	1		10/24/16 22:49	7439-92-1	
Sample: Rm. 96 sink		Lab ID: 10366694012	Collected: 09/25/16 06:29	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>1.6</b>	ug/L	0.10	1		10/24/16 22:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Sample: Rm. 96 bathroom sink	Lab ID: 10366694013	Collected: 09/25/16 06:29	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>3.4</b>	ug/L	0.10	1		10/24/16 22:55	7439-92-1	
<b>Sample: Rm. 96 fountain</b>	<b>Lab ID: 10366694014</b>	Collected: 09/25/16 06:29	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>1.0</b>	ug/L	0.10	1		10/24/16 22:58	7439-92-1	
<b>Sample: Rm. 97 bathroom sink</b>	<b>Lab ID: 10366694015</b>	Collected: 09/25/16 06:33	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>9.2</b>	ug/L	0.10	1		10/24/16 23:01	7439-92-1	
<b>Sample: Rm. 97 fountain</b>	<b>Lab ID: 10366694016</b>	Collected: 09/25/16 06:34	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>1.6</b>	ug/L	0.10	1		10/24/16 23:10	7439-92-1	
<b>Sample: Rm. 97 sink</b>	<b>Lab ID: 10366694017</b>	Collected: 09/25/16 06:34	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>1.4</b>	ug/L	0.10	1		10/24/16 23:13	7439-92-1	
<b>Sample: Rm. 98 bathroom sink</b>	<b>Lab ID: 10366694018</b>	Collected: 09/25/16 06:34	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>10.5</b>	ug/L	0.10	1		10/24/16 23:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Sample: Rm. 98 fountain	Lab ID: 10366694019	Collected: 09/25/16 06:39	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	1.1	ug/L	0.10	1		10/24/16 23:18	7439-92-1	
<b>Sample: Rm. 98 sink</b>	<b>Lab ID: 10366694020</b>	Collected: 09/25/16 06:40	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	1.5	ug/L	0.10	1		10/24/16 23:21	7439-92-1	
<b>Sample: Rm. 99 sink</b>	<b>Lab ID: 10366694021</b>	Collected: 09/25/16 06:48	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	1.8	ug/L	0.10	1		10/25/16 03:23	7439-92-1	
<b>Sample: Rm. 99 bathroom sink</b>	<b>Lab ID: 10366694022</b>	Collected: 09/25/16 06:48	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	5.2	ug/L	0.10	1		10/25/16 03:35	7439-92-1	
<b>Sample: Rm. 99 fountain</b>	<b>Lab ID: 10366694023</b>	Collected: 09/25/16 06:49	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	0.81	ug/L	0.10	1		10/25/16 03:38	7439-92-1	
<b>Sample: Rm. 100 bathroom sink</b>	<b>Lab ID: 10366694024</b>	Collected: 09/25/16 06:55	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	12.8	ug/L	0.10	1		10/25/16 03:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Sample: Rm. 100 sink		Lab ID: 10366694025	Collected: 09/25/16 06:56	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>11.8</b>	ug/L	0.10	1		10/25/16 03:44	7439-92-1	
Sample: Rm. 101 sink		Lab ID: 10366694026	Collected: 09/25/16 06:59	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>7.4</b>	ug/L	0.10	1		10/25/16 03:47	7439-92-1	
Sample: Rm. 101 bathroom sink		Lab ID: 10366694027	Collected: 09/25/16 06:59	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>8.3</b>	ug/L	0.10	1		10/25/16 03:56	7439-92-1	
Sample: Rm. 102 sink		Lab ID: 10366694028	Collected: 09/25/16 07:04	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>12.7</b>	ug/L	0.10	1		10/25/16 03:59	7439-92-1	
Sample: Rm. 102 bathroom sink		Lab ID: 10366694029	Collected: 09/25/16 07:05	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>11.4</b>	ug/L	0.10	1		10/25/16 04:02	7439-92-1	
Sample: Rm. 103 bathroom sink		Lab ID: 10366694030	Collected: 09/25/16 07:10	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>8.8</b>	ug/L	0.10	1		10/25/16 04:05	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Sample: Rm. 103 sink		Lab ID: 10366694031	Collected: 09/25/16 07:10	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>16.6</b>	ug/L	0.10	1		10/25/16 04:08	7439-92-1	
Sample: Rm. 104 sink		Lab ID: 10366694032	Collected: 09/25/16 07:14	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>7.0</b>	ug/L	0.10	1		10/25/16 04:11	7439-92-1	
Sample: Rm. 104 bathroom sink		Lab ID: 10366694033	Collected: 09/25/16 07:15	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>8.3</b>	ug/L	0.10	1		10/25/16 04:14	7439-92-1	
Sample: Water fountain across library		Lab ID: 10366694034	Collected: 09/25/16 07:17	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>1.8</b>	ug/L	0.10	1		10/25/16 04:17	7439-92-1	
Sample: Rm. 105 sink		Lab ID: 10366694035	Collected: 09/25/16 07:20	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>5.8</b>	ug/L	0.10	1		10/25/16 04:20	7439-92-1	
Sample: Rm. 105 bathroom sink		Lab ID: 10366694036	Collected: 09/25/16 07:21	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>7.0</b>	ug/L	0.10	1		10/25/16 04:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

Sample: Rm. 106 sink	Lab ID: 10366694037	Collected: 09/25/16 07:25	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	12.4	ug/L	0.10	1		10/25/16 04:32	7439-92-1	
<b>Sample: Rm. 106 bathroom sink</b>	<b>Lab ID: 10366694038</b>	Collected: 09/25/16 07:25	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	11.9	ug/L	0.10	1		10/25/16 04:35	7439-92-1	
<b>Sample: Center foyer womens bath. sink</b>	<b>Lab ID: 10366694039</b>	Collected: 09/25/16 07:30	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	3.7	ug/L	0.10	1		10/25/16 04:38	7439-92-1	
<b>Sample: Center foyer mens bath. sink</b>	<b>Lab ID: 10366694040</b>	Collected: 09/25/16 07:32	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	15.2	ug/L	0.10	1		10/25/16 04:41	7439-92-1	
<b>Sample: Gym office sink</b>	<b>Lab ID: 10366694041</b>	Collected: 09/25/16 07:34	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	20.1	ug/L	0.10	1		10/25/16 22:21	7439-92-1	
<b>Sample: Center foyer fountain</b>	<b>Lab ID: 10366694042</b>	Collected: 09/25/16 07:35	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	4.7	ug/L	0.10	1		10/25/16 22:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Sample: Womens bathrrom adj. to gym si		Lab ID: 10366694043	Collected: 09/25/16 07:40	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	15.1	ug/L	0.10	1		10/25/16 22:27	7439-92-1	
Sample: Mid-north corridor mens br sin		Lab ID: 10366694044	Collected: 09/25/16 07:45	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	13.9	ug/L	0.10	1		10/25/16 22:28	7439-92-1	
Sample: Mid-north corridor womens br		Lab ID: 10366694045	Collected: 09/25/16 07:46	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	6.7	ug/L	0.10	1		10/25/16 22:29	7439-92-1	
Sample: Mid-north corridor mens br sin		Lab ID: 10366694046	Collected: 09/25/16 07:45	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	9.9	ug/L	0.10	1		10/25/16 22:30	7439-92-1	
Sample: Mid-north corridor womens br		Lab ID: 10366694047	Collected: 09/25/16 07:46	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	3.3	ug/L	0.10	1		10/25/16 22:31	7439-92-1	
Sample: Rm. 107 sink		Lab ID: 10366694048	Collected: 09/25/16 07:52	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	21.4	ug/L	0.10	1		10/25/16 22:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Sample: Rm. 108 sink	Lab ID: 10366694049	Collected: 09/25/16 08:00	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>10.3</b>	ug/L	0.10	1		10/25/16 22:36	7439-92-1	
<b>Sample: Rm. 109 sink</b>	<b>Lab ID: 10366694050</b>	Collected: 09/25/16 08:02	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>10.2</b>	ug/L	0.10	1		10/25/16 22:37	7439-92-1	
<b>Sample: Rm. 110 sink</b>	<b>Lab ID: 10366694051</b>	Collected: 09/25/16 08:05	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>6.8</b>	ug/L	0.10	1		10/25/16 22:39	7439-92-1	
<b>Sample: Rm. 111 sink</b>	<b>Lab ID: 10366694052</b>	Collected: 09/25/16 08:07	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>8.5</b>	ug/L	0.10	1		10/25/16 22:41	7439-92-1	
<b>Sample: Far-north corridor mens br lef</b>	<b>Lab ID: 10366694053</b>	Collected: 09/25/16 08:10	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>20.6</b>	ug/L	0.10	1		10/25/16 22:42	7439-92-1	
<b>Sample: Far-north corridor mens br rig</b>	<b>Lab ID: 10366694054</b>	Collected: 09/25/16 08:11	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>16.9</b>	ug/L	0.10	1		10/25/16 22:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

Sample: Rm. 112 sink	Lab ID: 10366694055	Collected: 09/25/16 08:13	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>16.8</b>	ug/L	0.10	1		10/25/16 22:45	7439-92-1	

Sample: Far-north corridor womens br I	Lab ID: 10366694056	Collected: 09/25/16 08:15	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>14.5</b>	ug/L	0.10	1		10/25/16 22:46	7439-92-1	

Sample: Far-north corridor womens br r	Lab ID: 10366694057	Collected: 09/25/16 08:16	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>14.0</b>	ug/L	0.10	1		10/25/16 22:49	7439-92-1	

Sample: Far-north custodial sink	Lab ID: 10366694058	Collected: 09/25/16 08:22	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>26.0</b>	ug/L	0.10	1		10/25/16 22:50	7439-92-1	

Sample: Rm. 113 sink	Lab ID: 10366694059	Collected: 09/25/16 08:25	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>16.1</b>	ug/L	0.10	1		10/25/16 22:52	7439-92-1	

Sample: Center north corridor cutodial	Lab ID: 10366694060	Collected: 09/25/16 08:28	Received: 10/17/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS, DW</b>	Analytical Method: EPA 200.8							
Lead	<b>7.3</b>	ug/L	0.10	1		10/25/16 22:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Sample: North corridor fountain		Lab ID: 10366694061	Collected: 09/25/16 08:32	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	2.2	ug/L	0.10	1		10/24/16 19:37	7439-92-1	
Sample: Rm 114 sink		Lab ID: 10366694062	Collected: 09/25/16 08:35	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	29.4	ug/L	0.10	1		10/24/16 19:44	7439-92-1	
Sample: Rm 115 sink		Lab ID: 10366694063	Collected: 09/25/16 08:37	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	11.5	ug/L	0.10	1		10/24/16 19:45	7439-92-1	
Sample: Staff lounge mens br sink		Lab ID: 10366694064	Collected: 09/25/16 08:40	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	5.1	ug/L	0.10	1		10/24/16 19:46	7439-92-1	
Sample: Staff lounge womens br sink		Lab ID: 10366694065	Collected: 09/25/16 08:41	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	4.7	ug/L	0.10	1		10/24/16 19:47	7439-92-1	
Sample: Staff lounge sink		Lab ID: 10366694066	Collected: 09/25/16 08:42	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	3.8	ug/L	0.10	1		10/24/16 19:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

<b>Sample: Kitchen Handsink Left</b>		<b>Lab ID: 10366694067</b>	Collected: 09/25/16 08:45	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>50.9</b>	ug/L	0.10	1		10/24/16 19:50	7439-92-1	
------	-------------	------	------	---	--	----------------	-----------	--

<b>Sample: Kitchen Doublesink Left</b>		<b>Lab ID: 10366694068</b>	Collected: 09/25/16 08:47	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>16.0</b>	ug/L	0.10	1		10/24/16 19:51	7439-92-1	
------	-------------	------	------	---	--	----------------	-----------	--

<b>Sample: Kitchen Doublesink Right</b>		<b>Lab ID: 10366694069</b>	Collected: 09/25/16 08:49	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>9.9</b>	ug/L	0.10	1		10/24/16 19:52	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

<b>Sample: Kitchen Handsink Right</b>		<b>Lab ID: 10366694070</b>	Collected: 09/25/16 08:51	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>16.7</b>	ug/L	0.10	1		10/24/16 19:53	7439-92-1	
------	-------------	------	------	---	--	----------------	-----------	--

<b>Sample: Cafeteria Fountain</b>		<b>Lab ID: 10366694071</b>	Collected: 09/25/16 08:52	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>2.6</b>	ug/L	0.10	1		10/24/16 19:56	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

<b>Sample: Central foyer custodial sink</b>		<b>Lab ID: 10366694072</b>	Collected: 09/25/16 08:55	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>6.7</b>	ug/L	0.10	1		10/24/16 19:59	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Sample: Room 206 Bathroom Sink		Lab ID: 10366694073	Collected: 09/25/16 08:59	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	17.6	ug/L	0.10	1		10/24/16 20:00	7439-92-1	
Sample: Nurses office sink		Lab ID: 10366694074	Collected: 09/25/16 09:02	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	2.0	ug/L	0.10	1		10/24/16 20:01	7439-92-1	
Sample: Nurses office bathroom sink		Lab ID: 10366694075	Collected: 09/25/16 09:03	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	2.9	ug/L	0.10	1		10/24/16 20:02	7439-92-1	
Sample: South corridor custodial sink		Lab ID: 10366694076	Collected: 09/25/16 09:07	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	32.2	ug/L	0.10	1		10/24/16 20:03	7439-92-1	
Sample: South corridor exterior spigot		Lab ID: 10366694077	Collected: 09/25/16 09:10	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	16.2	ug/L	0.10	1		10/24/16 20:04	7439-92-1	
Sample: North corridor exterior spigot		Lab ID: 10366694078	Collected: 09/25/16 09:12	Received: 10/17/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	51.4	ug/L	0.10	1		10/24/16 20:05	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

**Sample: Cafeteria exterior spigot**      **Lab ID: 10366694079**      Collected: 09/25/16 09:15      Received: 10/17/16 09:45      Matrix: Water

**200.8 MET ICPMS, DW**

Analytical Method: EPA 200.8

Lead	<b>88.3</b>	ug/L	0.10	1		10/24/16 20:06	7439-92-1	
------	-------------	------	------	---	--	----------------	-----------	--

**Sample: Basement custodial sink**      **Lab ID: 10366694080**      Collected: 09/25/16 09:18      Received: 10/17/16 09:45      Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

**200.8 MET ICPMS, DW**

Analytical Method: EPA 200.8

Lead	<b>44.6</b>	ug/L	0.10	1		10/24/16 20:10	7439-92-1	
------	-------------	------	------	---	--	----------------	-----------	--

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

QC Batch: 442347 Analysis Method: EPA 200.8  
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water  
Associated Lab Samples: 10366694001, 10366694002, 10366694003, 10366694004, 10366694005, 10366694006, 10366694007, 10366694008, 10366694009, 10366694010, 10366694011, 10366694012, 10366694013, 10366694014, 10366694015, 10366694016, 10366694017, 10366694018, 10366694019, 10366694020

METHOD BLANK: 2410021 Matrix: Water  
Associated Lab Samples: 10366694001, 10366694002, 10366694003, 10366694004, 10366694005, 10366694006, 10366694007, 10366694008, 10366694009, 10366694010, 10366694011, 10366694012, 10366694013, 10366694014, 10366694015, 10366694016, 10366694017, 10366694018, 10366694019, 10366694020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/24/16 21:59	

LABORATORY CONTROL SAMPLE: 2410022

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	102	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2413768 2413769

Parameter	Units	10366694001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	7.1	100	100	104	105	97	98	70-130	1	20	

MATRIX SPIKE SAMPLE: 2413770

Parameter	Units	10366694020 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.5	100	96.7	95	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

QC Batch:	442348	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	ICPMS Metals, Drinking Water
Associated Lab Samples:	10366694021, 10366694022, 10366694023, 10366694024, 10366694025, 10366694026, 10366694027, 10366694028, 10366694029, 10366694030, 10366694031, 10366694032, 10366694033, 10366694034, 10366694035, 10366694036, 10366694037, 10366694038, 10366694039, 10366694040		

METHOD BLANK:	2410026	Matrix:	Water
Associated Lab Samples:	10366694021, 10366694022, 10366694023, 10366694024, 10366694025, 10366694026, 10366694027, 10366694028, 10366694029, 10366694030, 10366694031, 10366694032, 10366694033, 10366694034, 10366694035, 10366694036, 10366694037, 10366694038, 10366694039, 10366694040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/25/16 03:11	

LABORATORY CONTROL SAMPLE: 2410027						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	101	101	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2413523													2413524	
Parameter	Units	10366694021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual		
Lead	ug/L	1.8	100	100	98.7	99.1	97	97	70-130	0	20			

MATRIX SPIKE SAMPLE: 2413525							
Parameter	Units	10366694040 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	15.2	100	114	99	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

QC Batch: 442349 Analysis Method: EPA 200.8  
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water  
 Associated Lab Samples: 10366694041, 10366694042, 10366694043, 10366694044, 10366694045, 10366694046, 10366694047, 10366694048, 10366694049, 10366694050, 10366694051, 10366694052, 10366694053, 10366694054, 10366694055, 10366694056, 10366694057, 10366694058, 10366694059, 10366694060

METHOD BLANK: 2410029 Matrix: Water  
 Associated Lab Samples: 10366694041, 10366694042, 10366694043, 10366694044, 10366694045, 10366694046, 10366694047, 10366694048, 10366694049, 10366694050, 10366694051, 10366694052, 10366694053, 10366694054, 10366694055, 10366694056, 10366694057, 10366694058, 10366694059, 10366694060

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/25/16 22:07	

LABORATORY CONTROL SAMPLE: 2410030

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	99.6	100	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2415452 2415453

Parameter	Units	10366694041 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	20.1	100	100	118	119	97	99	70-130	1	20	

MATRIX SPIKE SAMPLE: 2415454

Parameter	Units	10366694051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	6.8	100	106	99	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

**QUALITY CONTROL DATA**

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

QC Batch: 442350 Analysis Method: EPA 200.8  
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water  
 Associated Lab Samples: 10366694061, 10366694062, 10366694063, 10366694064, 10366694065, 10366694066, 10366694067, 10366694068, 10366694069, 10366694070, 10366694071, 10366694072, 10366694073, 10366694074, 10366694075, 10366694076, 10366694077, 10366694078, 10366694079, 10366694080

METHOD BLANK: 2410032 Matrix: Water  
 Associated Lab Samples: 10366694061, 10366694062, 10366694063, 10366694064, 10366694065, 10366694066, 10366694067, 10366694068, 10366694069, 10366694070, 10366694071, 10366694072, 10366694073, 10366694074, 10366694075, 10366694076, 10366694077, 10366694078, 10366694079, 10366694080

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/24/16 19:35	

LABORATORY CONTROL SAMPLE: 2410033

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	102	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2414266 2414267

Parameter	Units	10366694061 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	2.2	100	100	107	108	105	106	70-130	0	20	

MATRIX SPIKE SAMPLE: 2414268

Parameter	Units	10366694071 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.6	100	112	110	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

## QUALIFIERS

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

### LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: SG CSD - Glendaal Elementary

Pace Project No.: 10366694

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10366694001	Librarians office sink	EPA 200.8	442347		
10366694002	Library bathroom sink	EPA 200.8	442347		
10366694003	Rm. 92 sink	EPA 200.8	442347		
10366694004	Rm. 92 bathroom sink	EPA 200.8	442347		
10366694005	Rm. 94 sink	EPA 200.8	442347		
10366694006	Rm. 94 Bathroom sink	EPA 200.8	442347		
10366694007	Rm. 93 sink	EPA 200.8	442347		
10366694008	Rm. 93 bathroom sink	EPA 200.8	442347		
10366694009	Rm. 94 fountain	EPA 200.8	442347		
10366694010	Rm. 95 sink	EPA 200.8	442347		
10366694011	Rm. 95 bathroom sink	EPA 200.8	442347		
10366694012	Rm. 96 sink	EPA 200.8	442347		
10366694013	Rm. 96 bathroom sink	EPA 200.8	442347		
10366694014	Rm. 96 fountain	EPA 200.8	442347		
10366694015	Rm. 97 bathroom sink	EPA 200.8	442347		
10366694016	Rm. 97 fountain	EPA 200.8	442347		
10366694017	Rm. 97 sink	EPA 200.8	442347		
10366694018	Rm. 98 bathroom sink	EPA 200.8	442347		
10366694019	Rm. 98 fountain	EPA 200.8	442347		
10366694020	Rm. 98 sink	EPA 200.8	442347		
10366694021	Rm. 99 sink	EPA 200.8	442348		
10366694022	Rm. 99 bathroom sink	EPA 200.8	442348		
10366694023	Rm. 99 fountain	EPA 200.8	442348		
10366694024	Rm. 100 bathroom sink	EPA 200.8	442348		
10366694025	Rm. 100 sink	EPA 200.8	442348		
10366694026	Rm. 101 sink	EPA 200.8	442348		
10366694027	Rm. 101 bathroom sink	EPA 200.8	442348		
10366694028	Rm. 102 sink	EPA 200.8	442348		
10366694029	Rm. 102 bathroom sink	EPA 200.8	442348		
10366694030	Rm. 103 bathroom sink	EPA 200.8	442348		
10366694031	Rm. 103 sink	EPA 200.8	442348		
10366694032	Rm. 104 sink	EPA 200.8	442348		
10366694033	Rm. 104 bathroom sink	EPA 200.8	442348		
10366694034	Water fountain across library	EPA 200.8	442348		
10366694035	Rm. 105 sink	EPA 200.8	442348		
10366694036	Rm. 105 bathroom sink	EPA 200.8	442348		
10366694037	Rm. 106 sink	EPA 200.8	442348		
10366694038	Rm. 106 bathroom sink	EPA 200.8	442348		
10366694039	Center foyer womens bath. sink	EPA 200.8	442348		
10366694040	Center foyer mens bath. sink	EPA 200.8	442348		
10366694041	Gym office sink	EPA 200.8	442349		
10366694042	Center foyer fountain	EPA 200.8	442349		
10366694043	Womens bathrrom adj. to gym si	EPA 200.8	442349		
10366694044	Mid-north corridor mens br sin	EPA 200.8	442349		
10366694045	Mid-north corridor womens br	EPA 200.8	442349		
10366694046	Mid-north corridor mens br sin	EPA 200.8	442349		
10366694047	Mid-north corridor womens br	EPA 200.8	442349		
10366694048	Rm. 107 sink	EPA 200.8	442349		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: SG CSD - Glendaal Elementary  
Pace Project No.: 10366694

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10366694049	Rm. 108 sink	EPA 200.8	442349		
10366694050	Rm. 109 sink	EPA 200.8	442349		
10366694051	Rm. 110 sink	EPA 200.8	442349		
10366694052	Rm. 111 sink	EPA 200.8	442349		
10366694053	Far-north corridor mens br lef	EPA 200.8	442349		
10366694054	Far-north corridor mens br rig	EPA 200.8	442349		
10366694055	Rm. 112 sink	EPA 200.8	442349		
10366694056	Far-north corridor womens br l	EPA 200.8	442349		
10366694057	Far-north corridor womens br r	EPA 200.8	442349		
10366694058	Far-north custodial sink	EPA 200.8	442349		
10366694059	Rm. 113 sink	EPA 200.8	442349		
10366694060	Center north corridor cutodial	EPA 200.8	442349		
10366694061	North corridor fountain	EPA 200.8	442350		
10366694062	Rm 114 sink	EPA 200.8	442350		
10366694063	Rm 115 sink	EPA 200.8	442350		
10366694064	Staff lounge mens br sink	EPA 200.8	442350		
10366694065	Staff lounge womens br sink	EPA 200.8	442350		
10366694066	Staff lounge sink	EPA 200.8	442350		
10366694067	Kitchen Handsink Left	EPA 200.8	442350		
10366694068	Kitchen Doublesink Left	EPA 200.8	442350		
10366694069	Kitchen Doublesink Right	EPA 200.8	442350		
10366694070	Kitchen Handsink Right	EPA 200.8	442350		
10366694071	Cafeteria Fountain	EPA 200.8	442350		
10366694072	Central foyer custodial sink	EPA 200.8	442350		
10366694073	Room 206 Bathroom Sink	EPA 200.8	442350		
10366694074	Nurses office sink	EPA 200.8	442350		
10366694075	Nurses office bathroom sink	EPA 200.8	442350		
10366694076	South corridor custodial sink	EPA 200.8	442350		
10366694077	South corridor exterior spigot	EPA 200.8	442350		
10366694078	North corridor exterior spigot	EPA 200.8	442350		
10366694079	Cafeteria exterior spigot	EPA 200.8	442350		
10366694080	Basement custodial sink	EPA 200.8	442350		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

**CHAIN-OF-CUSTODY / Analytical Request Document**  
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

16346694

Page: 1 of 7  
2082842

**Section A**  
Company: PACE  
Address: \_\_\_\_\_  
Email To: \_\_\_\_\_  
Phone: \_\_\_\_\_ Fax: \_\_\_\_\_  
Requested Due Date/TAT: \_\_\_\_\_

**Section B**  
Report To: \_\_\_\_\_  
Copy To: \_\_\_\_\_  
Purchase Order No.: \_\_\_\_\_  
Project Name: Chemical Elementary  
Project Number: \_\_\_\_\_

**Section C**  
Company Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
Pace Quote Reference: \_\_\_\_\_  
Pace Project Manager: \_\_\_\_\_  
Pace Profile #: \_\_\_\_\_

**REGULATORY AGENCY**  
 NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER \_\_\_\_\_  
Site Location: \_\_\_\_\_ STATE: NY

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	SAMPLE CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=CMP)	COLLECTED		# OF CONTAINERS	Preservatives	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
					COMPOSITE START	COMPOSITE END/GRAB					
1	Labratory Office Sink	DW	09/25/16	0609	1						001
2	Library Bathroom Sink	WW	0610		1						002
3	Rm. 92 Sink	SL	0613		1						003
4	Rm. 92 Bathroom Sink	OL	0613		1						004
5	Rm. 94 Sink	WP	0617		1						005
6	Rm. 94 Bathroom Sink	AR	0617		1						006
7	Rm. 95 Sink	TS	0622		1						007
8	Rm. 93 Bathroom Sink	OT	0622		1						008
9	<del>Rm. 93 Bathroom Sink</del> Rm. 94 Bathroom Sink		0622		1						009
10	Rm. 95 Sink		0625		1						010
11	Rm. 95 Bathroom Sink		0625		1						011
12	Rm. 96 Sink		0629		1						012

**ADDITIONAL COMMENTS**  
1-1-16 PSI  
Cali Nelson Pace  
10/13/16 16:00  
10/13/16 16:00  
Cali Nelson Pace  
10/13/16 9:45  
10/13/16 9:45

**RELINQUISHED BY / AFFILIATION** DATE TIME  
Cali Nelson Pace 9/28/16 16:00  
Cali Nelson Pace 10/13/16 16:00  
Cali Nelson Pace 10/13/16 9:45  
Cali Nelson Pace 10/13/16 9:45

**ACCEPTED BY / AFFILIATION** DATE TIME  
Cali Nelson Pace 9/28/16 16:00  
Cali Nelson Pace 10/13/16 16:00  
Cali Nelson Pace 10/13/16 9:45  
Cali Nelson Pace 10/13/16 9:45

**SAMPLE CONDITIONS**  
Received on \_\_\_\_\_  
Ice (Y/N) \_\_\_\_\_  
Custody Sealed Cooler (Y/N) \_\_\_\_\_  
Temp in °C \_\_\_\_\_  
Samples Intact (Y/N) \_\_\_\_\_

**SAMPLER NAME AND SIGNATURE**  
PRINT Name of SAMPLER: Ben Feist  
SIGNATURE of SAMPLER: [Signature]  
DATE Signed (MM/DD/YYYY): 09-25-16

ORIGINAL

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10366694

**Section A**  
Required Client Information:  
Company: **PACE**  
Address: \_\_\_\_\_  
Email To: \_\_\_\_\_  
Phone: \_\_\_\_\_ Fax: \_\_\_\_\_  
Requested Due Date/TAT: \_\_\_\_\_

**Section B**  
Required Project Information:  
Report To: \_\_\_\_\_  
Copy To: \_\_\_\_\_  
Purchase Order No.: \_\_\_\_\_  
Project Name: **Chemical Elementary**  
Project Number: \_\_\_\_\_

**Section C**  
Invoice Information:  
Attention: \_\_\_\_\_  
Company Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
Pace Quote Reference: \_\_\_\_\_  
Pace Project Manager: \_\_\_\_\_  
Pace Profile #: \_\_\_\_\_

**REGULATORY AGENCY**  
 NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER \_\_\_\_\_  
 Site Location \_\_\_\_\_  
 STATE: \_\_\_\_\_

Page: **2** of **7**  
 2082843

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Analysis Test Y/N	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
			COMPOSITE START	COMPOSITE END/DRAW									
1	Rm. 96 Bathroom Sink	DW	9-15-16	0629	G	DW G		1	Unpreserved				013
2	Rm. 96 Fountain	WT		0629				1					014
3	Rm. 97 Bathroom Sink	WW		0633				1					015
4	Rm. 97 Fountain	P		0634				1					016
5	Rm. 97 Sink	SL		0634				1					017
6	Rm. 98 Bathroom Sink	OL		0634				1					018
7	Rm. 98 Fountain	WP		0639				1					019
8	Rm. 98 Sink	AR		0640				1					020
9	Rm. 99 Sink	TS		0648				1					021
10	Rm. 99 Bathroom Sink	OT		0648				1					022
11	Rm. 99 Fountain			0649				1					023
12	Rm. 100 Bathroom Sink			0655				1					024

**ADDITIONAL COMMENTS**  
 RELINQUISHED BY / AFFILIATION: **JAM and PSI** DATE: **9/28/16** TIME: **16:00**  
 ACCEPTED BY / AFFILIATION: **Clini Welltop Pace** DATE: **9/28/16** TIME: **16:00**  
**Clini Welltop Pace**  
**Feel ex**  
**AM-10-17-16 9:45**  
**18.4**  
**15.8**

**SAMPLER NAME AND SIGNATURE**  
 PRINT Name of SAMPLER: **Ben Foster**  
 SIGNATURE of SAMPLER: **[Signature]**

**DATE SIGNED (MM/DD/YY):** **09-25-16**

**Temp in °C**  
 Received on: \_\_\_\_\_  
 Custody: \_\_\_\_\_  
 Sealed Cooler: \_\_\_\_\_  
 Samples In tact: \_\_\_\_\_

**SAMPLE CONDITIONS**  
 Y/N

ORIGINAL

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

**CHAIN-OF-CUSTODY / Analytical Request Document**  
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10366694

**Section A**  
Required Client Information:  
Company: **PACE**  
Address:  
Email To:  
Phone:  
Requested Due Date/TAT:

**Section B**  
Required Project Information:  
Report To:  
Copy To:  
Purchase Order No.:  
Project Name: **Glendale Elementary**  
Project Number:

**Section C**  
Invoice Information:  
Attention:  
Company Name:  
Address:  
Pace Quote Reference:  
Pace Project Manager:  
Pace Profile #:

Page: **3** of **7**  
Invoice Number: **2082844**

REGULATORY AGENCY  
 NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER

Site Location STATE: **NY**

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives Unpreserved H <sub>2</sub> SO <sub>4</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No. / Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB								
1	Rm. 103 SINK	DW	9/25/16	6556	G	DW	6	1		N		025
2	Rm. 101 SINK	WT	9/25/16	6557	G	WT	1	1		X	LEAD BY-200.8	024
3	Rm. 101 Bathroom SINK	WW	9/25/16	6559	G	WW	1	1				027
4	Rm. 102 SINK	P	9/25/16	6704	G	P	1	1				028
5	Rm. 102 Bathroom SINK	SL	9/25/16	6705	G	SL	1	1				029
6	Rm. 103 Bathroom SINK	OL	9/25/16	6710	G	OL	1	1				030
7	Rm. 103 SINK	WP	9/25/16	6711	G	WP	1	1				031
8	Rm. 104 SINK	AR	9/25/16	6714	G	AR	1	1				032
9	Rm. 104 Bathroom SINK	TS	9/25/16	6715	G	TS	1	1				033
10	Water Fountain across library	OT	9/25/16	6712	G	OT	1	1				034
11	Rm. 105 SINK		9/25/16	6720	G		1	1				035
12	Rm. 105 Bathroom SINK		9/25/16	6721	G		1	1				036

**RELEASING BY / AFFILIATION** DATE TIME  
**ACCEPTED BY / AFFILIATION** DATE TIME

RELINQUISHED BY / AFFILIATION: **PSI** DATE: **9/25/16** TIME: **16:00**  
 ACCEPTED BY / AFFILIATION: **Chli Nollan** DATE: **9/25/16** TIME: **16:00**

ADDITIONAL COMMENTS: **Chli Nollan** DATE: **10/17/16** TIME: **9:45**  
**18-8**  
**188**

Temp in °C: **18.8**  
 Received on Ice (Y/N): **N**  
 Sealed Cooler (Y/N): **Y**  
 Samples Intact (Y/N): **Y**

SAMPLER NAME AND SIGNATURE: **Ben Foote**  
 PRINT Name of SAMPLER: **Ben Foote**  
 SIGNATURE of SAMPLER: **RF**  
 DATE Signed (MM/DD/YYYY): **09-25-16**

ORIGINAL

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



10366694

Page: 4 of 7  
 2082845

**Section A**  
 Required Client Information:  
 Company: PACE  
 Address: \_\_\_\_\_  
 Email To: \_\_\_\_\_  
 Phone: \_\_\_\_\_ Fax: \_\_\_\_\_  
 Requested Due Date/TAT: \_\_\_\_\_

**Section B**  
 Required Project Information:  
 Report To: \_\_\_\_\_  
 Copy To: \_\_\_\_\_  
 Purchase Order No.: \_\_\_\_\_  
 Project Name: Glendael Elementary  
 Project Number: \_\_\_\_\_

**Section C**  
 Invoice Information:  
 Attention: \_\_\_\_\_  
 Company Name: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 Pace Quote Reference: \_\_\_\_\_  
 Pace Project Manager: \_\_\_\_\_  
 Pace Profile #: \_\_\_\_\_

**REGULATORY AGENCY**  
 NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER \_\_\_\_\_

Site Location: \_\_\_\_\_  
 STATE: NY

ITEM #	Section D Required Client Information	MATRIX CODE (see valid codes to left)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives Unpreserved H <sub>2</sub> SO <sub>4</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other	Requested Analysis Filtered (Y/N)	Pace Project No./ Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB					
1	Rm. 106 Sink	W	DATE	TIME	DATE	TIME			
2	Rm. 106 Bathroom Sink	W	9-25-11	0725					037
3	Center foyer Womens Bath. Sink	W		0725					038
4	Center foyer Mens Bath. Sink	W		0730					039
5	Cym Office Sink	W		0732					040
6	Center foyer fountain	W		0734					041
7	Womens Bathroom Adj. to Gym Sink	W		0735					042
8	M.D.-North Corridor Mens BR Sink Left (Right)	W		0740					043
9	Mid-North Corridor Womens BR Sink	W		0745					044
10	Mid-North Corridor Mens BR Right Sink	W		0746					045
11	Mid-North Corridor Womens BR Sink Left	W		0748					046
12	Rm. 107 Sink	W		0752					047
									048

**ADDITIONAL COMMENTS**  
 Relinquished by / Affiliation: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Accepted by / Affiliation: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Residual Chlorine (Y/N): \_\_\_\_\_

Temp in °C: \_\_\_\_\_  
 Received on Ice (Y/N): \_\_\_\_\_  
 Custody Sealed Cooler (Y/N): \_\_\_\_\_  
 Samples Intact (Y/N): \_\_\_\_\_

**DATE SIGNED (MM/DD/YYYY):** 07-25-16  
**PRINT NAME OF SAMPLER:** Ben Foster  
**SIGNATURE OF SAMPLER:** [Signature]

**SAMPLER NAME AND SIGNATURE**  
 DATE SIGNED (MM/DD/YYYY): 07-25-16  
 PRINT NAME OF SAMPLER: Ben Foster  
 SIGNATURE OF SAMPLER: [Signature]

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

**CHAIN-OF-CUSTODY / Analytical Request Document**  
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10366694

Page: 5 of 7  
2082846

**Section A**  
Required Client Information:  
Company: PACE  
Address:  
Email To:  
Phone:  
Requested Due Date/TAT:

**Section B**  
Required Project Information:  
Report To:  
Copy To:  
Purchase Order No.:  
Project Name: Chemical Elementary  
Project Number:

**Section C**  
Invoice Information:  
Attention:  
Company Name:  
Address:  
Face Quote Reference:  
Face Project Manager:  
Face Profile #:

**REGULATORY AGENCY**  
 NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER

Site Location STATE: NY

ITEM #	Section D Required Client Information	MATRIX CODE (see valid codes to left)	COLLECTED		# OF CONTAINERS	Preservatives	Requested Analysis Filtered (Y/N)	Pace Project No./ Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB				
	Matrix Codes Drinking Water DW Water WT Waste Water WW Product P Soil/Solid SL Oil OL Wipe WP Air AR Tissue TS Other OT	SAMPLE TYPE (G=GRAB C=COMP)	DATE	TIME	SAMPLE TEMP AT COLLECTION	H <sub>2</sub> SO <sub>4</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other		
1	Rm. 108 Sink	DW G	4-15-16	0800	1			049
2	Rm. 109 Sink			0802	1			050
3	Rm. 110 Sink			0805	1			051
4	Rm. 111 Sink			0807	1			052
5	Far-North-Corridor Mens BR Left Sink			0810	1			053
6	Far-North-Corridor Mens BR Right Sink			0811	1			054
7	Rm. 112 Sink			0815	1			055
8	Far-North-Corridor Womens BR Left Sink			0815	1			056
9	Far-North-Corridor Womens BR Right Sink			0816	1			057
10	Far-North-Corridor Sink			0822	1			058
11	Rm. 113 Sink			0825	1			059
12	Center North-Corridor Custodial Sink			0828	1			060

**ADDITIONAL COMMENTS**  
LEAD BY ZOC. 8

**RELINQUISHED BY / AFFILIATION** DATE TIME  
Colin McElroy Pace 9/20/16 16:00

**ACCEPTED BY / AFFILIATION** DATE TIME  
Colin McElroy Pace 9/20/16 16:00

**TEMP IN °C**  
18.6  
18.5

**Received on** 10/17/16 9:45  
18.5

**Custody Sealed Cooler** (Y/N)  
N

**Samples Intact** (Y/N)  
Y

**DATE SIGNED** (MM/DD/YYYY): 09-25-16

**PRINT NAME OF SAMPLER:** Ben Fook

**SIGNATURE OF SAMPLER:** [Signature]

**SAMPLER NAME AND SIGNATURE**

**ORIGINAL**

**CHAIN-OF-CUSTODY / Analytical Request Document**

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10366694

**Section A**  
Required Client Information:  
Company: **PACE**  
Address:  
Email To:  
Phone:  
Requested Due Date/TAT:

**Section B**  
Required Project Information:  
Report To:  
Copy To:  
Purchase Order No.:  
Project Name: **Chemical Elementary**  
Project Number:

**Section C**  
Invoice Information:  
Attention:  
Company Name:  
Address:  
Pace Quote Reference:  
Pace Project Manager:  
Pace Profile #:

**REGULATORY AGENCY**  
 NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER  
 Site Location STATE: **NY**

Page: **6** of **7**  
2082847

ITEM #	Section D Required Client Information	MATRIX CODE (see valid codes to left)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives Unpreserved H <sub>2</sub> SO <sub>4</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>8</sub> Methanol Other	Analysis Test ↑ Y/N ↑	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB							
1	North Corridor Fountain	DW 6	4-25-16	0832	1						061
2	Rm 114 Sink			0835	1						062
3	Rm 115 Sink			0837	1						063
4	Stuff Lounge Mens BR Sink			0840	1						064
5	Stuff Lounge Womens BR Sink			0841	1						065
6	Stuff Lounge Sink			0842	1						066
7	Kitchen Hand Sink Left			0845	1						067
8	Kitchen Double Sink Left			0847	1						068
9	Kitchen Double Sink Right			0849	1						069
10	Kitchen Hand Sink Right			0851	1						070
11	Cafeteria Fountain			0852	1						071
12	Central Entry Custodial Sink			0855	1						072

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
<i>Tom at PSI</i>	4/25/16	16:00	<i>Chris Mally</i>	4/28/16	16:00	
<i>Chris Mally</i>	4/28/16	16:00	<i>Feet</i>	4/28/16	16:00	

**ORIGINAL**

SAMPLER NAME AND SIGNATURE  
 PRINT Name of SAMPLER: **Ben Foot**  
 SIGNATURE of SAMPLER: *Ben Foot*

DATE Signed (MM/DD/YYYY): **04-25-16**

Temp in °C  
 Received on Ice (Y/N)  
 Sealed Custody Cooler (Y/N)  
 Samples Intact (Y/N)

**CHAIN-OF-CUSTODY / Analytical Request Document**  
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10366694

**Section A** Required Client Information: Company: PACE Address: \_\_\_\_\_  
**Section B** Required Project Information: Report To: \_\_\_\_\_ Copy To: \_\_\_\_\_  
**Section C** Invoice Information: Attention: \_\_\_\_\_ Company Name: \_\_\_\_\_  
 Regulatory Agency: \_\_\_\_\_  
 NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER \_\_\_\_\_  
 Site Location: \_\_\_\_\_ STATE: NY  
 Pace Quote Reference: \_\_\_\_\_ Pace Project Manager: \_\_\_\_\_  
 Pace Profile #: \_\_\_\_\_  
 Requested Due Date/TAT: \_\_\_\_\_

Page: 7 of 7  
2082848

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No. / Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB								
1	Room 206 Bathroom Sink	DW	09/25/16	0859	G	206	1	Unpreserved				073
2	Nurses office sink	WT	09/26	0902	G	1	1					074
3	Nurses office Bathroom Sink	WW	09/26	0903	G	1	1					075
4	South Corridor Custodial sink	P	09/27	0907	G	1	1					076
5	South Corridor Exterior Spigot	SL	09/26	0910	G	1	1					077
6	North Corridor Exterior Spigot	OL	09/26	0912	G	1	1					078
7	Custodian Office Exterior Spigot	WP	09/26	0915	G	1	1					079
8	Basement Custodial Sink	AR	09/26	0918	G	1	1					080
9		TS										
10		OT										
11												
12												

**ADDITIONAL COMMENTS**  
 Relinquished by / Affiliation: John A. K. Date: 9/28/16 Time: 16:00  
 Accepted by / Affiliation: Celia Alday Date: 9/28/16 Time: 16:00  
 Relinquished by / Affiliation: Celia Alday Date: 10/13/16 Time: 16:00  
 Accepted by / Affiliation: Ben Feate Date: 10/17/16 Time: 9:00  
 Temp in °C: 18.8  
 Received on Ice (Y/N): N  
 Sealed Cooler (Y/N): Y  
 Samples Intact (Y/N): Y

**SAMPLER NAME AND SIGNATURE**  
 PRINT Name of SAMPLER: Ben Feate  
 SIGNATURE of SAMPLER: RR  
 DATE Signed (MM/DD/YY): 09-25-16

ORIGINAL

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

**Sample Condition Upon Receipt**

Client Name:

Pace NY

Project #:

**WO# : 10366694**



10366694

Courier:  Fed Ex  UPS  USPS  Client

Commercial  Pace  Speedee  Other:

Tracking Number: 706298753370, 3391

Custody Seal on Cooler/Box Present?  Yes  No      Seals Intact?  Yes  No

Optional: Proj. Due Date:      Proj. Name:

Packing Material:  Bubble Wrap  Bubble Bags  None  Other:      Temp Blank?  Yes  No

Thermometer Used:  151401163  151401164  B88A912167504  B88A0143310098      Type of Ice:  Wet  Blue  None  Samples on ice, cooling process has begun

Cooler Temp Read (°C): 18.4, 18.6 Cooler Temp Corrected (°C): 18.4, 18.5      Biological Tissue Frozen?  Yes  No  N/A  
Temp should be above freezing to 6°C      Correction Factor: 70.2      Date and Initials of Person Examining Contents: RAC 10-FF-16

USDA Regulated Soil  N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, AZ, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)?  Yes  No      Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.

	COMMENTS:
Chain of Custody Present?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A      1.
Chain of Custody Filled Out?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A      2.
Chain of Custody Relinquished?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A      3.
Sampler Name and/or Signature on COC?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A      4.
Samples Arrived within Hold Time?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A      5.
Short Hold Time Analysis (<72 hr)?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A      6.
Rush Turn Around Time Requested?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A      7.
Sufficient Volume?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A      8.
Correct Containers Used?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A      9.
-Pace Containers Used?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Containers Intact?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A      10.
Filtered Volume Received for Dissolved Tests?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A      11. Note if sediment is visible in the dissolved container
Sample Labels Match COC?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A      12. Times for samples 248-25 CRM 100 Bathroom sink and Room 1005 sink are reversed.
-Includes Date/Time/ID/Analysis Matrix: <u>WT</u>	
All containers needing acid/base preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A      13. <input checked="" type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl<2; NaOH >9 Sulfide, NaOH>12 Cyanide) Exceptions: VOA, Coliform, TOC, Oil and Grease, DRO/8015 (water) DOC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A      Sample # <u>1-80</u>
Headspace in VOA Vials (>6mm)?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A      14. Initial when completed:      Lot # of added preservative:
Trip Blank Present?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A      15.
Trip Blank Custody Seals Present?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A
Pace Trip Blank Lot # (if purchased):	

**CLIENT NOTIFICATION/RESOLUTION**

Field Data Required?  Yes  No

Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_

Comments/Resolution: \_\_\_\_\_

Project Manager Review: Awanda J Albrecht

Date: 10/20/16

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office ( i.e out of hold, incorrect preservative, out of temp, incorrect containers).