

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
SGHS001-Basement Bathrm Sink	10/22/2016 06:11	11/23/2016 21:31	10369839001	Lead	7.9	15	ug/L
SGHS002-Basement Custodial Clo	10/22/2016 06:12	11/23/2016 21:35	10369839002	Lead	24.3	15	ug/L
SGHS003-Basement Hose Faucet	10/22/2016 06:14	11/23/2016 21:36	10369839003	Lead	9.7	15	ug/L
SGHS004-Waterfountain#1 Drink	10/22/2016 06:16	11/23/2016 21:37	10369839004	Lead	<0.10	15	ug/L
SGHS005-Waterfountain#1 Founta	10/22/2016 06:17	11/23/2016 21:38	10369839005	Lead	<0.10	15	ug/L
SGHS006-Kitchen Dishhose Sink1	10/22/2016 06:20	11/23/2016 21:40	10369839006	Lead	7.4	15	ug/L
SGHS007-Kitchen Dishhose Sink2	10/22/2016 06:22	11/23/2016 21:41	10369839007	Lead	38.1	15	ug/L
SGHS008-Kitchen Pot Sink Sink3	10/22/2016 06:23	11/23/2016 21:44	10369839008	Lead	7.2	15	ug/L
SGHS009-Kitchen Pot Sink Sink4	10/22/2016 06:24	11/23/2016 21:45	10369839009	Lead	12.3	15	ug/L
SGHS010-Kitchen Prep Sink5	10/22/2016 06:25	11/23/2016 21:46	10369839010	Lead	10.8	15	ug/L
SGHS011-Kitchen Prep Sink6	10/22/2016 06:26	11/23/2016 21:48	10369839011	Lead	9.7	15	ug/L
SGHS012-Kitchen Kettle Sink7	10/22/2016 06:27	11/23/2016 21:50	10369839012	Lead	61.0	15	ug/L
SGHS013-Kitchen Kettle Sink8	10/22/2016 06:27	11/23/2016 21:51	10369839013	Lead	8.1	15	ug/L
SGHS014-Kitchen Bathrm Sink	10/22/2016 06:29	11/23/2016 21:52	10369839014	Lead	10.3	15	ug/L
SGHS015-Water Fountain #2	10/22/2016 06:34	11/23/2016 21:53	10369839015	Lead	1.8	15	ug/L
SGHS016-Mens Bathrm #1 Sink #1	10/22/2016 06:35	11/23/2016 21:54	10369839016	Lead	18.2	15	ug/L
SGHS017-Mens Bathrm #1 Sink #2	10/22/2016 06:35	11/23/2016 21:59	10369839017	Lead	4.6	15	ug/L
SGHS018-Womens Bathrm #1 Sink1	10/22/2016 06:37	11/23/2016 22:00	10369839018	Lead	2.5	15	ug/L
SGHS019-Womens Bathrm #1 Sink2	10/22/2016 06:38	11/23/2016 22:01	10369839019	Lead	3.1	15	ug/L
SGHS020-Womens Bathrm #1 Sink3	10/22/2016 06:38	11/23/2016 22:02	10369839020	Lead	3.8	15	ug/L
SGHS021-Stage Paint Rm Sink	10/22/2016 06:40	11/23/2016 20:19	10369839021	Lead	12.5	15	ug/L
SGHS022-Shop Rm C-2 Sink	10/22/2016 06:41	11/23/2016 20:25	10369839022	Lead	7.2	15	ug/L
SGHS023-Shop Rm C-2 Hose Fauce	10/22/2016 06:42	11/23/2016 20:26	10369839023	Lead	17.2	15	ug/L
SGHS024-Woodshop Rm C-5 Sink	10/22/2016 06:45	11/23/2016 20:28	10369839024	Lead	425	15	ug/L
SGHS025-Printshop Rm C-6 Sink1	10/22/2016 06:47	11/23/2016 20:29	10369839025	Lead	8.1	15	ug/L
SGHS026-Printshop Rm C-6 Sink2	10/22/2016 06:47	11/23/2016 20:30	10369839026	Lead	7.8	15	ug/L
SGHS027-Printshop Rm C-6 Sink3	10/22/2016 06:48	11/23/2016 20:31	10369839027	Lead	7.2	15	ug/L
SGHS028-Water Fountain #3	10/22/2016 06:50	11/23/2016 20:32	10369839028	Lead	3.1	15	ug/L
SGHS029-Old Gym Hallway Waterf	10/22/2016 07:00	11/23/2016 20:33	10369839029	Lead	3.9	15	ug/L
SGHS030-Old Gym Custodial Clos	10/22/2016 07:02	11/23/2016 20:37	10369839030	Lead	286	15	ug/L
SGHS031-Home Ed Rm B-5 Sink#1	10/22/2016 07:11	11/23/2016 20:38	10369839031	Lead	28.8	15	ug/L
SGHS032-Home Ed Rm B-5 Sink#2	10/22/2016 07:11	11/23/2016 20:40	10369839032	Lead	4.0	15	ug/L
SGHS033-Home Ed Rm B-5 Sink#3	10/22/2016 07:12	11/23/2016 20:41	10369839033	Lead	35.1	15	ug/L
SGHS034-Laundry/Office Sink	10/22/2016 07:14	11/23/2016 20:42	10369839034	Lead	15.1	15	ug/L
SGHS035-Home Ed Rm B-4 Sink#1	10/22/2016 07:16	11/23/2016 20:43	10369839035	Lead	15.0	15	ug/L
SGHS036-Home Ed Rm B-4 Sink#2	10/22/2016 07:17	11/23/2016 20:44	10369839036	Lead	34.7	15	ug/L
SGHS037-Home Ed Rm B-4 Sink#3	10/22/2016 07:17	11/23/2016 20:45	10369839037	Lead	14.7	15	ug/L
SGHS038-Library Office Rm B-3	10/22/2016 07:19	11/23/2016 20:47	10369839038	Lead	33.8	15	ug/L
SGHS039-Rm B-7 Office Sink	10/22/2016 07:21	11/28/2016 16:07	10369839039	Lead	14.1	15	ug/L
SGHS040-Main Office Mail Rm Si	10/22/2016 07:24	11/28/2016 16:10	10369839040	Lead	26.9	15	ug/L
SGHS041-Guidence Office Storag	10/22/2016 07:25	11/23/2016 22:39	10369839041	Lead	19.9	15	ug/L
SGHS042-Mens Bath Rm #2 Sink	10/22/2016 07:27	11/23/2016 22:44	10369839042	Lead	7.1	15	ug/L
SGHS043-Womens Bath Rm #2 Sink	10/22/2016 07:29	11/23/2016 22:45	10369839043	Lead	12.3	15	ug/L
SGHS044-Boys Bath Rm #3 Sink#1	10/22/2016 07:31	11/23/2016 22:46	10369839044	Lead	10.0	15	ug/L
SGHS045-Boys Bath Rm #3 Sink#2	10/22/2016 07:32	11/23/2016 22:47	10369839045	Lead	9.0	15	ug/L
SGHS046-Boys Bath Rm #3 Sink#3	10/22/2016 07:33	11/23/2016 22:48	10369839046	Lead	7.2	15	ug/L
SGHS047-Boys Bath Rm #3 Sink#4	10/22/2016 07:34	11/23/2016 22:52	10369839047	Lead	17.3	15	ug/L
SGHS048-Girls Bath Rm #3Sink#1	10/22/2016 07:35	11/23/2016 22:53	10369839048	Lead	18.8	15	ug/L
SGHS049-Girls Bath Rm #3Sink#2	10/22/2016 07:36	11/23/2016 22:54	10369839049	Lead	47.4	15	ug/L
SGHS050-Girls Bath Rm #3Sink#3	10/22/2016 07:36	11/23/2016 22:55	10369839050	Lead	104	15	ug/L

SGHS051-Girls Bath Rm #3Sink#4	10/22/2016 07:37	11/23/2016 22:56	10369839051	Lead	16.8	15	ug/L
SGHS052-Water Fountain #4	10/22/2016 07:40	11/23/2016 22:58	10369839052	Lead	0.95	15	ug/L
SGHS053-Girls Bath Rm #3Sink#5	10/22/2016 07:41	11/23/2016 22:59	10369839053	Lead	65.8	15	ug/L
SGHS054-Rm A-2 Office Sink	10/22/2016 07:43	11/23/2016 23:00	10369839054	Lead	17.2	15	ug/L
SGHS055-Mens PE Office Sink	10/22/2016 07:45	11/23/2016 23:02	10369839055	Lead	6.1	15	ug/L
SGHS056-Mens PE Office Shower	10/22/2016 07:46	11/23/2016 23:06	10369839056	Lead	55.6	15	ug/L
SGHS057-Boys Locker Rm Sink	10/22/2016 07:48	11/23/2016 23:07	10369839057	Lead	3.1	15	ug/L
SGHS058-Boys LockerRm BathSink	10/22/2016 07:49	11/23/2016 23:08	10369839058	Lead	1.5	15	ug/L
SGHS059-Boys LockerRm Shower#1	10/22/2016 07:53	11/23/2016 23:10	10369839059	Lead	3.3	15	ug/L
SGHS060-Boys LockerRm Shower#2	10/22/2016 07:55	11/23/2016 23:11	10369839060	Lead	23.9	15	ug/L
SGHS061-Boys LockerRm Shower#3	10/22/2016 07:57	11/27/2016 18:57	10369839061	Lead	23.4	15	ug/L
SGHS062-Womens PE Office Sink	10/22/2016 07:58	11/27/2016 19:15	10369839062	Lead	5.4	15	ug/L
SGHS063-Womens PE Office Showe	10/22/2016 07:59	11/27/2016 19:18	10369839063	Lead	18.2	15	ug/L
SGHS064-Girls Locker Rm Sink	10/22/2016 08:01	11/27/2016 19:21	10369839064	Lead	5.7	15	ug/L
SGHS065-Custodial Closet Ice R	10/22/2016 08:03	11/27/2016 19:24	10369839065	Lead	8.4	15	ug/L
SGHS066-Mens BathRm #4 Sink#1	10/22/2016 08:05	11/27/2016 19:27	10369839066	Lead	7.9	15	ug/L
SGHS067-Mens BathRm #4 Sink#2	10/22/2016 08:06	11/27/2016 19:30	10369839067	Lead	7.3	15	ug/L
SGHS068-Mens BathRm #4 Sink#3	10/22/2016 08:07	11/27/2016 19:33	10369839068	Lead	3.2	15	ug/L
SGHS069-Mens BathRm #4 Sink#4	10/22/2016 08:08	11/27/2016 19:36	10369839069	Lead	6.4	15	ug/L
SGHS070-Concession Stand Rm Si	10/22/2016 08:10	11/27/2016 19:45	10369839070	Lead	13.4	15	ug/L
SGHS071-Water Fountain #4	10/22/2016 08:12	11/27/2016 19:48	10369839071	Lead	<0.10	15	ug/L
SGHS072-Water Fountain #5 Drin	10/22/2016 08:12	11/27/2016 19:51	10369839072	Lead	<0.10	15	ug/L
SGHS073-Water Fountain #5 Foun	10/22/2016 08:13	11/27/2016 19:54	10369839073	Lead	<0.10	15	ug/L
SGHS074-Water Fountain #6	10/22/2016 08:15	11/27/2016 19:57	10369839074	Lead	0.4	15	ug/L
SGHS075-Water Fountain #7	10/22/2016 08:16	11/27/2016 20:00	10369839075	Lead	0.45	15	ug/L
SGHS076-Womens BathRm #4Sink1	10/22/2016 08:18	11/27/2016 20:03	10369839076	Lead	1.9	15	ug/L
SGHS077-Womens BathRm #4Sink2	10/22/2016 08:19	11/27/2016 20:06	10369839077	Lead	11.8	15	ug/L
SGHS078-Womens BathRm #4Sink3	10/22/2016 08:19	11/27/2016 20:09	10369839078	Lead	7.6	15	ug/L
SGHS079-Womens BathRm #4Sink4	10/22/2016 08:22	11/27/2016 20:12	10369839079	Lead	4.8	15	ug/L
SGHS080-Water Fountain #8	10/22/2016 08:25	11/28/2016 00:33	10369839080	Lead	1.1	15	ug/L
SGHS081-Weight Rm Water Founta	10/22/2016 08:27	11/28/2016 11:16	10369839081	Lead	0.35	15	ug/L
SGHS082-PE Office Shower	10/22/2016 08:30	11/28/2016 11:23	10369839082	Lead	47.7	15	ug/L
SGHS083-Custodial Closet #1 Si	10/22/2016 08:35	11/28/2016 11:24	10369839083	Lead	8.2	15	ug/L
SGHS084-Art Rm A-3 Sink #1	10/22/2016 08:41	11/28/2016 11:25	10369839084	Lead	6.1	15	ug/L
SGHS085-Art Rm A-3 Sink #2	10/22/2016 08:41	11/28/2016 11:26	10369839085	Lead	5.0	15	ug/L
SGHS086-Art Rm A-3 Sink #3	10/22/2016 08:42	11/28/2016 11:27	10369839086	Lead	3.7	15	ug/L
SGHS087-Art Rm A-5 Sink #1	10/22/2016 08:43	11/28/2016 11:28	10369839087	Lead	6.3	15	ug/L
SGHS088-Art Rm A-5 Sink #2	10/22/2016 08:44	11/28/2016 11:29	10369839088	Lead	7.5	15	ug/L
SGHS089-ArtRm A-5 DarkRm Sink	10/22/2016 08:45	11/28/2016 11:30	10369839089	Lead	5.1	15	ug/L
SGHS090-Rm A-6 Office Sink	10/22/2016 08:46	11/28/2016 11:31	10369839090	Lead	18.8	15	ug/L
SGHS091-Nurses Office Sink	10/22/2016 08:48	11/28/2016 11:33	10369839091	Lead	13.8	15	ug/L
SGHS092-NursesOfficeBathRmSink	10/22/2016 08:48	11/28/2016 11:37	10369839092	Lead	8.5	15	ug/L
SGHS093-Mens BathRm #5 Sink	10/22/2016 08:50	11/28/2016 11:38	10369839093	Lead	15.7	15	ug/L
SGHS094-Womens BathRm #5 Sink	10/22/2016 08:51	11/28/2016 11:39	10369839094	Lead	10.0	15	ug/L
SGHS095-HandicapBathRm#1Sink#1	10/22/2016 08:53	11/28/2016 11:40	10369839095	Lead	15.7	15	ug/L
SGHS096-HandicapBathRm#1Sink#2	10/22/2016 08:53	11/28/2016 11:41	10369839096	Lead	5.6	15	ug/L
SGHS097-Custodial Closet#2 Sin	10/22/2016 08:54	11/28/2016 11:42	10369839097	Lead	20.8	15	ug/L
SGHS098-Water Fountain #9	10/22/2016 09:00	11/28/2016 11:44	10369839098	Lead	3.8	15	ug/L
SGHS099-Water Fountain #10	10/22/2016 09:01	11/28/2016 11:45	10369839099	Lead	4.4	15	ug/L
SGHS100-Boys BathRm#6 Sink #1	10/22/2016 09:05	11/28/2016 11:46	10369839100	Lead	5.8	15	ug/L
SGHS101-Boys BathRm#6 Sink #2	10/22/2016 09:05	11/28/2016 14:04	10369839101	Lead	4.3	15	ug/L
SGHS102-Boys BathRm#6 Sink #3	10/22/2016 09:06	11/28/2016 14:09	10369839102	Lead	3.7	15	ug/L

SGHS103-Boys BathRm#6 Sink #4	10/22/2016 09:07	11/28/2016 14:10	10369839103	Lead	0.1	15	ug/L
SGHS104-Girls BathRm#6 Sink #1	10/22/2016 09:09	11/28/2016 14:13	10369839104	Lead	6.7	15	ug/L
SGHS105-Girls BathRm#6 Sink #2	10/22/2016 09:10	11/28/2016 14:14	10369839105	Lead	5.5	15	ug/L
SGHS106-Girls BathRm#6 Sink #3	10/22/2016 09:11	11/28/2016 14:15	10369839106	Lead	4.6	15	ug/L
SGHS107-Girls BathRm#6 Sink #4	10/22/2016 09:12	11/28/2016 14:16	10369839107	Lead	8.4	15	ug/L
SGHS108-Girls BathRm#6 Sink #5	10/22/2016 09:13	11/28/2016 14:17	10369839108	Lead	5.6	15	ug/L
SGHS109-Science Rm D-3 Sink #1	10/22/2016 09:24	11/28/2016 14:18	10369839109	Lead	4.4	15	ug/L
SGHS110-Science Rm D-3 Sink #2	10/22/2016 09:24	11/28/2016 14:20	10369839110	Lead	36.0	15	ug/L
SGHS111-Science Rm D-3 Sink #3	10/22/2016 09:25	11/28/2016 14:21	10369839111	Lead	35.2	15	ug/L
SGHS112-Science Rm D-3 Sink #4	10/22/2016 09:26	11/28/2016 14:23	10369839112	Lead	5.1	15	ug/L
SGHS113-Science Rm D-3 Sink #5	10/22/2016 09:27	11/28/2016 14:28	10369839113	Lead	5.0	15	ug/L
SGHS114-Science Rm D-3 Sink #6	10/22/2016 09:27	11/28/2016 14:29	10369839114	Lead	5.8	15	ug/L
SGHS115-Science Rm D-3 Sink #7	10/22/2016 09:28	11/28/2016 14:30	10369839115	Lead	5.3	15	ug/L
SGHS116-Science Rm D-3 Sink #8	10/22/2016 09:28	11/28/2016 14:32	10369839116	Lead	5.2	15	ug/L
SGHS117-Science Rm D-3 Sink #9	10/22/2016 09:30	11/28/2016 14:33	10369839117	Lead	5.2	15	ug/L
SGHS118-ScienceRm D-3 Sink #10	10/22/2016 09:30	11/28/2016 14:34	10369839118	Lead	10.4	15	ug/L
SGHS119-ScienceRm D-3 Sink #11	10/22/2016 09:31	11/28/2016 14:35	10369839119	Lead	8.6	15	ug/L
SGHS120-ScienceRm D-3 Sink #12	10/22/2016 09:32	11/28/2016 14:36	10369839120	Lead	43.4	15	ug/L
SGHS121-ScienceRm D-3 Sink #13	10/22/2016 09:33	11/28/2016 13:29	10369839121	Lead	12.4	15	ug/L
SGHS122-Handicap BathRm Mens#2	10/22/2016 09:35	11/28/2016 13:36	10369839122	Lead	9.5	15	ug/L
SGHS123-HandicapBathRmWomens#3	10/22/2016 09:35	11/28/2016 13:37	10369839123	Lead	13.1	15	ug/L
SGHS124-Science Rm D-5 Sink	10/22/2016 09:37	11/28/2016 13:38	10369839124	Lead	7.4	15	ug/L
SGHS125-Science Rm D-6 Sink	10/22/2016 09:38	11/28/2016 13:39	10369839125	Lead	1.3	15	ug/L
SGHS126-Rm 208 Office Sink	10/22/2016 09:40	11/28/2016 13:40	10369839126	Lead	11.1	15	ug/L
SGHS127-Science Rm D-7 Sink #1	10/22/2016 09:42	11/28/2016 13:41	10369839127	Lead	2.8	15	ug/L
SGHS128-Science Rm D-7 Sink #2	10/22/2016 09:43	11/28/2016 13:42	10369839128	Lead	5.9	15	ug/L
SGHS129-Science Rm D-7 Sink #3	10/22/2016 09:44	11/28/2016 13:43	10369839129	Lead	3.5	15	ug/L
SGHS130-Science Rm D-7 Sink #4	10/22/2016 09:44	11/28/2016 13:47	10369839130	Lead	5.4	15	ug/L
SGHS131-Science Rm D-7 Sink #5	10/22/2016 09:45	11/28/2016 13:48	10369839131	Lead	3.4	15	ug/L
SGHS132-Science Rm D-7 Sink #6	10/22/2016 09:46	11/28/2016 13:50	10369839132	Lead	12.7	15	ug/L
SGHS133-Science Rm D-7 Sink #7	10/22/2016 09:47	11/28/2016 13:51	10369839133	Lead	6.6	15	ug/L
SGHS134-Science Rm D-7 Sink #8	10/22/2016 09:47	11/28/2016 13:52	10369839134	Lead	18.1	15	ug/L
SGHS135-Science Rm D-7 Sink #9	10/22/2016 09:48	11/28/2016 13:53	10369839135	Lead	6.1	15	ug/L
SGHS136-ScienceRm D-7 Sink #10	10/22/2016 09:49	11/28/2016 13:54	10369839136	Lead	13.7	15	ug/L
SGHS137-ScienceRm D-7 Sink #11	10/22/2016 09:50	11/28/2016 13:56	10369839137	Lead	2.8	15	ug/L
SGHS138-ScienceRm D-7 Sink #12	10/22/2016 09:51	11/28/2016 13:57	10369839138	Lead	3.9	15	ug/L
SGHS139-ScienceRm D-9 Sink #1	10/22/2016 09:52	11/28/2016 14:02	10369839139	Lead	4.2	15	ug/L
SGHS140-ScienceRm D-9 Sink #2	10/22/2016 09:53	11/28/2016 14:03	10369839140	Lead	3.0	15	ug/L
SGHS141-ScienceRm D-10 Sink	10/22/2016 09:54	11/28/2016 12:56	10369839141	Lead	8.3	15	ug/L
SGHS142-Art Rm B-29 Sink #1	10/22/2016 09:57	11/28/2016 13:01	10369839142	Lead	9.7	15	ug/L
SGHS143-Art Rm B-29 Sink #2	10/22/2016 09:57	11/28/2016 13:02	10369839143	Lead	6.6	15	ug/L
SGHS144-Art Rm B-29 Sink #3	10/22/2016 09:58	11/28/2016 13:03	10369839144	Lead	5.6	15	ug/L
SGHS145-Art Rm B-29 Sink #4	10/22/2016 09:58	11/28/2016 13:04	10369839145	Lead	5.5	15	ug/L
SGHS146-Rm B-28 Sink	10/22/2016 10:00	11/28/2016 13:07	10369839146	Lead	43.4	15	ug/L
SGHS147-Foreign Lang Office Si	10/22/2016 10:01	11/28/2016 13:08	10369839147	Lead	44.7	15	ug/L
SGHS148-Rm B-26 Sink	10/22/2016 10:03	11/28/2016 13:10	10369839148	Lead	19.5	15	ug/L
SGHS149-Faculty Lounge Sink	10/22/2016 10:05	11/28/2016 13:11	10369839149	Lead	5.2	15	ug/L
SGHS150-FacultyLoungeBath1Sink	10/22/2016 10:06	11/28/2016 13:12	10369839150	Lead	19.9	15	ug/L
SGHS151-FacultyLoungeBath2Sink	10/22/2016 10:07	11/28/2016 13:13	10369839151	Lead	27.0	15	ug/L
SGHS152-Custodial Closet #3 Si	10/22/2016 10:09	11/28/2016 13:15	10369839152	Lead	26.4	15	ug/L
SGHS153-Boys BathRm #7 Sink #1	10/22/2016 10:10	11/28/2016 13:16	10369839153	Lead	65.9	15	ug/L
SGHS154-Boys BathRm #7 Sink #2	10/22/2016 10:11	11/28/2016 13:17	10369839154	Lead	49.0	15	ug/L

SGHS155-Boys BathRm #7 Sink #3	10/22/2016 10:12	11/28/2016 13:23	10369839155	Lead	97.7	15	ug/L
SGHS156-Boys BathRm #7 Sink #4	10/22/2016 10:13	11/28/2016 13:24	10369839156	Lead	15.3	15	ug/L
SGHS157-Boys BathRm #7 Sink #5	10/22/2016 10:14	11/28/2016 13:25	10369839157	Lead	36.4	15	ug/L
SGHS158-Water Fountain #11	10/22/2016 10:15	11/28/2016 13:26	10369839158	Lead	0.7	15	ug/L
SGHS159-Girls BathRm#7Sink#1	10/22/2016 10:17	11/28/2016 13:27	10369839159	Lead	106	15	ug/L
SGHS160-Girls BathRm#7Sink#2	10/22/2016 10:18	11/28/2016 13:28	10369839160	Lead	68.8	15	ug/L
SGHS161-Girls BathRm#7Sink#3	10/22/2016 10:19	11/28/2016 10:43	10369839161	Lead	25.6	15	ug/L
SGHS162-Girls BathRm#7Sink#4	10/22/2016 10:20	11/28/2016 10:48	10369839162	Lead	119	15	ug/L
SGHS163-Girls BathRm#7Sink#5	10/22/2016 10:20	11/28/2016 10:49	10369839163	Lead	92.0	15	ug/L
SGHS164-Social Study Office Si	10/22/2016 10:21	11/28/2016 10:50	10369839164	Lead	33.0	15	ug/L
SGHS165-Rm A-27 Sink	10/22/2016 10:23	11/28/2016 10:51	10369839165	Lead	238	15	ug/L
SGHS166-Water Fountain #12	10/22/2016 10:25	11/28/2016 10:52	10369839166	Lead	1.5	15	ug/L
SGHS167-Storage/BathRm Sink #1	10/22/2016 10:25	11/28/2016 10:53	10369839167	Lead	53.0	15	ug/L
SGHS168-Storage/BathRm Sink #2	10/22/2016 10:26	11/28/2016 10:56	10369839168	Lead	41.2	15	ug/L
SGHS169-Storage/BathRm Sink #3	10/22/2016 10:26	11/28/2016 10:57	10369839169	Lead	94.6	15	ug/L
SGHS170-PSJLM Rm A-30 Sink	10/22/2016 10:27	11/28/2016 15:46	10369839170	Lead	658	15	ug/L
SGHS171-Custodial Closet #4 Si	10/22/2016 10:28	11/28/2016 11:00	10369839171	Lead	97.9	15	ug/L
SGHS172-Water Fountain #12	10/22/2016 10:30	11/28/2016 11:02	10369839172	Lead	0.1	15	ug/L
SGHS173-Boys BathRm #8 Sink #1	10/22/2016 10:32	11/28/2016 11:03	10369839173	Lead	5.0	15	ug/L
SGHS174-Boys BathRm #8 Sink #2	10/22/2016 10:32	11/28/2016 11:04	10369839174	Lead	3.7	15	ug/L
SGHS175-Boys BathRm #8 Sink #3	10/22/2016 10:33	11/28/2016 11:05	10369839175	Lead	2.8	15	ug/L
SGHS176-Boys BathRm #8 Sink #4	10/22/2016 10:33	11/28/2016 11:06	10369839176	Lead	4.4	15	ug/L
SGHS177-Girls BathRm #8Sink #1	10/22/2016 10:34	11/28/2016 11:12	10369839177	Lead	8.4	15	ug/L
SGHS178-Girls BathRm #8Sink #2	10/22/2016 10:35	11/28/2016 11:13	10369839178	Lead	6.1	15	ug/L
SGHS179-Girls BathRm #8Sink #3	10/22/2016 10:36	11/28/2016 11:14	10369839179	Lead	8.4	15	ug/L
SGHS180-Girls BathRm #8Sink #4	10/22/2016 10:36	11/28/2016 11:15	10369839180	Lead	7.7	15	ug/L
SGHS181-Custodial Closet #5 Si	10/22/2016 10:37	11/27/2016 17:27	10369839181	Lead	119	15	ug/L
SGHS182-ScienceRm D-13 Sink #1	10/22/2016 10:40	11/27/2016 17:39	10369839182	Lead	19.9	15	ug/L
SGHS183-ScienceRm D-13 Sink #2	10/22/2016 10:40	11/27/2016 17:42	10369839183	Lead	3.2	15	ug/L
SGHS184-ScienceRm D-13 Sink #3	10/22/2016 10:41	11/27/2016 17:45	10369839184	Lead	1.1	15	ug/L
SGHS185-Mens BathRm #9 Sink	10/22/2016 10:43	11/27/2016 17:48	10369839185	Lead	66.1	15	ug/L
SGHS186-Womens BathRm #9 Sink	10/22/2016 10:44	11/27/2016 17:57	10369839186	Lead	7.2	15	ug/L
SGHS187-Rm D-14 Office Sink	10/22/2016 10:45	11/27/2016 18:00	10369839187	Lead	34.8	15	ug/L
SGHS188-Rm D-15 Office Sink	10/22/2016 10:46	11/27/2016 18:03	10369839188	Lead	92.8	15	ug/L
SGHS189-Science Rm D-18 Sink#1	10/22/2016 10:48	11/27/2016 18:06	10369839189	Lead	1.7	15	ug/L
SGHS190-Science Rm D-18 Sink#2	10/22/2016 10:48	11/27/2016 18:09	10369839190	Lead	1.6	15	ug/L
SGHS191-Science Rm D-18 Sink#3	10/22/2016 10:49	11/27/2016 18:12	10369839191	Lead	2.3	15	ug/L
SGHS192-Science Rm D-18 Sink#4	10/22/2016 10:49	11/27/2016 18:15	10369839192	Lead	7.7	15	ug/L
SGHS193-Science Rm D-18 Sink#5	10/22/2016 10:50	11/27/2016 18:18	10369839193	Lead	3.4	15	ug/L
SGHS194-Science Rm D-18 Sink#6	10/22/2016 10:51	11/27/2016 18:21	10369839194	Lead	2.2	15	ug/L
SGHS195-Science Rm D-18 Sink#7	10/22/2016 10:52	11/27/2016 18:24	10369839195	Lead	1.5	15	ug/L
SGHS196-Science Rm D-18 Sink#8	10/22/2016 10:53	11/27/2016 18:39	10369839196	Lead	1.9	15	ug/L
SGHS197-Science Rm D-18 Sink#9	10/22/2016 10:54	11/27/2016 18:42	10369839197	Lead	13.5	15	ug/L
SGHS198-ScienceRm D-18 Sink#10	10/22/2016 10:54	11/27/2016 18:45	10369839198	Lead	1.4	15	ug/L
SGHS199-ScienceRm D-18 Sink#11	10/22/2016 10:55	11/27/2016 18:48	10369839199	Lead	1.9	15	ug/L
SGHS200-ScienceRm D-18 Sink#12	10/22/2016 10:55	11/27/2016 18:51	10369839200	Lead	1.9	15	ug/L
SGHS201-ScienceRmD-18HoodSink1	10/22/2016 10:56	11/27/2016 15:51	10369839201	Lead	78.9	15	ug/L
SGHS202-ScienceRmD-18HoodSink2	10/22/2016 10:56	11/27/2016 16:09	10369839202	Lead	30.0	15	ug/L
SGHS203-ScienceRmD-18HoodSink3	10/22/2016 10:57	11/27/2016 16:12	10369839203	Lead	23.7	15	ug/L
SGHS204-ScienceRmD-18HoodSink4	10/22/2016 10:57	11/27/2016 16:15	10369839204	Lead	259	15	ug/L
SGHS205-ScienceRm D-20 Sink	10/22/2016 10:58	11/27/2016 16:18	10369839205	Lead	50.8	15	ug/L
SGHS206-ScienceRmD-20HoodSink	10/22/2016 10:59	11/27/2016 16:21	10369839206	Lead	35.4	15	ug/L

SGHS207-ScienceRm D-19 Sink #1	10/22/2016 11:00	11/27/2016 16:24	10369839207	Lead	5.2	15	ug/L
SGHS208-ScienceRm D-19 Sink #2	10/22/2016 11:01	11/27/2016 16:27	10369839208	Lead	69.6	15	ug/L
SGHS209-ScienceRm D-21 Sink #1	10/22/2016 11:03	11/27/2016 16:30	10369839209	Lead	5.8	15	ug/L
SGHS210-ScienceRm D-21 Sink #2	10/22/2016 11:04	11/27/2016 16:33	10369839210	Lead	262	15	ug/L
SGHS211-ScienceRm D-21 Sink #3	10/22/2016 11:04	11/27/2016 16:36	10369839211	Lead	6.8	15	ug/L
SGHS212-ScienceRm D-22 Sink #1	10/22/2016 11:05	11/27/2016 16:45	10369839212	Lead	3.0	15	ug/L
SGHS213-ScienceRm D-22 Sink #2	10/22/2016 11:06	11/27/2016 16:48	10369839213	Lead	39.9	15	ug/L
SGHS214-ScienceRm D-22 Sink #3	10/22/2016 11:07	11/27/2016 16:51	10369839214	Lead	12.2	15	ug/L
SGHS215-ScienceRm D-22 Sink #4	10/22/2016 11:08	11/27/2016 16:54	10369839215	Lead	125	15	ug/L
SGHS216-ScienceRm D-22 Sink #5	10/22/2016 11:09	11/27/2016 16:57	10369839216	Lead	191	15	ug/L
SGHS217-ScienceRm D-22 Sink #6	10/22/2016 11:10	11/27/2016 17:00	10369839217	Lead	18.0	15	ug/L
SGHS218-ScienceRm D-22 Sink #7	10/22/2016 11:11	11/27/2016 17:03	10369839218	Lead	1.7	15	ug/L
SGHS219-ScienceRm D-22 Sink #8	10/22/2016 11:11	11/27/2016 17:06	10369839219	Lead	2.5	15	ug/L
SGHS220-ScienceRm D-22 Sink #9	10/22/2016 11:12	11/27/2016 17:09	10369839220	Lead	12.1	15	ug/L
SGHS221-ScienceRm D-22Sink #10	10/22/2016 11:13	11/28/2016 14:47	10369839221	Lead	5.4	15	ug/L
SGHS222-ScienceRm D-22Sink #11	10/22/2016 11:14	11/28/2016 14:48	10369839222	Lead	86.1	15	ug/L
SGHS223-ScienceRm D-22Sink #12	10/22/2016 11:15	11/28/2016 14:49	10369839223	Lead	2.6	15	ug/L
SGHS224-ScienceRmD-22HoodSink1	10/22/2016 11:16	11/28/2016 14:52	10369839224	Lead	60.7	15	ug/L
SGHS225-ScienceRmD-22HoodSink2	10/22/2016 11:16	11/28/2016 14:53	10369839225	Lead	262	15	ug/L
SGHS226-ScienceRmD-22HoodSink3	10/22/2016 11:17	11/28/2016 14:54	10369839226	Lead	88.9	15	ug/L
SGHS227-ScienceRmD-22HoodSink4	10/22/2016 11:18	11/28/2016 14:55	10369839227	Lead	286	15	ug/L
SGHS228-ScienceRmD-3 Hood Sink	10/22/2016 11:23	11/28/2016 14:58	10369839228	Lead	132	15	ug/L
SGHS229-Exterior Faucet #1Main	10/22/2016 11:29	11/28/2016 14:59	10369839229	Lead	284	15	ug/L
SGHS230-Exterior Faucet #2Libr	10/22/2016 11:30	11/28/2016 15:00	10369839230	Lead	37.1	15	ug/L
SGHS231-Exterior Faucet #3Adj	10/22/2016 11:32	11/28/2016 15:01	10369839231	Lead	39.6	15	ug/L
SGHS232-Exterior Faucet #4Conc	10/22/2016 11:45	11/28/2016 15:02	10369839232	Lead	5.5	15	ug/L
SGHS233-Exterior Faucet #5Base	10/22/2016 11:48	11/28/2016 15:07	10369839233	Lead	128	15	ug/L
SGHS234-Exterior WaterFountain	10/22/2016 11:49	11/28/2016 15:09	10369839234	Lead	6.7	15	ug/L
SGHS235-PaintShopDarkRm Sink	10/22/2016 11:25	11/28/2016 15:10	10369839235	Lead	13.4	15	ug/L

NYSDOH Action Level for Lead of 15 ppb