

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
SGMS 001-Girls Bathrm. #1 (sin	10/16/2016 06:03	11/23/2016 15:58	10369390001	Lead	1.8	15	ug/L
SGMS 002-Boys Bathrm. #1 (sink	10/16/2016 06:04	11/23/2016 16:00	10369390002	Lead	2.7	15	ug/L
SGMS 003-Water Fountain #1	10/16/2016 06:06	11/23/2016 16:02	10369390003	Lead	0.39	15	ug/L
SGMS 004-Nurse's Office (sink)	10/16/2016 06:10	11/22/2016 23:38	10369390004	Lead	2.5	15	ug/L
SGMS 005-Nurse's Office Bathrm	10/16/2016 06:10	11/22/2016 23:39	10369390005	Lead	1.8	15	ug/L
SGMS 006-Main Office Bathrm (s	10/16/2016 06:12	11/22/2016 23:40	10369390006	Lead	2.3	15	ug/L
SGMS 007-Custodial Closet #1 R	10/16/2016 06:14	11/22/2016 23:41	10369390007	Lead	110	15	ug/L
SGMS 008-Art Rm. 107 (sink)#1	10/16/2016 06:15	11/22/2016 23:43	10369390008	Lead	1.7	15	ug/L
SGMS 009-Art Rm. 107 (sink)#2	10/16/2016 06:17	11/22/2016 23:44	10369390009	Lead	2.5	15	ug/L
SGMS 010-Art Rm. 107 (sink)#3	10/16/2016 06:18	11/22/2016 23:45	10369390010	Lead	3.3	15	ug/L
SGMS 011-Rm. 111 Bathrm. (sink	10/16/2016 06:19	11/22/2016 23:46	10369390011	Lead	5.5	15	ug/L
SGMS 012-Boiler Rm. (sink)	10/16/2016 06:21	11/22/2016 23:48	10369390012	Lead	2.3	15	ug/L
SGMS 013-Boiler Rm. Bathrm. (s	10/16/2016 06:22	11/22/2016 23:52	10369390013	Lead	3.7	15	ug/L
SGMS 014-Men's Bathrm. #1, 1	10/16/2016 06:25	11/22/2016 23:53	10369390014	Lead	6.7	15	ug/L
SGMS 015-Men's Bathrm. #1, 2	10/16/2016 06:26	11/22/2016 23:54	10369390015	Lead	5.8	15	ug/L
SGMS 016-Men's Bathrm. #1, 3	10/16/2016 06:27	11/22/2016 23:55	10369390016	Lead	10.5	15	ug/L
SGMS 017-Men's Bathrm. #1, 4	10/16/2016 06:27	11/22/2016 23:56	10369390017	Lead	5.3	15	ug/L
SGMS 018-Womens Bathrm. #1, 1	10/16/2016 06:30	11/22/2016 23:57	10369390018	Lead	9.2	15	ug/L
SGMS 019-Womens Bathrm. #1, 2	10/16/2016 06:31	11/22/2016 23:58	10369390019	Lead	10.2	15	ug/L
SGMS 020-Womens Bathrm. #1, 3	10/16/2016 06:33	11/22/2016 23:59	10369390020	Lead	6.5	15	ug/L
SGMS 021-Womens Bathrm. #1, 4	10/16/2016 06:34	11/28/2016 12:23	10369390021	Lead	21.7	15	ug/L
SGMS 022-Water Fountain #2	10/16/2016 06:35	11/28/2016 12:30	10369390022	Lead	0.39	15	ug/L
SGMS 023-Water Fountain #3	10/16/2016 06:35	11/28/2016 12:31	10369390023	Lead	0.35	15	ug/L
SGMS 024-Girls Locker Rm #1, 1	10/16/2016 06:45	11/28/2016 12:32	10369390024	Lead	20.0	15	ug/L
SGMS 025-Girls Locker Rm #1, 2	10/16/2016 06:46	11/28/2016 12:33	10369390025	Lead	5.4	15	ug/L
SGMS 026-Boys Locker Rm. #1, 1	10/16/2016 06:48	11/28/2016 12:34	10369390026	Lead	6.7	15	ug/L
SGMS 027-Boys Locker Rm. #1, 2	10/16/2016 06:49	11/28/2016 12:35	10369390027	Lead	7.2	15	ug/L
SGMS 028-Water Fountain #4	10/16/2016 06:56	11/28/2016 12:37	10369390028	Lead	1.1	15	ug/L
SGMS 029-Boys Locker Rm. #2 (S	10/16/2016 07:04	11/28/2016 12:38	10369390029	Lead	6.3	15	ug/L
SGMS 030-Boys Locker Rm. #2 (W	10/16/2016 07:05	11/28/2016 12:41	10369390030	Lead	2.5	15	ug/L
SGMS 031-Boys Locker Rm. #2 Rm	10/16/2016 07:06	11/30/2016 02:45	10369390031	Lead	9.2	15	ug/L
SGMS 032-Girls Locker Rm#2 (si	10/16/2016 07:10	11/28/2016 12:42	10369390032	Lead	1.1	15	ug/L
SGMS 033-Girls Locker Rm#2 (wa	10/16/2016 07:11	11/28/2016 12:45	10369390033	Lead	4.9	15	ug/L
SGMS 034-Girls Locker Rm#2 rm	10/16/2016 07:12	11/28/2016 12:46	10369390034	Lead	5.9	15	ug/L
SGMS 035-Custodial Closet #2 (10/16/2016 07:15	11/28/2016 12:47	10369390035	Lead	7.9	15	ug/L
SGMS 036-Boys Bathrm. #2(washs	10/16/2016 07:21	11/28/2016 12:48	10369390036	Lead	1.4	15	ug/L
SGMS 037-Girls Bathrm. #2 (was	10/16/2016 07:25	11/28/2016 12:49	10369390037	Lead	1.6	15	ug/L
SGMS 038-Water Fountain #5	10/16/2016 07:30	11/28/2016 12:50	10369390038	Lead	1.0	15	ug/L
SGMS 039-Kitchen Rm 110 sink1	10/16/2016 07:32	11/30/2016 02:57	10369390039	Lead	6.6	15	ug/L
SGMS 040-Kitchen Rm 110 sink2	10/16/2016 07:32	11/28/2016 12:51	10369390040	Lead	46.8	15	ug/L
SGMS 041-Kitchen Rm 110 sink3	10/16/2016 07:34	11/28/2016 09:32	10369390041	Lead	6.9	15	ug/L
SGMS 042-Kitchen Rm.110 dish h	10/16/2016 07:35	11/28/2016 09:39	10369390042	Lead	1.8	15	ug/L
SGMS 043-Kitchen Rm.110 bathrm	10/16/2016 07:37	11/28/2016 09:40	10369390043	Lead	44.6	15	ug/L
SGMS 045-Home Ed Rm 143 sink 2	10/16/2016 07:40	11/28/2016 09:41	10369390044	Lead	7.8	15	ug/L
SGMS 046-Home Ed Rm 143 sink 3	10/16/2016 07:41	11/28/2016 09:42	10369390045	Lead	7.9	15	ug/L
SGMS 047-Home Ed Rm 143 sink 4	10/16/2016 07:42	11/28/2016 09:43	10369390046	Lead	9.9	15	ug/L
SGMS 048-Art Rm. 141 (sink)#1	10/16/2016 07:45	11/28/2016 09:44	10369390047	Lead	21.0	15	ug/L
SGMS 049-Art Rm. 141 (sink)#2	10/16/2016 07:46	11/28/2016 09:45	10369390048	Lead	8.6	15	ug/L
SGMS 050-Art Rm. 141 (sink)#3	10/16/2016 07:47	11/28/2016 09:46	10369390049	Lead	7.5	15	ug/L
SGMS 051-Art Rm. 141 (sink)#4	10/16/2016 07:48	11/28/2016 09:50	10369390050	Lead	7.6	15	ug/L

SGMS 052-Tech Rm. 137 (sink)#1	10/16/2016 07:50	11/28/2016 09:51	10369390051	Lead	17.0	15	ug/L
SGMS 053-Tech Rm. 137 (sink)#2	10/16/2016 07:50	11/28/2016 09:54	10369390052	Lead	9.5	15	ug/L
SGMS 054-Tech Rm. 137 (sink)#3	10/16/2016 07:51	11/28/2016 09:55	10369390053	Lead	9.9	15	ug/L
SGMS 055-Custodial Closet #3 (10/16/2016 07:55	11/28/2016 09:56	10369390054	Lead	2.9	15	ug/L
SGMS 056-Handicap Bathrm. #1 (10/16/2016 07:59	11/28/2016 09:57	10369390055	Lead	1.7	15	ug/L
SGMS 057-Girls Bathrm #3 sink1	10/16/2016 08:02	11/28/2016 09:58	10369390056	Lead	4.5	15	ug/L
SGMS 058-Girls Bathrm #3 sink2	10/16/2016 08:03	11/28/2016 09:59	10369390057	Lead	7.0	15	ug/L
SGMS 059-Girls Bathrm #3 sink3	10/16/2016 08:05	11/28/2016 10:00	10369390058	Lead	5.2	15	ug/L
SGMS 060-Boys Bathrm #3 sink#1	10/16/2016 08:07	11/28/2016 10:06	10369390059	Lead	3.3	15	ug/L
SGMS 061-Boys Bathrm #3 sink#2	10/16/2016 08:08	11/28/2016 10:07	10369390060	Lead	4.4	15	ug/L
SGMS 062-Boys Bathrm #3 sink#3	10/16/2016 08:09	11/23/2016 12:21	10369390061	Lead	4.9	15	ug/L
SGMS 063-Water Fountain #6	10/16/2016 08:10	11/23/2016 12:27	10369390062	Lead	0.32	15	ug/L
SGMS 064-Water Fountain #7	10/16/2016 08:11	11/23/2016 12:29	10369390063	Lead	0.3	15	ug/L
SGMS 065-Science Rm.167 sink#1	10/16/2016 08:15	11/23/2016 12:30	10369390064	Lead	0.98	15	ug/L
SGMS 066-Science Rm.167 sink#2	10/16/2016 08:16	11/23/2016 12:32	10369390065	Lead	1.5	15	ug/L
SGMS 067-Science Rm.167 sink#3	10/16/2016 08:16	11/23/2016 12:36	10369390066	Lead	1.5	15	ug/L
SGMS 068-Science Rm.167 sink#4	10/16/2016 08:17	11/23/2016 12:37	10369390067	Lead	1.2	15	ug/L
SGMS 069-Copy Rm. 283 sink#1	10/16/2016 08:19	11/23/2016 12:38	10369390068	Lead	4.0	15	ug/L
SGMS 070-Copy Rm. 283 sink#2	10/16/2016 08:20	11/23/2016 12:40	10369390069	Lead	8.0	15	ug/L
SGMS 071-Handicap Bathrm. #2 (10/16/2016 08:22	11/23/2016 12:41	10369390070	Lead	1.9	15	ug/L
SGMS 072-Boys Bathrm #4, sink1	10/16/2016 08:23	11/23/2016 12:42	10369390071	Lead	4.7	15	ug/L
SGMS 073-Boys Bathrm #4, sink2	10/16/2016 08:23	11/23/2016 12:45	10369390072	Lead	4.5	15	ug/L
SGMS 074-Water Fountain #8	10/16/2016 08:25	11/23/2016 12:47	10369390073	Lead	0.44	15	ug/L
SGMS 075-Water Fountain #9	10/16/2016 08:26	11/23/2016 12:48	10369390074	Lead	0.48	15	ug/L
SGMS 076-Girls Bath#4 (sink)#1	10/16/2016 08:30	11/23/2016 12:53	10369390075	Lead	6.9	15	ug/L
SGMS 077-Girls Bath#4 (sink)#2	10/16/2016 08:31	11/23/2016 12:54	10369390076	Lead	4.7	15	ug/L
SGMS 078-Girls Bath#4 (sink)#3	10/16/2016 08:32	11/23/2016 12:56	10369390077	Lead	5.3	15	ug/L
SGMS 079-Science Rm 267 sink#1	10/16/2016 08:35	11/23/2016 12:57	10369390078	Lead	3.1	15	ug/L
SGMS 080-Science Rm 267 sink#2	10/16/2016 08:35	11/23/2016 12:59	10369390079	Lead	3.8	15	ug/L
SGMS 081-Science Rm 267 sink#3	10/16/2016 08:36	11/23/2016 13:00	10369390080	Lead	0.91	15	ug/L
SGMS 082-Science Rm 267 sink#4	10/16/2016 08:37	11/28/2016 00:39	10369390081	Lead	1.9	15	ug/L
SGMS 083-Library Office Rm 242	10/16/2016 08:39	11/28/2016 00:51	10369390082	Lead	0.85	15	ug/L
SGMS 084-Girls Bathrm #5 (sink	10/16/2016 08:41	11/28/2016 00:54	10369390083	Lead	4.1	15	ug/L
SGMS 085-Boys Bathrm #5 (sink)	10/16/2016 08:42	11/28/2016 01:03	10369390084	Lead	1.2	15	ug/L
SGMS 086-Water Fountain #10	10/16/2016 08:42	11/28/2016 01:06	10369390085	Lead	0.18	15	ug/L
SGMS 087-Science Rm.201(sink)1	10/16/2016 08:45	11/28/2016 01:09	10369390086	Lead	5.6	15	ug/L
SGMS 088-Science Rm.201(sink)2	10/16/2016 08:45	11/28/2016 01:12	10369390087	Lead	8.0	15	ug/L
SGMS 089-Science Rm.201(sink)3	10/16/2016 08:46	11/28/2016 01:15	10369390088	Lead	6.7	15	ug/L
SGMS 090-Science Rm.201(sink)4	10/16/2016 08:47	11/28/2016 01:18	10369390089	Lead	16.7	15	ug/L
SGMS 091-Science Rm.201(sink)5	10/16/2016 08:48	11/28/2016 01:21	10369390090	Lead	32.6	15	ug/L
SGMS 092-Science Rm 205 sink#1	10/16/2016 08:50	11/28/2016 01:24	10369390091	Lead	4.7	15	ug/L
SGMS 093-Science Rm 205 sink#2	10/16/2016 08:51	11/28/2016 01:27	10369390092	Lead	14.3	15	ug/L
SGMS 094-Science Rm 205 sink#3	10/16/2016 08:51	11/28/2016 01:30	10369390093	Lead	12.7	15	ug/L
SGMS 095-Science Rm 207 sink#1	10/16/2016 08:55	11/28/2016 01:39	10369390094	Lead	27.8	15	ug/L
SGMS 096-Science Rm 207 sink#2	10/16/2016 08:56	11/28/2016 01:42	10369390095	Lead	6.2	15	ug/L
SGMS 097-Science Rm 207 sink#3	10/16/2016 08:56	11/28/2016 01:45	10369390096	Lead	16.0	15	ug/L
SGMS 098-Science Rm 207 sink#4	10/16/2016 08:57	11/28/2016 01:48	10369390097	Lead	12.5	15	ug/L
SGMS 099-Science Rm 207 sink#5	10/16/2016 08:57	11/28/2016 01:51	10369390098	Lead	14.5	15	ug/L
SGMS 100-Science Rm 207 sink#6	10/16/2016 08:58	11/28/2016 01:54	10369390099	Lead	12.7	15	ug/L
SGMS 101-Science Rm 204 sink#1	10/16/2016 08:59	11/28/2016 01:57	10369390100	Lead	6.3	15	ug/L
SGMS 102-Science Rm 204 sink#2	10/16/2016 09:00	11/22/2016 22:24	10369390101	Lead	66.2	15	ug/L
SGMS 103-Custodial Closet #4 (10/16/2016 09:01	11/22/2016 22:31	10369390102	Lead	30.3	15	ug/L

SGMS 104-Girls Bathrm #6 (Wash	10/16/2016 09:03	11/22/2016 22:32	10369390103	Lead	1.3	15	ug/L
SGMS 105-Boys Bathrm #6 (Washes	10/16/2016 09:04	11/22/2016 22:34	10369390104	Lead	2.3	15	ug/L
SGMS 106-Water Fountain #11	10/16/2016 09:05	11/22/2016 22:35	10369390105	Lead	0.68	15	ug/L
SGMS 107-Faculty Rm 218 Mens B	10/16/2016 09:11	11/22/2016 22:36	10369390106	Lead	2.9	15	ug/L
SGMS 108-Faculty Rm 218 Womens	10/16/2016 09:12	11/23/2016 20:12	10369390107	Lead	3.2	15	ug/L
SGMS 109-Rm 218 Custodial Clos	10/16/2016 09:13	11/23/2016 20:13	10369390108	Lead	30.8	15	ug/L
SGMS 110-Rm. 236 (sink)	10/16/2016 09:15	11/23/2016 20:14	10369390109	Lead	1.4	15	ug/L
SGMS 111-Exterior Faucet #1	10/16/2016 09:25	11/23/2016 20:15	10369390110	Lead	1.8	15	ug/L
SGMS 112-Exterior Faucet #2	10/16/2016 09:25	11/30/2016 03:00	10369390111	Lead	22.7	15	ug/L
SGMS 113-Exterior Faucet #3	10/16/2016 09:25	11/23/2016 20:16	10369390112	Lead	11.1	15	ug/L

NYSDOH Action Level for Lead of 15 ppb