

November 30, 2016

Pete Zwack
Scotia-Glenville CSD
900 Preddice Parkway
Scotia, NY 12302

RE: Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

Dear Pete Zwack:

Enclosed are the analytical results for sample(s) received by the laboratory on November 04, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager

Enclosures

cc: Barbara Cintron, Scotia-Glenville CSD



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Minnesota Certification IDs

1700 Elm Street SE Suite 200, Minneapolis, MN 55414

Alaska Certification UST-107

525 N 8th Street, Salina, KS 67401

A2LA Certification #: 2926.01

Alaska Certification #: UST-078

Alaska Certification #MN00064

Alabama Certification #40770

Arizona Certification #: AZ-0014

Arkansas Certification #: 88-0680

California Certification #: 01155CA

Colorado Certification #Pace

Connecticut Certification #: PH-0256

EPA Region 8 Certification #: 8TMS-L

Florida/NELAP Certification #: E87605

Guam Certification #:14-008r

Georgia Certification #: 959

Georgia EPD #: Pace

Idaho Certification #: MN00064

Hawaii Certification #MN00064

Illinois Certification #: 200011

Indiana Certification#C-MN-01

Iowa Certification #: 368

Kansas Certification #: E-10167

Kentucky Dept of Envi. Protection - DW #90062

Kentucky Dept of Envi. Protection - WW #:90062

Louisiana DEQ Certification #: 3086

Louisiana DHH #: LA140001

Maine Certification #: 2013011

Maryland Certification #: 322

Michigan DEPH Certification #: 9909

Minnesota Certification #: 027-053-137

Mississippi Certification #: Pace

Montana Certification #: MT0092

Nevada Certification #: MN_00064

Nebraska Certification #: Pace

New Jersey Certification #: MN-002

New York Certification #: 11647

North Carolina Certification #: 530

North Carolina State Public Health #: 27700

North Dakota Certification #: R-036

Ohio EPA #: 4150

Ohio VAP Certification #: CL101

Oklahoma Certification #: 9507

Oregon Certification #: MN200001

Oregon Certification #: MN300001

Pennsylvania Certification #: 68-00563

Puerto Rico Certification

Saipan (CNMI) #:MP0003

South Carolina #:74003001

Texas Certification #: T104704192

Tennessee Certification #: 02818

Utah Certification #: MN000642013-4

Virginia DGS Certification #: 251

Virginia/VELAP Certification #: Pace

Washington Certification #: C486

West Virginia Certification #: 382

West Virginia DHHR #:9952C

Wisconsin Certification #: 999407970

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10369390001	SGMS 001-Girls Bathrm. #1 (sin	Water	10/16/16 06:03	11/04/16 09:30
10369390002	SGMS 002-Boys Bathrm. #1 (sink	Water	10/16/16 06:04	11/04/16 09:30
10369390003	SGMS 003-Water Fountain #1	Water	10/16/16 06:06	11/04/16 09:30
10369390004	SGMS 004-Nurse's Office (sink)	Water	10/16/16 06:10	11/04/16 09:30
10369390005	SGMS 005-Nurse's Office Bathrm	Water	10/16/16 06:10	11/04/16 09:30
10369390006	SGMS 006-Main Office Bathrm (s	Water	10/16/16 06:12	11/04/16 09:30
10369390007	SGMS 007-Custodial Closet #1 R	Water	10/16/16 06:14	11/04/16 09:30
10369390008	SGMS 008-Art Rm. 107 (sink)#1	Water	10/16/16 06:15	11/04/16 09:30
10369390009	SGMS 009-Art Rm. 107 (sink)#2	Water	10/16/16 06:17	11/04/16 09:30
10369390010	SGMS 010-Art Rm. 107 (sink)#3	Water	10/16/16 06:18	11/04/16 09:30
10369390011	SGMS 011-Rm. 111 Bathrm. (sink	Water	10/16/16 06:19	11/04/16 09:30
10369390012	SGMS 012-Boiler Rm. (sink)	Water	10/16/16 06:21	11/04/16 09:30
10369390013	SGMS 013-Boiler Rm. Bathrm. (s	Water	10/16/16 06:22	11/04/16 09:30
10369390014	SGMS 014-Men's Bathrm. #1, 1	Water	10/16/16 06:25	11/04/16 09:30
10369390015	SGMS 015-Men's Bathrm. #1, 2	Water	10/16/16 06:26	11/04/16 09:30
10369390016	SGMS 016-Men's Bathrm. #1, 3	Water	10/16/16 06:27	11/04/16 09:30
10369390017	SGMS 017-Men's Bathrm. #1, 4	Water	10/16/16 06:27	11/04/16 09:30
10369390018	SGMS 018-Womens Bathrm. #1, 1	Water	10/16/16 06:30	11/04/16 09:30
10369390019	SGMS 019-Womens Bathrm. #1, 2	Water	10/16/16 06:31	11/04/16 09:30
10369390020	SGMS 020-Womens Bathrm. #1, 3	Water	10/16/16 06:33	11/04/16 09:30
10369390021	SGMS 021-Womens Bathrm. #1, 4	Water	10/16/16 06:34	11/04/16 09:30
10369390022	SGMS 022-Water Fountain #2	Water	10/16/16 06:35	11/04/16 09:30
10369390023	SGMS 023-Water Fountain #3	Water	10/16/16 06:35	11/04/16 09:30
10369390024	SGMS 024-Girls Locker Rm #1, 1	Water	10/16/16 06:45	11/04/16 09:30
10369390025	SGMS 025-Girls Locker Rm #1, 2	Water	10/16/16 06:46	11/04/16 09:30
10369390026	SGMS 026-Boys Locker Rm. #1, 1	Water	10/16/16 06:48	11/04/16 09:30
10369390027	SGMS 027-Boys Locker Rm. #1, 2	Water	10/16/16 06:49	11/04/16 09:30
10369390028	SGMS 028-Water Fountain #4	Water	10/16/16 06:56	11/04/16 09:30
10369390029	SGMS 029-Boys Locker Rm. #2 (S	Water	10/16/16 07:04	11/04/16 09:30
10369390030	SGMS 030-Boys Locker Rm. #2 (W	Water	10/16/16 07:05	11/04/16 09:30
10369390031	SGMS 031-Boys Locker Rm. #2 Rm	Water	10/16/16 07:06	11/04/16 09:30
10369390032	SGMS 032-Girls Locker Rm#2 (si	Water	10/16/16 07:10	11/04/16 09:30
10369390033	SGMS 033-Girls Locker Rm#2 (wa	Water	10/16/16 07:11	11/04/16 09:30
10369390034	SGMS 034-Girls Locker Rm#2 rm	Water	10/16/16 07:12	11/04/16 09:30
10369390035	SGMS 035-Custodial Closet #2 (Water	10/16/16 07:15	11/04/16 09:30
10369390036	SGMS 036-Boys Bathrm. #2(washs	Water	10/16/16 07:21	11/04/16 09:30

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10369390037	SGMS 037-Girls Bathrm. #2 (was	Water	10/16/16 07:25	11/04/16 09:30
10369390038	SGMS 038-Water Fountain #5	Water	10/16/16 07:30	11/04/16 09:30
10369390039	SGMS 039-Kitchen Rm 110 sink1	Water	10/16/16 07:32	11/04/16 09:30
10369390040	SGMS 040-Kitchen Rm 110 sink2	Water	10/16/16 07:32	11/04/16 09:30
10369390041	SGMS 041-Kitchen Rm 110 sink3	Water	10/16/16 07:34	11/04/16 09:30
10369390042	SGMS 042-Kitchen Rm.110 dish h	Water	10/16/16 07:35	11/04/16 09:30
10369390043	SGMS 043-Kitchen Rm.110 bathrm	Water	10/16/16 07:37	11/04/16 09:30
10369390044	SGMS 045-Home Ed Rm 143 sink 2	Water	10/16/16 07:40	11/04/16 09:30
10369390045	SGMS 046-Home Ed Rm 143 sink 3	Water	10/16/16 07:41	11/04/16 09:30
10369390046	SGMS 047-Home Ed Rm 143 sink 4	Water	10/16/16 07:42	11/04/16 09:30
10369390047	SGMS 048-Art Rm. 141 (sink)#1	Water	10/16/16 07:45	11/04/16 09:30
10369390048	SGMS 049-Art Rm. 141 (sink)#2	Water	10/16/16 07:46	11/04/16 09:30
10369390049	SGMS 050-Art Rm. 141 (sink)#3	Water	10/16/16 07:47	11/04/16 09:30
10369390050	SGMS 051-Art Rm. 141 (sink)#4	Water	10/16/16 07:48	11/04/16 09:30
10369390051	SGMS 052-Tech Rm. 137 (sink)#1	Water	10/16/16 07:50	11/04/16 09:30
10369390052	SGMS 053-Tech Rm. 137 (sink)#2	Water	10/16/16 07:50	11/04/16 09:30
10369390053	SGMS 054-Tech Rm. 137 (sink)#3	Water	10/16/16 07:51	11/04/16 09:30
10369390054	SGMS 055-Custodial Closet #3 (Water	10/16/16 07:55	11/04/16 09:30
10369390055	SGMS 056-Handicap Bathrm. #1 (Water	10/16/16 07:59	11/04/16 09:30
10369390056	SGMS 057-Girls Bathrm #3 sink1	Water	10/16/16 08:02	11/04/16 09:30
10369390057	SGMS 058-Girls Bathrm #3 sink2	Water	10/16/16 08:03	11/04/16 09:30
10369390058	SGMS 059-Girls Bathrm #3 sink3	Water	10/16/16 08:05	11/04/16 09:30
10369390059	SGMS 060-Boys Bathrm #3 sink#1	Water	10/16/16 08:07	11/04/16 09:30
10369390060	SGMS 061-Boys Bathrm #3 sink#2	Water	10/16/16 08:08	11/04/16 09:30
10369390061	SGMS 062-Boys Bathrm #3 sink#3	Water	10/16/16 08:09	11/04/16 09:30
10369390062	SGMS 063-Water Fountain #6	Water	10/16/16 08:10	11/04/16 09:30
10369390063	SGMS 064-Water Fountain #7	Water	10/16/16 08:11	11/04/16 09:30
10369390064	SGMS 065-Science Rm.167 sink#1	Water	10/16/16 08:15	11/04/16 09:30
10369390065	SGMS 066-Science Rm.167 sink#2	Water	10/16/16 08:16	11/04/16 09:30
10369390066	SGMS 067-Science Rm.167 sink#3	Water	10/16/16 08:16	11/04/16 09:30
10369390067	SGMS 068-Science Rm.167 sink#4	Water	10/16/16 08:17	11/04/16 09:30
10369390068	SGMS 069-Copy Rm. 283 sink#1	Water	10/16/16 08:19	11/04/16 09:30
10369390069	SGMS 070-Copy Rm. 283 sink#2	Water	10/16/16 08:20	11/04/16 09:30
10369390070	SGMS 071-Handicap Bathrm. #2 (Water	10/16/16 08:22	11/04/16 09:30
10369390071	SGMS 072-Boys Bathrm #4, sink1	Water	10/16/16 08:23	11/04/16 09:30
10369390072	SGMS 073-Boys Bathrm #4, sink2	Water	10/16/16 08:23	11/04/16 09:30

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10369390073	SGMS 074-Water Fountain #8	Water	10/16/16 08:25	11/04/16 09:30
10369390074	SGMS 075-Water Fountain #9	Water	10/16/16 08:26	11/04/16 09:30
10369390075	SGMS 076-Girls Bath#4 (sink)#1	Water	10/16/16 08:30	11/04/16 09:30
10369390076	SGMS 077-Girls Bath#4 (sink)#2	Water	10/16/16 08:31	11/04/16 09:30
10369390077	SGMS 078-Girls Bath#4 (sink)#3	Water	10/16/16 08:32	11/04/16 09:30
10369390078	SGMS 079-Science Rm 267 sink#1	Water	10/16/16 08:35	11/04/16 09:30
10369390079	SGMS 080-Science Rm 267 sink#2	Water	10/16/16 08:35	11/04/16 09:30
10369390080	SGMS 081-Science Rm 267 sink#3	Water	10/16/16 08:36	11/04/16 09:30
10369390081	SGMS 082-Science Rm 267 sink#4	Water	10/16/16 08:37	11/04/16 09:30
10369390082	SGMS 083-Library Office Rm 242	Water	10/16/16 08:39	11/04/16 09:30
10369390083	SGMS 084-Girls Bathrm #5 (sink	Water	10/16/16 08:41	11/04/16 09:30
10369390084	SGMS 085-Boys Bathrm #5 (sink)	Water	10/16/16 08:42	11/04/16 09:30
10369390085	SGMS 086-Water Fountain #10	Water	10/16/16 08:42	11/04/16 09:30
10369390086	SGMS 087-Science Rm.201(sink)1	Water	10/16/16 08:45	11/04/16 09:30
10369390087	SGMS 088-Science Rm.201(sink)2	Water	10/16/16 08:45	11/04/16 09:30
10369390088	SGMS 089-Science Rm.201(sink)3	Water	10/16/16 08:46	11/04/16 09:30
10369390089	SGMS 090-Science Rm.201(sink)4	Water	10/16/16 08:47	11/04/16 09:30
10369390090	SGMS 091-Science Rm.201(sink)5	Water	10/16/16 08:48	11/04/16 09:30
10369390091	SGMS 092-Science Rm 205 sink#1	Water	10/16/16 08:50	11/04/16 09:30
10369390092	SGMS 093-Science Rm 205 sink#2	Water	10/16/16 08:51	11/04/16 09:30
10369390093	SGMS 094-Science Rm 205 sink#3	Water	10/16/16 08:51	11/04/16 09:30
10369390094	SGMS 095-Science Rm 207 sink#1	Water	10/16/16 08:55	11/04/16 09:30
10369390095	SGMS 096-Science Rm 207 sink#2	Water	10/16/16 08:56	11/04/16 09:30
10369390096	SGMS 097-Science Rm 207 sink#3	Water	10/16/16 08:56	11/04/16 09:30
10369390097	SGMS 098-Science Rm 207 sink#4	Water	10/16/16 08:57	11/04/16 09:30
10369390098	SGMS 099-Science Rm 207 sink#5	Water	10/16/16 08:57	11/04/16 09:30
10369390099	SGMS 100-Science Rm 207 sink#6	Water	10/16/16 08:58	11/04/16 09:30
10369390100	SGMS 101-Science Rm 204 sink#1	Water	10/16/16 08:59	11/04/16 09:30
10369390101	SGMS 102-Science Rm 204 sink#2	Water	10/16/16 09:00	11/04/16 09:30
10369390102	SGMS 103-Custodial Closet #4 (Water	10/16/16 09:01	11/04/16 09:30
10369390103	SGMS 104-Girls Bathrm #6 (Wash	Water	10/16/16 09:03	11/04/16 09:30
10369390104	SGMS 105-Boys Bathrm #6 (Washes	Water	10/16/16 09:04	11/04/16 09:30
10369390105	SGMS 106-Water Fountain #11	Water	10/16/16 09:05	11/04/16 09:30
10369390106	SGMS 107-Faculty Rm 218 Mens B	Water	10/16/16 09:11	11/04/16 09:30
10369390107	SGMS 108-Faculty Rm 218 Womens	Water	10/16/16 09:12	11/04/16 09:30
10369390108	SGMS 109-Rm 218 Custodial Clos	Water	10/16/16 09:13	11/04/16 09:30

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10369390109	SGMS 110-Rm. 236 (sink)	Water	10/16/16 09:15	11/04/16 09:30
10369390110	SGMS 111-Exterior Faucet #1	Water	10/16/16 09:25	11/04/16 09:30
10369390111	SGMS 112-Exterior Faucet #2	Water	10/16/16 09:25	11/04/16 09:30
10369390112	SGMS 113-Exterior Faucet #3	Water	10/16/16 09:25	11/04/16 09:30

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10369390001	SGMS 001-Girls Bathrm. #1 (sin	EPA 200.8	WBS	1	PASI-M
10369390002	SGMS 002-Boys Bathrm. #1 (sink	EPA 200.8	WBS	1	PASI-M
10369390003	SGMS 003-Water Fountain #1	EPA 200.8	WBS	1	PASI-M
10369390004	SGMS 004-Nurse's Office (sink)	EPA 200.8	WBS	1	PASI-M
10369390005	SGMS 005-Nurse's Office Bathrm	EPA 200.8	WBS	1	PASI-M
10369390006	SGMS 006-Main Office Bathrm (s	EPA 200.8	WBS	1	PASI-M
10369390007	SGMS 007-Custodial Closet #1 R	EPA 200.8	WBS	1	PASI-M
10369390008	SGMS 008-Art Rm. 107 (sink)#1	EPA 200.8	WBS	1	PASI-M
10369390009	SGMS 009-Art Rm. 107 (sink)#2	EPA 200.8	WBS	1	PASI-M
10369390010	SGMS 010-Art Rm. 107 (sink)#3	EPA 200.8	WBS	1	PASI-M
10369390011	SGMS 011-Rm. 111 Bathrm. (sink	EPA 200.8	WBS	1	PASI-M
10369390012	SGMS 012-Boiler Rm. (sink)	EPA 200.8	WBS	1	PASI-M
10369390013	SGMS 013-Boiler Rm. Bathrm. (s	EPA 200.8	WBS	1	PASI-M
10369390014	SGMS 014-Men's Bathrm. #1, 1	EPA 200.8	WBS	1	PASI-M
10369390015	SGMS 015-Men's Bathrm. #1, 2	EPA 200.8	WBS	1	PASI-M
10369390016	SGMS 016-Men's Bathrm. #1, 3	EPA 200.8	WBS	1	PASI-M
10369390017	SGMS 017-Men's Bathrm. #1, 4	EPA 200.8	WBS	1	PASI-M
10369390018	SGMS 018-Womens Bathrm. #1, 1	EPA 200.8	WBS	1	PASI-M
10369390019	SGMS 019-Womens Bathrm. #1, 2	EPA 200.8	WBS	1	PASI-M
10369390020	SGMS 020-Womens Bathrm. #1, 3	EPA 200.8	WBS	1	PASI-M
10369390021	SGMS 021-Womens Bathrm. #1, 4	EPA 200.8	TT3	1	PASI-M
10369390022	SGMS 022-Water Fountain #2	EPA 200.8	TT3	1	PASI-M
10369390023	SGMS 023-Water Fountain #3	EPA 200.8	TT3	1	PASI-M
10369390024	SGMS 024-Girls Locker Rm #1, 1	EPA 200.8	TT3	1	PASI-M
10369390025	SGMS 025-Girls Locker Rm #1, 2	EPA 200.8	TT3	1	PASI-M
10369390026	SGMS 026-Boys Locker Rm. #1, 1	EPA 200.8	TT3	1	PASI-M
10369390027	SGMS 027-Boys Locker Rm. #1, 2	EPA 200.8	TT3	1	PASI-M
10369390028	SGMS 028-Water Fountain #4	EPA 200.8	TT3	1	PASI-M
10369390029	SGMS 029-Boys Locker Rm. #2 (S	EPA 200.8	TT3	1	PASI-M
10369390030	SGMS 030-Boys Locker Rm. #2 (W	EPA 200.8	TT3	1	PASI-M
10369390031	SGMS 031-Boys Locker Rm. #2 Rm	EPA 200.8	RJS	1	PASI-M
10369390032	SGMS 032-Girls Locker Rm#2 (si	EPA 200.8	TT3	1	PASI-M
10369390033	SGMS 033-Girls Locker Rm#2 (wa	EPA 200.8	TT3	1	PASI-M
10369390034	SGMS 034-Girls Locker Rm#2 rm	EPA 200.8	TT3	1	PASI-M
10369390035	SGMS 035-Custodial Closet #2 (EPA 200.8	TT3	1	PASI-M
10369390036	SGMS 036-Boys Bathrm. #2(washs	EPA 200.8	TT3	1	PASI-M
10369390037	SGMS 037-Girls Bathrm. #2 (was	EPA 200.8	TT3	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10369390038	SGMS 038-Water Fountain #5	EPA 200.8	TT3	1	PASI-M
10369390039	SGMS 039-Kitchen Rm 110 sink1	EPA 200.8	RJS	1	PASI-M
10369390040	SGMS 040-Kitchen Rm 110 sink2	EPA 200.8	TT3	1	PASI-M
10369390041	SGMS 041-Kitchen Rm 110 sink3	EPA 200.8	TT3	1	PASI-M
10369390042	SGMS 042-Kitchen Rm.110 dish h	EPA 200.8	TT3	1	PASI-M
10369390043	SGMS 043-Kitchen Rm.110 bathrm	EPA 200.8	TT3	1	PASI-M
10369390044	SGMS 045-Home Ed Rm 143 sink 2	EPA 200.8	TT3	1	PASI-M
10369390045	SGMS 046-Home Ed Rm 143 sink 3	EPA 200.8	TT3	1	PASI-M
10369390046	SGMS 047-Home Ed Rm 143 sink 4	EPA 200.8	TT3	1	PASI-M
10369390047	SGMS 048-Art Rm. 141 (sink)#1	EPA 200.8	TT3	1	PASI-M
10369390048	SGMS 049-Art Rm. 141 (sink)#2	EPA 200.8	TT3	1	PASI-M
10369390049	SGMS 050-Art Rm. 141 (sink)#3	EPA 200.8	TT3	1	PASI-M
10369390050	SGMS 051-Art Rm. 141 (sink)#4	EPA 200.8	TT3	1	PASI-M
10369390051	SGMS 052-Tech Rm. 137 (sink)#1	EPA 200.8	TT3	1	PASI-M
10369390052	SGMS 053-Tech Rm. 137 (sink)#2	EPA 200.8	TT3	1	PASI-M
10369390053	SGMS 054-Tech Rm. 137 (sink)#3	EPA 200.8	TT3	1	PASI-M
10369390054	SGMS 055-Custodial Closet #3 (EPA 200.8	TT3	1	PASI-M
10369390055	SGMS 056-Handicap Bathrm. #1 (EPA 200.8	TT3	1	PASI-M
10369390056	SGMS 057-Girls Bathrm #3 sink1	EPA 200.8	TT3	1	PASI-M
10369390057	SGMS 058-Girls Bathrm #3 sink2	EPA 200.8	TT3	1	PASI-M
10369390058	SGMS 059-Girls Bathrm #3 sink3	EPA 200.8	TT3	1	PASI-M
10369390059	SGMS 060-Boys Bathrm #3 sink#1	EPA 200.8	TT3	1	PASI-M
10369390060	SGMS 061-Boys Bathrm #3 sink#2	EPA 200.8	TT3	1	PASI-M
10369390061	SGMS 062-Boys Bathrm #3 sink#3	EPA 200.8	WBS	1	PASI-M
10369390062	SGMS 063-Water Fountain #6	EPA 200.8	WBS	1	PASI-M
10369390063	SGMS 064-Water Fountain #7	EPA 200.8	WBS	1	PASI-M
10369390064	SGMS 065-Science Rm.167 sink#1	EPA 200.8	WBS	1	PASI-M
10369390065	SGMS 066-Science Rm.167 sink#2	EPA 200.8	WBS	1	PASI-M
10369390066	SGMS 067-Science Rm.167 sink#3	EPA 200.8	WBS	1	PASI-M
10369390067	SGMS 068-Science Rm.167 sink#4	EPA 200.8	WBS	1	PASI-M
10369390068	SGMS 069-Copy Rm. 283 sink#1	EPA 200.8	WBS	1	PASI-M
10369390069	SGMS 070-Copy Rm. 283 sink#2	EPA 200.8	WBS	1	PASI-M
10369390070	SGMS 071-Handicap Bathrm. #2 (EPA 200.8	WBS	1	PASI-M
10369390071	SGMS 072-Boys Bathrm #4, sink1	EPA 200.8	WBS	1	PASI-M
10369390072	SGMS 073-Boys Bathrm #4, sink2	EPA 200.8	WBS	1	PASI-M
10369390073	SGMS 074-Water Fountain #8	EPA 200.8	WBS	1	PASI-M
10369390074	SGMS 075-Water Fountain #9	EPA 200.8	WBS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10369390075	SGMS 076-Girls Bath#4 (sink)#1	EPA 200.8	WBS	1	PASI-M
10369390076	SGMS 077-Girls Bath#4 (sink)#2	EPA 200.8	WBS	1	PASI-M
10369390077	SGMS 078-Girls Bath#4 (sink)#3	EPA 200.8	WBS	1	PASI-M
10369390078	SGMS 079-Science Rm 267 sink#1	EPA 200.8	WBS	1	PASI-M
10369390079	SGMS 080-Science Rm 267 sink#2	EPA 200.8	WBS	1	PASI-M
10369390080	SGMS 081-Science Rm 267 sink#3	EPA 200.8	WBS	1	PASI-M
10369390081	SGMS 082-Science Rm 267 sink#4	EPA 200.8	RJS	1	PASI-M
10369390082	SGMS 083-Library Office Rm 242	EPA 200.8	RJS	1	PASI-M
10369390083	SGMS 084-Girls Bathrm #5 (sink	EPA 200.8	RJS	1	PASI-M
10369390084	SGMS 085-Boys Bathrm #5 (sink)	EPA 200.8	RJS	1	PASI-M
10369390085	SGMS 086-Water Fountain #10	EPA 200.8	RJS	1	PASI-M
10369390086	SGMS 087-Science Rm.201(sink)1	EPA 200.8	RJS	1	PASI-M
10369390087	SGMS 088-Science Rm.201(sink)2	EPA 200.8	RJS	1	PASI-M
10369390088	SGMS 089-Science Rm.201(sink)3	EPA 200.8	RJS	1	PASI-M
10369390089	SGMS 090-Science Rm.201(sink)4	EPA 200.8	RJS	1	PASI-M
10369390090	SGMS 091-Science Rm.201(sink)5	EPA 200.8	RJS	1	PASI-M
10369390091	SGMS 092-Science Rm 205 sink#1	EPA 200.8	RJS	1	PASI-M
10369390092	SGMS 093-Science Rm 205 sink#2	EPA 200.8	RJS	1	PASI-M
10369390093	SGMS 094-Science Rm 205 sink#3	EPA 200.8	RJS	1	PASI-M
10369390094	SGMS 095-Science Rm 207 sink#1	EPA 200.8	RJS	1	PASI-M
10369390095	SGMS 096-Science Rm 207 sink#2	EPA 200.8	RJS	1	PASI-M
10369390096	SGMS 097-Science Rm 207 sink#3	EPA 200.8	RJS	1	PASI-M
10369390097	SGMS 098-Science Rm 207 sink#4	EPA 200.8	RJS	1	PASI-M
10369390098	SGMS 099-Science Rm 207 sink#5	EPA 200.8	RJS	1	PASI-M
10369390099	SGMS 100-Science Rm 207 sink#6	EPA 200.8	RJS	1	PASI-M
10369390100	SGMS 101-Science Rm 204 sink#1	EPA 200.8	RJS	1	PASI-M
10369390101	SGMS 102-Science Rm 204 sink#2	EPA 200.8	WBS	1	PASI-M
10369390102	SGMS 103-Custodial Closet #4 (EPA 200.8	WBS	1	PASI-M
10369390103	SGMS 104-Girls Bathrm #6 (Wash	EPA 200.8	WBS	1	PASI-M
10369390104	SGMS 105-Boys Bathrm #6 (Washes	EPA 200.8	WBS	1	PASI-M
10369390105	SGMS 106-Water Fountain #11	EPA 200.8	WBS	1	PASI-M
10369390106	SGMS 107-Faculty Rm 218 Mens B	EPA 200.8	WBS	1	PASI-M
10369390107	SGMS 108-Faculty Rm 218 Womens	EPA 200.8	WBS	1	PASI-M
10369390108	SGMS 109-Rm 218 Custodial Clos	EPA 200.8	WBS	1	PASI-M
10369390109	SGMS 110-Rm. 236 (sink)	EPA 200.8	WBS	1	PASI-M
10369390110	SGMS 111-Exterior Faucet #1	EPA 200.8	WBS	1	PASI-M
10369390111	SGMS 112-Exterior Faucet #2	EPA 200.8	RJS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10369390112	SGMS 113-Exterior Faucet #3	EPA 200.8	WBS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample: SGMS 001-Girls Bathrm. #1 Lab ID: 10369390001 Collected: 10/16/16 06:03 Received: 11/04/16 09:30 Matrix: Water								
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	1.8	ug/L	0.10	1		11/23/16 15:58	7439-92-1	
Sample: SGMS 002-Boys Bathrm. #1 Lab ID: 10369390002 Collected: 10/16/16 06:04 Received: 11/04/16 09:30 Matrix: Water								
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	2.7	ug/L	0.10	1		11/23/16 16:00	7439-92-1	
Sample: SGMS 003-Water Fountain #1 Lab ID: 10369390003 Collected: 10/16/16 06:06 Received: 11/04/16 09:30 Matrix: Water								
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	0.39	ug/L	0.10	1		11/23/16 16:02	7439-92-1	
Sample: SGMS 004-Nurse's Office (sink) Lab ID: 10369390004 Collected: 10/16/16 06:10 Received: 11/04/16 09:30 Matrix: Water								
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	2.5	ug/L	0.10	1		11/22/16 23:38	7439-92-1	
Sample: SGMS 005-Nurse's Office Bathrm Lab ID: 10369390005 Collected: 10/16/16 06:10 Received: 11/04/16 09:30 Matrix: Water								
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	1.8	ug/L	0.10	1		11/22/16 23:39	7439-92-1	
Sample: SGMS 006-Main Office Bathrm (s) Lab ID: 10369390006 Collected: 10/16/16 06:12 Received: 11/04/16 09:30 Matrix: Water								
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	2.3	ug/L	0.10	1		11/22/16 23:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample:	Lab ID:	Collected:	Received:	Matrix:				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: SGMS 007-Custodial Closet #1 R	Lab ID: 10369390007	10/16/16 06:14	11/04/16 09:30	Water				
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	110	ug/L	0.10	1		11/22/16 23:41	7439-92-1	
Sample: SGMS 008-Art Rm. 107 (sink)#1	Lab ID: 10369390008	10/16/16 06:15	11/04/16 09:30	Water				
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	1.7	ug/L	0.10	1		11/22/16 23:43	7439-92-1	
Sample: SGMS 009-Art Rm. 107 (sink)#2	Lab ID: 10369390009	10/16/16 06:17	11/04/16 09:30	Water				
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	2.5	ug/L	0.10	1		11/22/16 23:44	7439-92-1	
Sample: SGMS 010-Art Rm. 107 (sink)#3	Lab ID: 10369390010	10/16/16 06:18	11/04/16 09:30	Water				
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	3.3	ug/L	0.10	1		11/22/16 23:45	7439-92-1	
Sample: SGMS 011-Rm. 111 Bathrm. (sink)	Lab ID: 10369390011	10/16/16 06:19	11/04/16 09:30	Water				
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	5.5	ug/L	0.10	1		11/22/16 23:46	7439-92-1	
Sample: SGMS 012-Boiler Rm. (sink)	Lab ID: 10369390012	10/16/16 06:21	11/04/16 09:30	Water				
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	2.3	ug/L	0.10	1		11/22/16 23:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample: SGMS 013-Boiler Rm. Bathrm. (s) **Lab ID: 10369390013** Collected: 10/16/16 06:22 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.7	ug/L	0.10	1		11/22/16 23:52	7439-92-1	

Sample: SGMS 014-Men's Bathrm. #1, 1 **Lab ID: 10369390014** Collected: 10/16/16 06:25 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.7	ug/L	0.10	1		11/22/16 23:53	7439-92-1	

Sample: SGMS 015-Men's Bathrm. #1, 2 **Lab ID: 10369390015** Collected: 10/16/16 06:26 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.8	ug/L	0.10	1		11/22/16 23:54	7439-92-1	

Sample: SGMS 016-Men's Bathrm. #1, 3 **Lab ID: 10369390016** Collected: 10/16/16 06:27 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	10.5	ug/L	0.10	1		11/22/16 23:55	7439-92-1	

Sample: SGMS 017-Men's Bathrm. #1, 4 **Lab ID: 10369390017** Collected: 10/16/16 06:27 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.3	ug/L	0.10	1		11/22/16 23:56	7439-92-1	

Sample: SGMS 018-Womens Bathrm. #1, 1 **Lab ID: 10369390018** Collected: 10/16/16 06:30 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	9.2	ug/L	0.10	1		11/22/16 23:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample: SGMS 019-Womens Bathrm. #1, 2	Lab ID: 10369390019	Collected: 10/16/16 06:31	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	10.2	ug/L	0.10	1		11/22/16 23:58	7439-92-1	

Sample: SGMS 020-Womens Bathrm. #1, 3	Lab ID: 10369390020	Collected: 10/16/16 06:33	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	6.5	ug/L	0.10	1		11/22/16 23:59	7439-92-1	

Sample: SGMS 021-Womens Bathrm. #1, 4	Lab ID: 10369390021	Collected: 10/16/16 06:34	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	21.7	ug/L	0.10	1		11/28/16 12:23	7439-92-1	

Sample: SGMS 022-Water Fountain #2	Lab ID: 10369390022	Collected: 10/16/16 06:35	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.39	ug/L	0.10	1		11/28/16 12:30	7439-92-1	

Sample: SGMS 023-Water Fountain #3	Lab ID: 10369390023	Collected: 10/16/16 06:35	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.35	ug/L	0.10	1		11/28/16 12:31	7439-92-1	

Sample: SGMS 024-Girls Locker Rm #1, 1	Lab ID: 10369390024	Collected: 10/16/16 06:45	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	20.0	ug/L	0.10	1		11/28/16 12:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

Sample: SGMS 025-Girls Locker Rm #1, 2		Lab ID: 10369390025	Collected: 10/16/16 06:46	Received: 11/04/16 09:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.4	ug/L	0.10	1		11/28/16 12:33	7439-92-1	
Sample: SGMS 026-Boys Locker Rm. #1, 1		Lab ID: 10369390026	Collected: 10/16/16 06:48	Received: 11/04/16 09:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.7	ug/L	0.10	1		11/28/16 12:34	7439-92-1	
Sample: SGMS 027-Boys Locker Rm. #1, 2		Lab ID: 10369390027	Collected: 10/16/16 06:49	Received: 11/04/16 09:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	7.2	ug/L	0.10	1		11/28/16 12:35	7439-92-1	
Sample: SGMS 028-Water Fountain #4		Lab ID: 10369390028	Collected: 10/16/16 06:56	Received: 11/04/16 09:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.1	ug/L	0.10	1		11/28/16 12:37	7439-92-1	
Sample: SGMS 029-Boys Locker Rm. #2 (S)		Lab ID: 10369390029	Collected: 10/16/16 07:04	Received: 11/04/16 09:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.3	ug/L	0.10	1		11/28/16 12:38	7439-92-1	
Sample: SGMS 030-Boys Locker Rm. #2 (W)		Lab ID: 10369390030	Collected: 10/16/16 07:05	Received: 11/04/16 09:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.5	ug/L	0.10	1		11/28/16 12:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 031-Boys Locker Rm. #2 Rm	10369390031	10/16/16 07:06	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS	Analytical Method: EPA 200.8 Preparation Method: EPA 200.8							
Lead	9.2	ug/L	0.10	1	11/28/16 13:26	11/30/16 02:45	7439-92-1	

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 032-Girls Locker Rm#2 (si	10369390032	10/16/16 07:10	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	1.1	ug/L	0.10	1		11/28/16 12:42	7439-92-1	

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 033-Girls Locker Rm#2 (wa	10369390033	10/16/16 07:11	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	4.9	ug/L	0.10	1		11/28/16 12:45	7439-92-1	

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 034-Girls Locker Rm#2 rm	10369390034	10/16/16 07:12	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	5.9	ug/L	0.10	1		11/28/16 12:46	7439-92-1	

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 035-Custodial Closet #2 (10369390035	10/16/16 07:15	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	7.9	ug/L	0.10	1		11/28/16 12:47	7439-92-1	

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 036-Boys Bathrm. #2(washs	10369390036	10/16/16 07:21	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	1.4	ug/L	0.10	1		11/28/16 12:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample: SGMS 037-Girls Bathrm. #2 Lab ID: **10369390037** Collected: 10/16/16 07:25 Received: 11/04/16 09:30 Matrix: Water
(was

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.6	ug/L	0.10	1		11/28/16 12:49	7439-92-1	

Sample: SGMS 038-Water Fountain #5 Lab ID: **10369390038** Collected: 10/16/16 07:30 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.0	ug/L	0.10	1		11/28/16 12:50	7439-92-1	

Sample: SGMS 039-Kitchen Rm 110 sink1 Lab ID: **10369390039** Collected: 10/16/16 07:32 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8						
Lead	6.6	ug/L	0.10	1	11/28/16 13:26	11/30/16 02:57	7439-92-1	

Sample: SGMS 040-Kitchen Rm 110 sink2 Lab ID: **10369390040** Collected: 10/16/16 07:32 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	46.8	ug/L	0.10	1		11/28/16 12:51	7439-92-1	

Sample: SGMS 041-Kitchen Rm 110 sink3 Lab ID: **10369390041** Collected: 10/16/16 07:34 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.9	ug/L	0.10	1		11/28/16 09:32	7439-92-1	

Sample: SGMS 042-Kitchen Rm.110 dish h Lab ID: **10369390042** Collected: 10/16/16 07:35 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.8	ug/L	0.10	1		11/28/16 09:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample: SGMS 043-Kitchen Rm.110 bathrm **Lab ID: 10369390043** Collected: 10/16/16 07:37 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	44.6	ug/L	0.10	1		11/28/16 09:40	7439-92-1	

Sample: SGMS 045-Home Ed Rm 143 sink 2 **Lab ID: 10369390044** Collected: 10/16/16 07:40 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	7.8	ug/L	0.10	1		11/28/16 09:41	7439-92-1	

Sample: SGMS 046-Home Ed Rm 143 sink 3 **Lab ID: 10369390045** Collected: 10/16/16 07:41 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	7.9	ug/L	0.10	1		11/28/16 09:42	7439-92-1	

Sample: SGMS 047-Home Ed Rm 143 sink 4 **Lab ID: 10369390046** Collected: 10/16/16 07:42 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	9.9	ug/L	0.10	1		11/28/16 09:43	7439-92-1	

Sample: SGMS 048-Art Rm. 141 (sink)#1 **Lab ID: 10369390047** Collected: 10/16/16 07:45 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	21.0	ug/L	0.10	1		11/28/16 09:44	7439-92-1	

Sample: SGMS 049-Art Rm. 141 (sink)#2 **Lab ID: 10369390048** Collected: 10/16/16 07:46 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	8.6	ug/L	0.10	1		11/28/16 09:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample:	Lab ID:	Collected:	Received:	Matrix:				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: SGMS 050-Art Rm. 141 (sink)#3	Lab ID: 10369390049	10/16/16 07:47	11/04/16 09:30	Water				
Analytical Method: EPA 200.8								
Lead	7.5	ug/L	0.10	1		11/28/16 09:46	7439-92-1	
Sample: SGMS 051-Art Rm. 141 (sink)#4	Lab ID: 10369390050	10/16/16 07:48	11/04/16 09:30	Water				
Analytical Method: EPA 200.8								
Lead	7.6	ug/L	0.10	1		11/28/16 09:50	7439-92-1	
Sample: SGMS 052-Tech Rm. 137 (sink)#1	Lab ID: 10369390051	10/16/16 07:50	11/04/16 09:30	Water				
Analytical Method: EPA 200.8								
Lead	17.0	ug/L	0.10	1		11/28/16 09:51	7439-92-1	
Sample: SGMS 053-Tech Rm. 137 (sink)#2	Lab ID: 10369390052	10/16/16 07:50	11/04/16 09:30	Water				
Analytical Method: EPA 200.8								
Lead	9.5	ug/L	0.10	1		11/28/16 09:54	7439-92-1	
Sample: SGMS 054-Tech Rm. 137 (sink)#3	Lab ID: 10369390053	10/16/16 07:51	11/04/16 09:30	Water				
Analytical Method: EPA 200.8								
Lead	9.9	ug/L	0.10	1		11/28/16 09:55	7439-92-1	
Sample: SGMS 055-Custodial Closet #3 (Lab ID: 10369390054	10/16/16 07:55	11/04/16 09:30	Water				
Analytical Method: EPA 200.8								
Lead	2.9	ug/L	0.10	1		11/28/16 09:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 056-Handicap Bathrm. #1 (10369390055	10/16/16 07:59	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	1.7	ug/L	0.10	1		11/28/16 09:57	7439-92-1	

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 057-Girls Bathrm #3 sink1	10369390056	10/16/16 08:02	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	4.5	ug/L	0.10	1		11/28/16 09:58	7439-92-1	

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 058-Girls Bathrm #3 sink2	10369390057	10/16/16 08:03	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	7.0	ug/L	0.10	1		11/28/16 09:59	7439-92-1	

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 059-Girls Bathrm #3 sink3	10369390058	10/16/16 08:05	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	5.2	ug/L	0.10	1		11/28/16 10:00	7439-92-1	

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 060-Boys Bathrm #3 sink#1	10369390059	10/16/16 08:07	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	3.3	ug/L	0.10	1		11/28/16 10:06	7439-92-1	

Sample:	Lab ID:	Collected:	Received:	Matrix:				
SGMS 061-Boys Bathrm #3 sink#2	10369390060	10/16/16 08:08	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	4.4	ug/L	0.10	1		11/28/16 10:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample: SGMS 062-Boys Bathrm #3 sink#3 **Lab ID: 10369390061** Collected: 10/16/16 08:09 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.9	ug/L	0.10	1		11/23/16 12:21	7439-92-1	

Sample: SGMS 063-Water Fountain #6 **Lab ID: 10369390062** Collected: 10/16/16 08:10 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.32	ug/L	0.10	1		11/23/16 12:27	7439-92-1	

Sample: SGMS 064-Water Fountain #7 **Lab ID: 10369390063** Collected: 10/16/16 08:11 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.30	ug/L	0.10	1		11/23/16 12:29	7439-92-1	

Sample: SGMS 065-Science Rm.167 sink#1 **Lab ID: 10369390064** Collected: 10/16/16 08:15 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.98	ug/L	0.10	1		11/23/16 12:30	7439-92-1	

Sample: SGMS 066-Science Rm.167 sink#2 **Lab ID: 10369390065** Collected: 10/16/16 08:16 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.5	ug/L	0.10	1		11/23/16 12:32	7439-92-1	

Sample: SGMS 067-Science Rm.167 sink#3 **Lab ID: 10369390066** Collected: 10/16/16 08:16 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.5	ug/L	0.10	1		11/23/16 12:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample: SGMS 068-Science Rm.167 sink#4 **Lab ID: 10369390067** Collected: 10/16/16 08:17 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.2	ug/L	0.10	1		11/23/16 12:37	7439-92-1	

Sample: SGMS 069-Copy Rm. 283 sink#1 **Lab ID: 10369390068** Collected: 10/16/16 08:19 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.0	ug/L	0.10	1		11/23/16 12:38	7439-92-1	

Sample: SGMS 070-Copy Rm. 283 sink#2 **Lab ID: 10369390069** Collected: 10/16/16 08:20 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	8.0	ug/L	0.10	1		11/23/16 12:40	7439-92-1	

Sample: SGMS 071-Handicap Bathrm. #2 (**Lab ID: 10369390070** Collected: 10/16/16 08:22 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.9	ug/L	0.10	1		11/23/16 12:41	7439-92-1	

Sample: SGMS 072-Boys Bathrm #4, sink1 **Lab ID: 10369390071** Collected: 10/16/16 08:23 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.7	ug/L	0.10	1		11/23/16 12:42	7439-92-1	

Sample: SGMS 073-Boys Bathrm #4, sink2 **Lab ID: 10369390072** Collected: 10/16/16 08:23 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.5	ug/L	0.10	1		11/23/16 12:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample: SGMS 074-Water Fountain #8	Lab ID: 10369390073	Collected: 10/16/16 08:25	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.44	ug/L	0.10	1		11/23/16 12:47	7439-92-1	

Sample: SGMS 075-Water Fountain #9	Lab ID: 10369390074	Collected: 10/16/16 08:26	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.48	ug/L	0.10	1		11/23/16 12:48	7439-92-1	

Sample: SGMS 076-Girls Bath#4 (sink)#1	Lab ID: 10369390075	Collected: 10/16/16 08:30	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	6.9	ug/L	0.10	1		11/23/16 12:53	7439-92-1	

Sample: SGMS 077-Girls Bath#4 (sink)#2	Lab ID: 10369390076	Collected: 10/16/16 08:31	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	4.7	ug/L	0.10	1		11/23/16 12:54	7439-92-1	

Sample: SGMS 078-Girls Bath#4 (sink)#3	Lab ID: 10369390077	Collected: 10/16/16 08:32	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	5.3	ug/L	0.10	1		11/23/16 12:56	7439-92-1	

Sample: SGMS 079-Science Rm 267 sink#1	Lab ID: 10369390078	Collected: 10/16/16 08:35	Received: 11/04/16 09:30	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	3.1	ug/L	0.10	1		11/23/16 12:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample: SGMS 080-Science Rm 267 sink#2 **Lab ID: 10369390079** Collected: 10/16/16 08:35 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.8	ug/L	0.10	1		11/23/16 12:59	7439-92-1	

Sample: SGMS 081-Science Rm 267 sink#3 **Lab ID: 10369390080** Collected: 10/16/16 08:36 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.91	ug/L	0.10	1		11/23/16 13:00	7439-92-1	

Sample: SGMS 082-Science Rm 267 sink#4 **Lab ID: 10369390081** Collected: 10/16/16 08:37 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.9	ug/L	0.10	1		11/28/16 00:39	7439-92-1	

Sample: SGMS 083-Library Office Rm 242 **Lab ID: 10369390082** Collected: 10/16/16 08:39 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.85	ug/L	0.10	1		11/28/16 00:51	7439-92-1	

Sample: SGMS 084-Girls Bathrm #5 (sink) **Lab ID: 10369390083** Collected: 10/16/16 08:41 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.1	ug/L	0.10	1		11/28/16 00:54	7439-92-1	

Sample: SGMS 085-Boys Bathrm #5 (sink) **Lab ID: 10369390084** Collected: 10/16/16 08:42 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.2	ug/L	0.10	1		11/28/16 01:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample:	Lab ID:	Collected:	Received:	Matrix:				
Sample: SGMS 086-Water Fountain #10	Lab ID: 10369390085	10/16/16 08:42	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.18	ug/L	0.10	1		11/28/16 01:06	7439-92-1	
Sample: SGMS 087-Science Rm.201(sink)1	Lab ID: 10369390086	10/16/16 08:45	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.6	ug/L	0.10	1		11/28/16 01:09	7439-92-1	
Sample: SGMS 088-Science Rm.201(sink)2	Lab ID: 10369390087	10/16/16 08:45	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	8.0	ug/L	0.10	1		11/28/16 01:12	7439-92-1	
Sample: SGMS 089-Science Rm.201(sink)3	Lab ID: 10369390088	10/16/16 08:46	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.7	ug/L	0.10	1		11/28/16 01:15	7439-92-1	
Sample: SGMS 090-Science Rm.201(sink)4	Lab ID: 10369390089	10/16/16 08:47	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	16.7	ug/L	0.10	1		11/28/16 01:18	7439-92-1	
Sample: SGMS 091-Science Rm.201(sink)5	Lab ID: 10369390090	10/16/16 08:48	11/04/16 09:30	Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	32.6	ug/L	0.10	1		11/28/16 01:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: SGMS 092-Science Rm 205 sink#1

Lab ID: 10369390091 Collected: 10/16/16 08:50 Received: 11/04/16 09:30 Matrix: Water

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	4.7	ug/L	0.10	1		11/28/16 01:24	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: SGMS 093-Science Rm 205 sink#2

Lab ID: 10369390092 Collected: 10/16/16 08:51 Received: 11/04/16 09:30 Matrix: Water

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	14.3	ug/L	0.10	1		11/28/16 01:27	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: SGMS 094-Science Rm 205 sink#3

Lab ID: 10369390093 Collected: 10/16/16 08:51 Received: 11/04/16 09:30 Matrix: Water

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	12.7	ug/L	0.10	1		11/28/16 01:30	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: SGMS 095-Science Rm 207 sink#1

Lab ID: 10369390094 Collected: 10/16/16 08:55 Received: 11/04/16 09:30 Matrix: Water

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	27.8	ug/L	0.10	1		11/28/16 01:39	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: SGMS 096-Science Rm 207 sink#2

Lab ID: 10369390095 Collected: 10/16/16 08:56 Received: 11/04/16 09:30 Matrix: Water

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	6.2	ug/L	0.10	1		11/28/16 01:42	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: SGMS 097-Science Rm 207 sink#3

Lab ID: 10369390096 Collected: 10/16/16 08:56 Received: 11/04/16 09:30 Matrix: Water

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	16.0	ug/L	0.10	1		11/28/16 01:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Sample: SGMS 098-Science Rm 207 sink#4									
			Lab ID: 10369390097			Collected: 10/16/16 08:57		Received: 11/04/16 09:30 Matrix: Water	
Analytical Method: EPA 200.8									
Lead	12.5	ug/L	0.10	1		11/28/16 01:48	7439-92-1		
Sample: SGMS 099-Science Rm 207 sink#5									
			Lab ID: 10369390098			Collected: 10/16/16 08:57		Received: 11/04/16 09:30 Matrix: Water	
Analytical Method: EPA 200.8									
Lead	14.5	ug/L	0.10	1		11/28/16 01:51	7439-92-1		
Sample: SGMS 100-Science Rm 207 sink#6									
			Lab ID: 10369390099			Collected: 10/16/16 08:58		Received: 11/04/16 09:30 Matrix: Water	
Analytical Method: EPA 200.8									
Lead	12.7	ug/L	0.10	1		11/28/16 01:54	7439-92-1		
Sample: SGMS 101-Science Rm 204 sink#1									
			Lab ID: 10369390100			Collected: 10/16/16 08:59		Received: 11/04/16 09:30 Matrix: Water	
Analytical Method: EPA 200.8									
Lead	6.3	ug/L	0.10	1		11/28/16 01:57	7439-92-1		
Sample: SGMS 102-Science Rm 204 sink#2									
			Lab ID: 10369390101			Collected: 10/16/16 09:00		Received: 11/04/16 09:30 Matrix: Water	
Analytical Method: EPA 200.8									
Lead	66.2	ug/L	0.10	1		11/22/16 22:24	7439-92-1		
Sample: SGMS 103-Custodial Closet #4 (
			Lab ID: 10369390102			Collected: 10/16/16 09:01		Received: 11/04/16 09:30 Matrix: Water	
Analytical Method: EPA 200.8									
Lead	30.3	ug/L	0.10	1		11/22/16 22:31	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

Sample: SGMS 104-Girls Bathrm #6 (Wash) **Lab ID: 10369390103** Collected: 10/16/16 09:03 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.3	ug/L	0.10	1		11/22/16 22:32	7439-92-1	

Sample: SGMS 105-Boys Bathrm #6 (Washes) **Lab ID: 10369390104** Collected: 10/16/16 09:04 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.3	ug/L	0.10	1		11/22/16 22:34	7439-92-1	

Sample: SGMS 106-Water Fountain #11 **Lab ID: 10369390105** Collected: 10/16/16 09:05 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.68	ug/L	0.10	1		11/22/16 22:35	7439-92-1	

Sample: SGMS 107-Faculty Rm 218 Mens B **Lab ID: 10369390106** Collected: 10/16/16 09:11 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.9	ug/L	0.10	1		11/22/16 22:36	7439-92-1	

Sample: SGMS 108-Faculty Rm 218 Womens **Lab ID: 10369390107** Collected: 10/16/16 09:12 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.2	ug/L	0.10	1		11/23/16 20:12	7439-92-1	

Sample: SGMS 109-Rm 218 Custodial Clos **Lab ID: 10369390108** Collected: 10/16/16 09:13 Received: 11/04/16 09:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	30.8	ug/L	0.10	1		11/23/16 20:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Sample: SGMS 110-Rm. 236 (sink)		Lab ID: 10369390109	Collected: 10/16/16 09:15	Received: 11/04/16 09:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	1.4	ug/L	0.10	1		11/23/16 20:14	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

Sample: SGMS 111-Exterior Faucet #1		Lab ID: 10369390110	Collected: 10/16/16 09:25	Received: 11/04/16 09:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	1.8	ug/L	0.10	1		11/23/16 20:15	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

Sample: SGMS 112-Exterior Faucet #2		Lab ID: 10369390111	Collected: 10/16/16 09:25	Received: 11/04/16 09:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Analytical Method: EPA 200.8 Preparation Method: EPA 200.8

Lead	22.7	ug/L	0.10	1	11/28/16 13:26	11/30/16 03:00	7439-92-1	
------	-------------	------	------	---	----------------	----------------	-----------	--

Sample: SGMS 113-Exterior Faucet #3		Lab ID: 10369390112	Collected: 10/16/16 09:25	Received: 11/04/16 09:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	11.1	ug/L	0.10	1		11/23/16 20:16	7439-92-1	
------	-------------	------	------	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

QC Batch: 447459 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10369390107, 10369390108, 10369390109, 10369390110, 10369390112

METHOD BLANK: 2448189 Matrix: Water
Associated Lab Samples: 10369390107, 10369390108, 10369390109, 10369390110, 10369390112

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	11/23/16 19:41	

LABORATORY CONTROL SAMPLE: 2448190

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	96.8	97	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2456995 2456996

Parameter	Units	10369292241 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	0.44	100	100	103	105	103	105	70-130	2	20	

MATRIX SPIKE SAMPLE: 2456997

Parameter	Units	10369292251 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	0.43	100	105	105	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

QC Batch:	447631	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	ICPMS Metals, Drinking Water
Associated Lab Samples:	10369390001, 10369390002, 10369390003, 10369390004, 10369390005, 10369390006, 10369390007, 10369390008, 10369390009, 10369390010, 10369390011, 10369390012, 10369390013, 10369390014, 10369390015, 10369390016, 10369390017, 10369390018, 10369390019, 10369390020		

METHOD BLANK:	2449838	Matrix:	Water
Associated Lab Samples:	10369390001, 10369390002, 10369390003, 10369390004, 10369390005, 10369390006, 10369390007, 10369390008, 10369390009, 10369390010, 10369390011, 10369390012, 10369390013, 10369390014, 10369390015, 10369390016, 10369390017, 10369390018, 10369390019, 10369390020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	11/22/16 23:25	

LABORATORY CONTROL SAMPLE: 2449839

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	101	101	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2455975 2455976

Parameter	Units	10369390001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	1.8	100	100	99.2	108	97	106	70-130	8	20	

MATRIX SPIKE SAMPLE: 2455977

Parameter	Units	10369390011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.5	100	107	102	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

QC Batch: 447632 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10369390021, 10369390022, 10369390023, 10369390024, 10369390025, 10369390026, 10369390027, 10369390028, 10369390029, 10369390030, 10369390032, 10369390033, 10369390034, 10369390035, 10369390036, 10369390037, 10369390038, 10369390040

METHOD BLANK: 2449842 Matrix: Water
Associated Lab Samples: 10369390021, 10369390022, 10369390023, 10369390024, 10369390025, 10369390026, 10369390027, 10369390028, 10369390029, 10369390030, 10369390032, 10369390033, 10369390034, 10369390035, 10369390036, 10369390037, 10369390038, 10369390040

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	11/28/16 12:15	

LABORATORY CONTROL SAMPLE: 2449843

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	96.2	96	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2458018 2458019

Parameter	Units	10369390021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	21.7	100	100	116	119	94	97	70-130	2	20	

MATRIX SPIKE SAMPLE: 2458020

Parameter	Units	10369390032 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.1	100	95.1	94	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

QC Batch: 447633 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10369390041, 10369390042, 10369390043, 10369390044, 10369390045, 10369390046, 10369390047, 10369390048, 10369390049, 10369390050, 10369390051, 10369390052, 10369390053, 10369390054, 10369390055, 10369390056, 10369390057, 10369390058, 10369390059, 10369390060

METHOD BLANK: 2449846 Matrix: Water
Associated Lab Samples: 10369390041, 10369390042, 10369390043, 10369390044, 10369390045, 10369390046, 10369390047, 10369390048, 10369390049, 10369390050, 10369390051, 10369390052, 10369390053, 10369390054, 10369390055, 10369390056, 10369390057, 10369390058, 10369390059, 10369390060

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	11/28/16 09:23	

LABORATORY CONTROL SAMPLE: 2449847

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	95.3	95	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2457951 2457952

Parameter	Units	10369390041 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	6.9	100	100	104	101	97	94	70-130	3	20	

MATRIX SPIKE SAMPLE: 2457953

Parameter	Units	10369390051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	17.0	100	112	95	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

QC Batch: 447635 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10369390061, 10369390062, 10369390063, 10369390064, 10369390065, 10369390066, 10369390067, 10369390068, 10369390069, 10369390070, 10369390071, 10369390072, 10369390073, 10369390074, 10369390075, 10369390076, 10369390077, 10369390078, 10369390079, 10369390080

METHOD BLANK: 2449853 Matrix: Water
 Associated Lab Samples: 10369390061, 10369390062, 10369390063, 10369390064, 10369390065, 10369390066, 10369390067, 10369390068, 10369390069, 10369390070, 10369390071, 10369390072, 10369390073, 10369390074, 10369390075, 10369390076, 10369390077, 10369390078, 10369390079, 10369390080

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	11/23/16 12:18	

LABORATORY CONTROL SAMPLE: 2449854

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	102	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2455558 2455559

Parameter	Units	10369390061 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	4.9	100	100	99.4	98.4	94	93	70-130	1	20	

MATRIX SPIKE SAMPLE: 2455560

Parameter	Units	10369390071 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.7	100	101	97	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

QC Batch: 447636 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10369390081, 10369390082, 10369390083, 10369390084, 10369390085, 10369390086, 10369390087, 10369390088, 10369390089, 10369390090, 10369390091, 10369390092, 10369390093, 10369390094, 10369390095, 10369390096, 10369390097, 10369390098, 10369390099, 10369390100

METHOD BLANK: 2449859 Matrix: Water
 Associated Lab Samples: 10369390081, 10369390082, 10369390083, 10369390084, 10369390085, 10369390086, 10369390087, 10369390088, 10369390089, 10369390090, 10369390091, 10369390092, 10369390093, 10369390094, 10369390095, 10369390096, 10369390097, 10369390098, 10369390099, 10369390100

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	11/28/16 00:27	

LABORATORY CONTROL SAMPLE: 2449860

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	102	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2457587 2457588

Parameter	Units	10369390081 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	1.9	100	100	90.6	93.0	89	91	70-130	3	20	

MATRIX SPIKE SAMPLE: 2457589

Parameter	Units	10369390100 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	6.3	100	98.1	92	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

QC Batch: 447638 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10369390101, 10369390102, 10369390103, 10369390104, 10369390105, 10369390106

METHOD BLANK: 2449870 Matrix: Water
Associated Lab Samples: 10369390101, 10369390102, 10369390103, 10369390104, 10369390105, 10369390106

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	11/22/16 22:18	

LABORATORY CONTROL SAMPLE: 2449871

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	104	104	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2455958 2455959

Parameter	Units	10369390101 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	66.2	100	100	169	162	103	96	70-130	4	20	

MATRIX SPIKE SAMPLE: 2455960

Parameter	Units	10369532003 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.4	100	105	104	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

QC Batch: 448933 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET
Associated Lab Samples: 10369390031, 10369390039, 10369390111

METHOD BLANK: 2458009 Matrix: Water
Associated Lab Samples: 10369390031, 10369390039, 10369390111

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	11/30/16 02:03	

LABORATORY CONTROL SAMPLE: 2458010

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	102	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2458011 2458012

Parameter	Units	10369390031		MS		MSD		MS		MSD		% Rec Limits	RPD	Max RPD	Qual
		Result	Conc.	Spike Conc.	Spike Conc.	Result	Result	% Rec	% Rec						
Lead	ug/L	9.2	100	100	100	108	108	99	99	70-130	0	20			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10369390001	SGMS 001-Girls Bathrm. #1 (sin	EPA 200.8	447631		
10369390002	SGMS 002-Boys Bathrm. #1 (sink	EPA 200.8	447631		
10369390003	SGMS 003-Water Fountain #1	EPA 200.8	447631		
10369390004	SGMS 004-Nurse's Office (sink)	EPA 200.8	447631		
10369390005	SGMS 005-Nurse's Office Bathrm	EPA 200.8	447631		
10369390006	SGMS 006-Main Office Bathrm (s	EPA 200.8	447631		
10369390007	SGMS 007-Custodial Closet #1 R	EPA 200.8	447631		
10369390008	SGMS 008-Art Rm. 107 (sink)#1	EPA 200.8	447631		
10369390009	SGMS 009-Art Rm. 107 (sink)#2	EPA 200.8	447631		
10369390010	SGMS 010-Art Rm. 107 (sink)#3	EPA 200.8	447631		
10369390011	SGMS 011-Rm. 111 Bathrm. (sink	EPA 200.8	447631		
10369390012	SGMS 012-Boiler Rm. (sink)	EPA 200.8	447631		
10369390013	SGMS 013-Boiler Rm. Bathrm. (s	EPA 200.8	447631		
10369390014	SGMS 014-Men's Bathrm. #1, 1	EPA 200.8	447631		
10369390015	SGMS 015-Men's Bathrm. #1, 2	EPA 200.8	447631		
10369390016	SGMS 016-Men's Bathrm. #1, 3	EPA 200.8	447631		
10369390017	SGMS 017-Men's Bathrm. #1, 4	EPA 200.8	447631		
10369390018	SGMS 018-Womens Bathrm. #1, 1	EPA 200.8	447631		
10369390019	SGMS 019-Womens Bathrm. #1, 2	EPA 200.8	447631		
10369390020	SGMS 020-Womens Bathrm. #1, 3	EPA 200.8	447631		
10369390021	SGMS 021-Womens Bathrm. #1, 4	EPA 200.8	447632		
10369390022	SGMS 022-Water Fountain #2	EPA 200.8	447632		
10369390023	SGMS 023-Water Fountain #3	EPA 200.8	447632		
10369390024	SGMS 024-Girls Locker Rm #1, 1	EPA 200.8	447632		
10369390025	SGMS 025-Girls Locker Rm #1, 2	EPA 200.8	447632		
10369390026	SGMS 026-Boys Locker Rm. #1, 1	EPA 200.8	447632		
10369390027	SGMS 027-Boys Locker Rm. #1, 2	EPA 200.8	447632		
10369390028	SGMS 028-Water Fountain #4	EPA 200.8	447632		
10369390029	SGMS 029-Boys Locker Rm. #2 (S	EPA 200.8	447632		
10369390030	SGMS 030-Boys Locker Rm. #2 (W	EPA 200.8	447632		
10369390032	SGMS 032-Girls Locker Rm#2 (si	EPA 200.8	447632		
10369390033	SGMS 033-Girls Locker Rm#2 (wa	EPA 200.8	447632		
10369390034	SGMS 034-Girls Locker Rm#2 rm	EPA 200.8	447632		
10369390035	SGMS 035-Custodial Closet #2 (EPA 200.8	447632		
10369390036	SGMS 036-Boys Bathrm. #2(washs	EPA 200.8	447632		
10369390037	SGMS 037-Girls Bathrm. #2 (was	EPA 200.8	447632		
10369390038	SGMS 038-Water Fountain #5	EPA 200.8	447632		
10369390040	SGMS 040-Kitchen Rm 110 sink2	EPA 200.8	447632		
10369390041	SGMS 041-Kitchen Rm 110 sink3	EPA 200.8	447633		
10369390042	SGMS 042-Kitchen Rm.110 dish h	EPA 200.8	447633		
10369390043	SGMS 043-Kitchen Rm.110 bathrm	EPA 200.8	447633		
10369390044	SGMS 045-Home Ed Rm 143 sink 2	EPA 200.8	447633		
10369390045	SGMS 046-Home Ed Rm 143 sink 3	EPA 200.8	447633		
10369390046	SGMS 047-Home Ed Rm 143 sink 4	EPA 200.8	447633		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: 0821 Scotia Glenville Middle S

Pace Project No.: 10369390

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10369390047	SGMS 048-Art Rm. 141 (sink)#1	EPA 200.8	447633		
10369390048	SGMS 049-Art Rm. 141 (sink)#2	EPA 200.8	447633		
10369390049	SGMS 050-Art Rm. 141 (sink)#3	EPA 200.8	447633		
10369390050	SGMS 051-Art Rm. 141 (sink)#4	EPA 200.8	447633		
10369390051	SGMS 052-Tech Rm. 137 (sink)#1	EPA 200.8	447633		
10369390052	SGMS 053-Tech Rm. 137 (sink)#2	EPA 200.8	447633		
10369390053	SGMS 054-Tech Rm. 137 (sink)#3	EPA 200.8	447633		
10369390054	SGMS 055-Custodial Closet #3 (EPA 200.8	447633		
10369390055	SGMS 056-Handicap Bathrm. #1 (EPA 200.8	447633		
10369390056	SGMS 057-Girls Bathrm #3 sink1	EPA 200.8	447633		
10369390057	SGMS 058-Girls Bathrm #3 sink2	EPA 200.8	447633		
10369390058	SGMS 059-Girls Bathrm #3 sink3	EPA 200.8	447633		
10369390059	SGMS 060-Boys Bathrm #3 sink#1	EPA 200.8	447633		
10369390060	SGMS 061-Boys Bathrm #3 sink#2	EPA 200.8	447633		
10369390061	SGMS 062-Boys Bathrm #3 sink#3	EPA 200.8	447635		
10369390062	SGMS 063-Water Fountain #6	EPA 200.8	447635		
10369390063	SGMS 064-Water Fountain #7	EPA 200.8	447635		
10369390064	SGMS 065-Science Rm.167 sink#1	EPA 200.8	447635		
10369390065	SGMS 066-Science Rm.167 sink#2	EPA 200.8	447635		
10369390066	SGMS 067-Science Rm.167 sink#3	EPA 200.8	447635		
10369390067	SGMS 068-Science Rm.167 sink#4	EPA 200.8	447635		
10369390068	SGMS 069-Copy Rm. 283 sink#1	EPA 200.8	447635		
10369390069	SGMS 070-Copy Rm. 283 sink#2	EPA 200.8	447635		
10369390070	SGMS 071-Handicap Bathrm. #2 (EPA 200.8	447635		
10369390071	SGMS 072-Boys Bathrm #4, sink1	EPA 200.8	447635		
10369390072	SGMS 073-Boys Bathrm #4, sink2	EPA 200.8	447635		
10369390073	SGMS 074-Water Fountain #8	EPA 200.8	447635		
10369390074	SGMS 075-Water Fountain #9	EPA 200.8	447635		
10369390075	SGMS 076-Girls Bath#4 (sink)#1	EPA 200.8	447635		
10369390076	SGMS 077-Girls Bath#4 (sink)#2	EPA 200.8	447635		
10369390077	SGMS 078-Girls Bath#4 (sink)#3	EPA 200.8	447635		
10369390078	SGMS 079-Science Rm 267 sink#1	EPA 200.8	447635		
10369390079	SGMS 080-Science Rm 267 sink#2	EPA 200.8	447635		
10369390080	SGMS 081-Science Rm 267 sink#3	EPA 200.8	447635		
10369390081	SGMS 082-Science Rm 267 sink#4	EPA 200.8	447636		
10369390082	SGMS 083-Library Office Rm 242	EPA 200.8	447636		
10369390083	SGMS 084-Girls Bathrm #5 (sink	EPA 200.8	447636		
10369390084	SGMS 085-Boys Bathrm #5 (sink)	EPA 200.8	447636		
10369390085	SGMS 086-Water Fountain #10	EPA 200.8	447636		
10369390086	SGMS 087-Science Rm.201(sink)1	EPA 200.8	447636		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: 0821 Scotia Glenville Middle S
Pace Project No.: 10369390

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10369390087	SGMS 088-Science Rm.201(sink)2	EPA 200.8	447636		
10369390088	SGMS 089-Science Rm.201(sink)3	EPA 200.8	447636		
10369390089	SGMS 090-Science Rm.201(sink)4	EPA 200.8	447636		
10369390090	SGMS 091-Science Rm.201(sink)5	EPA 200.8	447636		
10369390091	SGMS 092-Science Rm 205 sink#1	EPA 200.8	447636		
10369390092	SGMS 093-Science Rm 205 sink#2	EPA 200.8	447636		
10369390093	SGMS 094-Science Rm 205 sink#3	EPA 200.8	447636		
10369390094	SGMS 095-Science Rm 207 sink#1	EPA 200.8	447636		
10369390095	SGMS 096-Science Rm 207 sink#2	EPA 200.8	447636		
10369390096	SGMS 097-Science Rm 207 sink#3	EPA 200.8	447636		
10369390097	SGMS 098-Science Rm 207 sink#4	EPA 200.8	447636		
10369390098	SGMS 099-Science Rm 207 sink#5	EPA 200.8	447636		
10369390099	SGMS 100-Science Rm 207 sink#6	EPA 200.8	447636		
10369390100	SGMS 101-Science Rm 204 sink#1	EPA 200.8	447636		
10369390101	SGMS 102-Science Rm 204 sink#2	EPA 200.8	447638		
10369390102	SGMS 103-Custodial Closet #4 (EPA 200.8	447638		
10369390103	SGMS 104-Girls Bathrm #6 (Wash	EPA 200.8	447638		
10369390104	SGMS 105-Boys Bathrm #6 (Washes	EPA 200.8	447638		
10369390105	SGMS 106-Water Fountain #11	EPA 200.8	447638		
10369390106	SGMS 107-Faculty Rm 218 Mens B	EPA 200.8	447638		
10369390107	SGMS 108-Faculty Rm 218 Womens	EPA 200.8	447459		
10369390108	SGMS 109-Rm 218 Custodial Clos	EPA 200.8	447459		
10369390109	SGMS 110-Rm. 236 (sink)	EPA 200.8	447459		
10369390110	SGMS 111-Exterior Faucet #1	EPA 200.8	447459		
10369390112	SGMS 113-Exterior Faucet #3	EPA 200.8	447459		
10369390031	SGMS 031-Boys Locker Rm. #2 Rm	EPA 200.8	448933	EPA 200.8	449209
10369390039	SGMS 039-Kitchen Rm 110 sink1	EPA 200.8	448933	EPA 200.8	449209
10369390111	SGMS 112-Exterior Faucet #2	EPA 200.8	448933	EPA 200.8	449209

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CHAIN-OF-CUSTODY / Analytical Request Document
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

①
10369390

Page: 1 of 10
2082936

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER

Site Location: NY
STATE: NY

Section C
Invoice Information:
Attention: _____
Company Name: _____
Address: _____
Pace Quote Reference: _____
Pace Project Manager: _____
Pace Profile #: _____

Section B
Required Client Information:
Report To: _____
Copy To: _____
Purchase Order No.: _____
Project Name: SCOTIA OTSEVILLE MIDDLE SCHOOL
Project Number: 0821

Section A
Required Client Information:
Company: PACE ANALYTICAL
Address: _____
Email To: _____
Phone: _____ Fax: _____
Requested Due Date/TAT: _____

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE Drinking Water DW Waste Water WW Product P Soil/Solid SL Oil OL Wipe WIP Air AR TS Other OT	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives						Requested Analysis Filtered (Y/N)	Pace Project No./ Lab I.D.	
			COMPOSITE START	COMPOSITE END/GRAB			DATE	TIME	Unpreserved	H ₂ SO ₄	HNO ₃	HCl			NaOH
1	SAMS 001 - OFFICE BATH RM #1 (SWW)			10/14	0603										001
2	SAMS 002 - BATH RM #1 (SWW)			10/14	0607										002
3	SAMS 003 - WATER FOUNTAIN #1			10/14	0606										003
4	SAMS 004 - MURKES OFFICE (SWW)			10/14	0610										004
5	SAMS 005 - MURKES OFFICE BATH RM (SWW)			10/14	0610										005
6	SAMS 006 - MAIN OFFICE BATH RM (SWW)			10/14	0612										006
7	SAMS 007 - CUSTODIAL closet #1 on 1st (SWW)			10/14	0614										007
8	SAMS 008 - ART RM 107 (SWW)			10/14	0615										008
9	SAMS 009 - ART RM 107 (SWW)			10/14	0617										009
10	SAMS 010 - ART RM 107 (SWW)			10/14	0618										010
11	SAMS 011 - RM 111 "BATH RM" (SWW)			10/14	0619										011
12	SAMS 012 - BOILER RM. (SWW)			10/14	0621										012

ADDITIONAL COMMENTS
 RELINQUISHED BY / AFFILIATION: ON PACE DATE: 10/16/16 TIME: 13:25
 ACCEPTED BY / AFFILIATION: ON PACE DATE: 10/16/16 TIME: 13:25
 SAMPLE CONDITIONS: Received on Ice (Y/N): N Sealed Custody (Y/N): N Samples Intact (Y/N): Y

DATE: 11/9/16 TIME: 16:00
 SIGNATURE: Scott P. Pace
 DATE SIGNED: 10/14/16
 SIGNATURE OF SAMPLER: William Bandwell (CB)

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: WILLIAM BANDWELL (CB)
 SIGNATURE OF SAMPLER: _____

CHAIN-OF-CUSTODY / Analytical Request Document
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Section A
Required Client Information:
Company: FACE ANALYTICAL
Address: _____
Email To: _____
Phone: _____
Requested Due Date/TAT: _____

Section B
Required Project Information:
Report To: _____
Copy To: _____
Purchase Order No.: _____
Project Name: KOTA GREENVILLE MIDDLE SCHOOL
Project Number: 0021

Section C
Invoice Information:
Attention: _____
Company Name: _____
Address: _____
Pace Quote Reference: _____
Pace Project Manager: _____
Pace Profile #: _____

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____

Site Location: _____
STATE: IN

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Analysis Test ↑	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No. / Lab I.D.
				COMPOSITE START	COMPOSITE END/GRAB							
1	SAMS 013 - Drinking Water (SW) #1	DW	D	10/10	0022							013
2	SAMS 014 - Drinking Water (SW) #1	DW	D	10/10	0025							014
3	SAMS 015 - Drinking Water (SW) #2	DW	D	10/10	0026							015
4	SAMS 016 - Drinking Water (SW) #3	DW	D	10/10	0027							016
5	SAMS 017 - Drinking Water (SW) #4	DW	D	10/10	0027							017
6	SAMS 018 - Drinking Water (SW) #1	DW	D	10/10	0030							018
7	SAMS 019 - Drinking Water (SW) #2	DW	D	10/10	0031							019
8	SAMS 020 - Drinking Water (SW) #3	DW	D	10/10	0033							020
9	SAMS 021 - Drinking Water (SW) #4	DW	D	10/10	0034							021
10	SAMS 022 - Drinking Water (SW) #2	DW	D	10/10	0035							022
11	SAMS 023 - Drinking Water (SW) #3	DW	D	10/10	0035							023
12	SAMS 024 - Drinking Water (SW) #1	DW	D	10/10	0045							024

ADDITIONAL COMMENTS
 RELINQUISHED BY / AFFILIATION: ON PACE DATE: 11/6/16 TIME: 15:00
 ACCEPTED BY / AFFILIATION: ON PACE DATE: 10/10/16 TIME: 13:25
 SAMPLE CONDITIONS: N N Y
13:25
15:00
14:30
14:3

Received on: _____
 Temp in °C: _____
 Iced (Y/N): _____
 Custody Sealed Cooler (Y/N): _____
 Samples Intact (Y/N): _____

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: WILLIAM BARRELL
 SIGNATURE OF SAMPLER: _____
 DATE Signed (MM/DD/YYYY): 10/10/16

ORIGINAL

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.
 F-ALL-Q-020rev.07, 15-May-2007

CHAIN-OF-CUSTODY / Analytical Request Document
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

103 69390

Section A Required Client Information:
Company: PACE Analytical
Address: _____
Report To: _____
Copy To: _____
Purchase Order No.: _____
Project Name: SCOTTS CREEKVILLE MIDDLE SCHOOL
Project Number: 0821
Requested Due Date/TAT: _____

Section B Required Project Information:
Report To: _____
Copy To: _____
Purchase Order No.: _____
Project Name: SCOTTS CREEKVILLE MIDDLE SCHOOL
Project Number: 0821
Requested Due Date/TAT: _____

Section C Invoice Information:
Attention: _____
Company Name: _____
Address: _____
Pace Quote Reference: _____
Pace Project Manager: _____
Pace Profile #: _____

Pages: 3 of 10
2082994

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____

Site Location STATE: MS

ITEM #	Section D Required Client Information	Section E Matrix Codes MATRIX / CODE	Section F Matrix Code (see valid codes to left)	Section G SAMPLE TYPE (G=GRAB C=COMP)	Section H COLLECTED		Section I SAMPLE TEMP AT COLLECTION	Section J # OF CONTAINERS	Section K Preservatives	Section L Analysis Test	Section M Requested Analysis Filtered (Y/N)	Section N Pace Project No./ Lab I.D.
					COMPOSITE START	COMPOSITE ENDGRAB						
		DW Drinking Water WT Water WW Waste Water P Product SL Soil/Solid OL Oil WP Wipe AR Air TS Tissue Other	DATE	TIME	DATE	TIME		Unpreserved H ₂ SO ₄ HNO ₃ HCl NaOH Na ₂ S ₂ O ₃ Methanol Other	↓	Y/N		
1	SCMS 025 Boys Locker Rm #1 (SWR) #2	DW	10/10	08:46	10/10	08:46				↑		025
2	SCMS 026 Boys Locker Rm #1 (SWR) #1	DW	10/10	08:48	10/10	08:48				↑		026
3	SCMS 027 Boys Locker Rm #1 (SWR) #2	DW	10/10	08:49	10/10	08:49				↑		027
4	SCMS 028 - WATER FOUNTAIN #4	DW	10/10	08:50	10/10	08:50				↑		028
5	SCMS 029 Boys Locker Rm #2 (SWR)	DW	10/10	08:54	10/10	08:54				↑		029
6	SCMS 030 Boys Locker Rm #2 (SWR)	DW	10/10	08:55	10/10	08:55				↑		030
7	SCMS 031 Boys Locker Rm #2 (SWR)	DW	10/10	08:56	10/10	08:56				↑		031
8	SCMS 032 Boys Locker Rm #2 (SWR)	DW	10/10	08:56	10/10	08:56				↑		032
9	SCMS 033 Boys Locker Rm #2 (SWR)	DW	10/10	08:56	10/10	08:56				↑		033
10	SCMS 034 Boys Locker Rm #2 (SWR)	DW	10/10	08:56	10/10	08:56				↑		034
11	SCMS 025 Classroom Closet #2 (SWR)	DW	10/10	07:15	10/10	07:15				↑		035
12	SCMS 036 Boys Locker Rm #2 (SWR)	DW	10/10	07:21	10/10	07:21				↑		036

Section O ADDITIONAL COMMENTS
 RELINQUISHED BY / AFFILIATION: PAACE DATE: 10/10/16 TIME: 15:25
 ACCEPTED BY / AFFILIATION: ON PACE DATE: 10/10/16 TIME: 16:00
 SAMPLE CONDITIONS: Sealed Cooler (Y/N) N, Custody (Y/N) N, Received on (Y/N) N, Temp in °C 14.3

Section P SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: WILLIAM BARNWELL
 SIGNATURE of SAMPLER: [Signature]
 DATE Signed (MM/DD/YYYY): 10/10/16

Section Q Residual Chlorine (Y/N): _____

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days. F-ALL-Q-020rev.07, 15-May-2007

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

1036 9390

Section A Required Client Information:	Section B Required Project Information:	Section C Invoice Information:
Company: PACE ANALYTICAL	Report To:	Attention:
Address:	Copy To:	Company Name:
Email To:	Purchase Order No.:	Address:
Phone:	Project Name: SCOTTA OCEANVILLE MIDDLE SCHOOL	Pace Quote Reference:
Requested Due Date/TAT:	Project Number: 0821	Pace Project Manager:
		Pace Profile #:
		REGULATORY AGENCY
		<input type="checkbox"/> NPDES <input checked="" type="checkbox"/> GROUND WATER <input checked="" type="checkbox"/> DRINKING WATER
		<input type="checkbox"/> UST <input type="checkbox"/> RCRA <input type="checkbox"/> OTHER
		Site Location STATE: NY

ITEM #	Section D Required Client Information	Matrix Codes MATRIX CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives										Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB				DATE	TIME	DATE	TIME	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₃	Methanol		
1	SEMS 057 BOYS BATH #2 (SWR)	DW	10/16	0725	D														037
2	SEMS 058 WATER FOUNTAIN #5	WT	10/10	0730	D														038
3	SEMS 059 KITCHEN CABINETS #1	WW	10/14	0732	D														039
4	SEMS 060 KITCHEN CABINETS #2	P	10/14	0732	D														040
5	SEMS 061 KITCHEN CABINETS #3	SL	10/16	0734	D														041
6	SEMS 062 KITCHEN CABINETS #4	OL	10/16	0735	D														042
7	SEMS 063 KITCHEN CABINETS #5	WP	10/16	0737	D														043
8	SEMS 064 HALLWAY #1	AR	10/16	0740	D														044
9	SEMS 065 HALLWAY #2	TS	10/16	0740	D														045
10	SEMS 066 HALLWAY #3	OT	10/16	0741	D														046
11	SEMS 067 HALLWAY #4		10/16	0742	D														047
12	SEMS 068 ART ROOM #1		10/16	0745	D														047

RELIQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
<i>[Signature]</i>	10/16/16	13:25	<i>[Signature]</i> Pace	10/16/16	15:25	N N Y
<i>[Signature]</i>	11/9/16	16:00	<i>[Signature]</i> Pace	11/14/16	08:00	N Y Y

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: **WILLIAM BARDWELL**

SIGNATURE of SAMPLER: *[Signature]*

DATE Signed (MM/DD/YY): **10/16/16**

Temp in °C: **15.0**

Received on Ice (Y/N): **N**

Custody Sealed Cooler (Y/N): **N**

Samples Intact (Y/N): **Y**

CHAIN-OF-CUSTODY / Analytical Request Document
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

5 of 10
10369390

Section A
Required Client Information:
Company: PACE ANALYTICAL
Address: _____
Email To: _____
Phone: _____ Fax: _____
Requested Due Date/TAT: _____

Section B
Required Project Information:
Report To: _____
Copy To: _____
Purchase Order No.: _____
Project Name: SCOTIA GREENVILLE MIDDLES ST-1000 C
Project Number: 0821

Section C
Invoice Information:
Attention: _____
Company Name: _____
Address: _____
Pace Quote Reference: _____
Pace Project Manager: _____
Pace Profile #: _____

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____

Site Location: _____ STATE: NC

ITEM #	Section D Required Client Information	Matrix Codes MATRIX I CODE	SAMPLE CODE (see valid codes to left)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
				COMPOSITE START	COMPOSITE END/GRAB						
1	San Jose - Nat. Park #1 (SWR) #2	DW	DJ0	10/16 0746	10/16 0746						048
2	San Jose - Nat. Park #1 (SWR) #3	DW	DJ0	10/16 0747	10/16 0747						049
3	San Jose - Nat. Park #1 (SWR) #4	DW	DJ0	10/16 0748	10/16 0748						050
4	San Jose - Nat. Park #1 (SWR) #1	DW	DJ0	10/16 0750	10/16 0750						051
5	San Jose - Nat. Park #1 (SWR) #2	DW	DJ0	10/16 0750	10/16 0750						052
6	San Jose - Nat. Park #1 (SWR) #3	DW	DJ0	10/16 0751	10/16 0751						053
7	San Jose - Nat. Park #1 (SWR) #4	DW	DJ0	10/16 0755	10/16 0755						054
8	San Jose - Nat. Park #1 (SWR) #1	DW	DJ0	10/16 0759	10/16 0759						055
9	San Jose - Nat. Park #1 (SWR) #2	DW	DJ0	10/16 0822	10/16 0822						056
10	San Jose - Nat. Park #1 (SWR) #3	DW	DJ0	10/16 0803	10/16 0803						057
11	San Jose - Nat. Park #1 (SWR) #3	DW	DJ0	10/16 0805	10/16 0805						058
12	San Jose - Nat. Park #1 (SWR) #1	DW	DJ0	10/16 0807	10/16 0807						059

ADDITIONAL COMMENTS
 PS: 10/16/16 13:25
 ON PACE
 11/9/16 16:00 Fed Ex
 Sample Data / PACE 11/14/16 0930
 14.3 N
 15.0

RELINQUISHED BY / AFFILIATION
 DATE: 10/16/16 13:25
 TIME: 13:25
 ACCEPTED BY / AFFILIATION
 DATE: 11/14/16 0930
 TIME: 0930

SAMPLE CONDITIONS
 Received on Ice (Y/N) N
 Custody Sealed (Y/N) N
 Samples Intact (Y/N) Y

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: William D. PACE
 SIGNATURE of SAMPLER: [Signature]
 DATE Signed (MM/DD/YYYY): 10/16/16

ORIGINAL

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: 6 of 10
2082997



Section A
Required Client Information:
 Company: PALE ANALYTICAL
 Address: _____
 Email To: _____
 Phone: _____ Fax: _____
 Requested Due Date/TAT: _____

Section B
Required Project Information:
 Report To: _____
 Copy To: _____
 Purchase Order No.: _____
 Project Name: SCOTIA OTISVILLE MIDDLE SCHOOL
 Project Number: 2008

Section C
Invoice Information:
 Attention: _____
 Company Name: _____
 Address: _____
 Pace Quote Reference: _____
 Pace Project Manager: _____
 Pace Profile #: _____

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____

Site Location STATE: MD

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	SAMPLE CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Requested Analysis Filtered (Y/N)	Pace Project No./ Lab I.D.	
					COMPOSITE START	COMPOSITE END/GRAB			DATE	TIME	DATE	TIME	H ₂ SO ₄	HNO ₃	HCl			NaOH
1	SAMPLE ID (A-Z, 0-9 / -) Sample IDs MUST BE UNIQUE	Drinking Water	DW	DW	060	060			X	X	X	X	X	X	X	X		060
2		Waste Water	WW	WW	061	061			X	X	X	X	X	X	X	X		061
3		Product	P	P	062	062			X	X	X	X	X	X	X	X		062
4		Soil/Solid	SL	SL	063	063			X	X	X	X	X	X	X	X		063
5		Oil	OL	OL	064	064			X	X	X	X	X	X	X	X		064
6		Wipe	WP	WP	065	065			X	X	X	X	X	X	X	X		065
7		Air	AR	AR	066	066			X	X	X	X	X	X	X	X		066
8		Tissue	TS	TS	067	067			X	X	X	X	X	X	X	X		067
9		Other	OT	OT	068	068			X	X	X	X	X	X	X	X		068
10					069	069			X	X	X	X	X	X	X	X		069
11					070	070			X	X	X	X	X	X	X	X		070
12					071	071			X	X	X	X	X	X	X	X		071

ADDITIONAL COMMENTS
 RELINQUISHED BY / AFFILIATION: ON PACE DATE: 10/19/16 TIME: 13:25
 ACCEPTED BY / AFFILIATION: ON PACE DATE: 10/19/16 TIME: 13:25
 DATE SIGNED (MM/DD/YYYY): 10/16/16
 PRINT NAME OF SAMPLER: WILLIAM BARRETT
 SIGNATURE OF SAMPLER: _____
 DATE SIGNED (MM/DD/YYYY): 10/16/16
 RECEIVED ON: 150 Temp in °C: 14.3
 Sealed Cooler (Y/N): N
 Custody (Y/N): N
 Samples Intact (Y/N): Y

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



10369390

Section A Required Client Information: Company: PAVE ANALYTICAL Address: _____
Section B Required Project Information: Report To: _____ Copy To: _____
Section C Invoice Information: Attention: _____ Company Name: _____
 Regulatory Agency: NPDES GROUND WATER DRINKING WATER RCRA OTHER _____
 Pace Quote Reference: _____ Pace Project Manager: _____ Site Location STATE: MS
 Project Name: SCOTTA STEVENSON MIDDLE SCHOOL Project Number: 0821
 Purchase Order No.: _____ Requested Due Date/TAT: _____
 Phone: _____ Fax: _____

ITEM #	Section D Required Client Information SAMPLE ID (A-Z, 0-9 / .)	Matrix Codes MATRIX / CODE Drinking Water DW Water WT Waste Water WW Product P Soil/Solid SL Oil OL Wipe WP Air AR Tissue TS Other OT	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives H ₂ SO ₄ HNO ₃ HCl NaOH Na ₂ O ₂ Methanol Other	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
					COMPOSITE START	COMPOSITE END/GRAB						
1	S0MS073-BOND BATH RM #4 (SWR)#2		DJ0		10/10	0823						072
2	S0MS074-WATER FOUNTAIN #8		DJ0		10/10	0825						073
3	S0MS075-WATER FOUNTAIN #9		DJ0		10/10	0824						074
4	S0MS076-BOND BATH RM #4 (SWR)#2		DJ0		10/10	0830						075
5	S0MS077-BOND BATH RM #4 (SWR)#3		DJ0		10/10	0831						076
6	S0MS078-BOND BATH RM #4 (SWR)#1		DJ0		10/10	0832						077
7	S0MS079-SUCULE RM 267 (SWR)#1		DJ0		10/10	0835						078
8	S0MS080-SUCULE RM 267 (SWR)#2		DJ0		10/10	0835						079
9	S0MS081-SUCULE RM 267 (SWR)#3		DJ0		10/10	0836						080
10	S0MS082-SUCULE RM 267 (SWR)#4		DJ0		10/10	0837						081
11	S0MS083-LINENARY OFFICE RM 292 (SWR)#1		DJ0		10/10	0839						082
12	S0MS084-BOND BATH RM #5 (SWR)#1		DJ0		10/10	0831						083
ADDITIONAL COMMENTS: <u>PAVE</u> <u>10/19/16 15:25</u> <u>PAVE EX</u> <u>11/9/16 16:00</u> <u>SCOTT STEVENSON PACE</u> <u>11/14/16 0930</u>												
RELINQUISHED BY / AFFILIATION: <u>PAVE</u> DATE: <u>10/19/16</u> TIME: <u>15:25</u>												
ACCEPTED BY / AFFILIATION: <u>PAVE EX</u> DATE: <u>11/9/16</u> TIME: <u>16:00</u>												
SAMPLE CONDITIONS: Received on Ice (Y/N): <u>N</u> Sealed Cooler (Y/N): <u>N</u> Custody (Y/N): <u>N</u> Samples Intact (Y/N): <u>Y</u>												
Temp in °C: <u>14.3</u> <u>15.0</u>												

ORIGINAL

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: WILLIAM BARRY SEC
 SIGNATURE of SAMPLER: [Signature]

DATE SIGNED
 (MM/DD/YYYY): 10/19/16

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

CHAIN-OF-CUSTODY / Analytical Request Document
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: 8 of 10
10369390

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: <u>PACE ANALYTICAL</u>	Report To:	Company Name:	Attention:	Company Name:	Invoice Information:
Address:	Copy To:	Address:		Address:	
Email To:	Purchase Order No.:	Pace Quote Reference:		Pace Project Manager:	
Phone:	Project Name: <u>SCOTIA ORCHARDVILLE MIDDLE SCHOOL</u>	Pace Profile #:			
Requested Due Date/TAT:	Project Number: <u>0821</u>				

ITEM #	Section D Required Client Information	Matrix Codes MATRIX I CODE	SAMPLE CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
					COMPOSITE START	COMPOSITE END/GRAB						
		DW Drinking Water WT Waste Water WW Waste Water Product P Soil/Solid SL Oil OL Wipe WP Air AR Tissue TS Other OT	DATE	TIME	DATE	TIME			H ₂ SO ₄ HCl NaOH Na ₂ S ₂ O ₃ Methanol Other			
1	SOM5085 - Bath #5 (SWE)		DW	D	10/16	0842			X	X		084
2	SOM5086 - Bath #10		DW	D	10/16	0842			X	X		085
3	SOM5087 - Shower #1		DW	D	10/16	0845			X	X		086
4	SOM5088 - Shower #2		DW	D	10/16	0846			X	X		087
5	SOM5089 - Shower #3		DW	D	10/16	0847			X	X		088
6	SOM5090 - Shower #4		DW	D	10/16	0848			X	X		089
7	SOM5091 - Shower #5		DW	D	10/16	0850			X	X		090
8	SOM5092 - Shower #1		DW	D	10/16	0851			X	X		091
9	SOM5093 - Shower #2		DW	D	10/16	0857			X	X		092
10	SOM5094 - Shower #3		DW	D	10/16	0857			X	X		093
11	SOM5095 - Shower #1		DW	D	10/16	0857			X	X		094
12	SOM5096 - Shower #2		DW	D	10/16	0856			X	X		095

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS	Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)
<u>Field</u>	<u>On PACE</u>	<u>10/16/16</u>	<u>13:25</u>	<u>On PACE</u>	<u>10/16</u>	<u>13:25</u>	<u>N</u>	<u>N</u>	<u>Y</u>	<u>Y</u>
<u>On PACE</u>	<u>On PACE</u>	<u>11/2/16</u>	<u>16:00</u>	<u>Feed Est</u>	<u>11/4/16</u>	<u>0930</u>	<u>N</u>	<u>Y</u>	<u>Y</u>	<u>Y</u>
				<u>Sanah P. PACE</u>	<u>11/4/16</u>	<u>0930</u>	<u>15.0</u>	<u>N</u>	<u>Y</u>	<u>Y</u>
							<u>14.3</u>			

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: William Barwick

SIGNATURE of SAMPLER: [Signature]

DATE SIGNED (MM/DD/YYYY): 10/16/16

ORIGINAL

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days. F-ALL-C-020rev.07, 15-May-2007

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



1036930

Section A
 Required Client Information:
 Company: **PALE ANALYTICAL**
 Address:
 Email To:
 Phone:
 Requested Due Date/TAT:

Section B
 Required Project Information:
 Report To:
 Copy To:
 Purchase Order No.:
 Project Name: **SOUTH GREENVILLE MIDDLE SCHOOL**
 Project Number: **0321**

Section C
 Invoice Information:
 Attention:
 Company Name:
 Address:
 PACE Quote Reference:
 PACE Project Manager:
 PACE Profile #:

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA

Site Location
 STATE: **MS**

Page: **9** of **10**
2083000

ITEM #	Section D Required Client Information	Matrix Codes MATRIX CODE	SAMPLE CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Requested Analysis Filtered (Y/N)	Temp in °C	Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)	
					COMPOSITE START	COMPOSITE END/GRAB									
1	SOPMS 097 - SQUIBBE Ln. 207 (SWE) #3	DW	DW 10/16/08 0856	D		10/16/08 0856									
2	SOPMS 098 - SQUIBBE Ln. 207 (SWE) #4	WT	WT 10/16/08 0857	D		10/16/08 0857									
3	SOPMS 099 - SQUIBBE Ln. 207 (SWE) #5	WW	WW 10/16/08 0857	D		10/16/08 0857									
4	SOPMS 100 - SQUIBBE Ln. 207 (SWE) #6	P	P 10/16/08 0858	D		10/16/08 0858									
5	SOPMS 101 - SQUIBBE Ln. 207 (SWE) #1	SL	SL 10/16/08 0859	D		10/16/08 0859									
6	SOPMS 102 - SQUIBBE Ln. 207 (SWE) #2	OL	OL 10/16/08 0860	D		10/16/08 0860									
7	SOPMS 103 - CANTONNE CROSETT #7 (SWE)	WP	WP 10/16/08 0861	D		10/16/08 0861									
8	SOPMS 104 - GARDY BATTY Ln. 26 (SWE)	AR	AR 10/16/08 0863	D		10/16/08 0863									
9	SOPMS 105 - BOWS BATTY Ln. 26 (SWE)	TS	TS 10/16/08 0864	D		10/16/08 0864									
10	SOPMS 106 - WARDEN FOUNTAIN #11	OT	OT 10/16/08 0865	D		10/16/08 0865									
11	SOPMS 107 - BAYERS Ln. 218 "HARDWARE" (SWE)			D											
12	SOPMS 108 - BAYERS Ln. 218 "HARDWARE" (SWE)			D											

ADDITIONAL COMMENTS: **RELINQUISHED BY / AFFILIATION: PACE DATE: 10/16/08 TIME: 13:25**
ACCEPTED BY / AFFILIATION: PACE DATE: 10/16/08 TIME: 13:25
DATE SIGNED (MM/DD/YYYY): 10/16/08
SIGNATURE OF SAMPLER: William B. PACE
PRINT NAME OF SAMPLER: WILLIAM B. PACE
SIGNATURE OF SAMPLER: [Signature]

RELINQUISHED BY / AFFILIATION: **PACE** DATE: **11/9/16** TIME: **16:00**
 ACCEPTED BY / AFFILIATION: **PACE Ex** DATE: **11/4/10** TIME: **09:30**
 DATE SIGNED (MM/DD/YYYY): **11/4/10**
 SIGNATURE OF SAMPLER: **Sarah Pate PACE**
 PRINT NAME OF SAMPLER: **Sarah Pate PACE**
 SIGNATURE OF SAMPLER: **[Signature]**

Temp in °C: **143**
 Received on Ice (Y/N): **N**
 Custody Sealed Cooler (Y/N): **N**
 Samples Intact (Y/N): **Y**

ORIGINAL

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

CHAIN-OF-CUSTODY / Analytical Request Document
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10
10369390

Section A Required Client Information: Company: PVE ANALYTICAL Address: _____
Section B Required Project Information: Report To: _____ Copy To: _____
 Project Name: SCOTTS ORLENVILLE MIDDLE SCHOOL Project Number: 0824
 Purchase Order No.: _____
 Email To: _____ Phone: _____ Fax: _____
 Requested Due Date/TAT: _____
Section C Invoice Information: Attention: _____ Company Name: _____
 Address: _____
 Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____
 Regulatory Agency: _____
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____
 Site Location STATE: NY

ITEM #	Matrix Codes MATRIX / CODE Drinking Water DW Waste Water WW Product P Soil/Solid SL Oil OL Wipe WP Air AR Tissue TS Other OT	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives Unpreserved H ₂ SO ₄ HNO ₃ HCl NaOH Na ₂ S ₂ O ₃ Methanol Other	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB						
1	SOM 109 - PM 1218 CUSTOMER CLASSIFIED	D	10/10	0913						108
2	SOM 110 - PM 2316 CUMC	D	10/10	0915						109
3	SOM 111 - EXTREME FACET #1	D	10/10	0925						110
4	SOM 112 - EXTREME FACET #2	D	10/10	0925						111
5	SOM 113 - EXTREME FACET #3	D	10/10	0925						112
6	SOM 114 - LY	D	10/14							
7										
8										
9										
10										
11										
12										

ADDITIONAL COMMENTS RELINQUISHED BY / AFFILIATION DATE TIME ACCEPTED BY / AFFILIATION DATE TIME SAMPLE CONDITIONS

PSI - SCOTT'S ORLENVILLE MIDDLE SCHOOL 10/18/16 13:25 ON PACE 10/18/16 13:25 N N Y
 ON PACE 11/9/16 16:00 Fed Ex Sarah Pates / PACE 11/10/16 09:30 150 N Y Y
 113

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: WILLIAM BARRINER DATE Signed (MM/DD/YYYY): 10/16/16
 SIGNATURE of SAMPLER: _____

Temp in °C Received on Ice (Y/N) Sealed Cooler (Y/N) Samples Intact (Y/N)


ORIGINAL

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days. F-ALL-Q-020rev.07, 15-May-2007

Sample Condition Upon Receipt

Client Name: NY Public Schools Project #: _____

WO# : 10369390



10369390

Courier: Fed Ex UPS USPS Client
 Commercial Pace SpeedDee Other: _____
 Tracking Number: 7062 98756131/6140

Custody Seal on Cooler/Box Present? Yes No Seals Intact? Yes No **Optional:** Proj. Due Date: _____ Proj. Name: _____

Packing Material: Bubble Wrap Bubble Bags None Other: _____ Temp Blank? Yes No

Thermometer Used: 151401163 151401164 B88A912167504 B88A0143310098
 Type of Ice: Wet Blue None Samples on ice, cooling process has begun

Cooler Temp Read (°C): 14.1/14.8 Cooler Temp Corrected (°C): 14.3/150 Biological Tissue Frozen? Yes No N/A
 Temp should be above freezing to 6°C Correction Factor: 10.2 Date and Initials of Person Examining Contents: SMP 11/10/16

USDA Regulated Soil (N/A, water sample)
 Did samples originate in a quarantine zone within the United States: AL, AR, AZ, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)? Yes No
 Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No
If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.

	COMMENTS:
Chain of Custody Present? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	1.
Chain of Custody Filled Out? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	2.
Chain of Custody Relinquished? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	3.
Sampler Name and/or Signature on COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	5.
Short Hold Time Analysis (<72 hr)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	6.
Rush Turn Around Time Requested? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	7.
Sufficient Volume? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	8.
Correct Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	9.
-Pace Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	10.
Filtered Volume Received for Dissolved Tests? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container
Sample Labels Match COC? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A -Includes Date/Time/ID/Analysis Matrix: <u>WT</u>	12. <u>IDs vary Sample label does not have time or Analysis</u>
All containers needing acid/base preservation have been checked? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl<2; NaOH >9 Sulfide, NaOH >12 Cyanide) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Exceptions: VOA, Coliform, TOC, Oil and Grease, DRO/8015 (water) DOC <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	13. <input checked="" type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl Sample # <u>1/1</u> <u>1-112</u> Initial when completed: _____ Lot # of added preservative: _____
Headspace in VOA Vials (>6mm)? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
Trip Blank Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Custody Seals Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if purchased): _____	

CLIENT NOTIFICATION/RESOLUTION

Person Contacted: _____ Date/Time: _____ Field Data Required? Yes No
 Comments/Resolution: _____

Project Manager Review: Luana J. Albert Date: 11/11/16

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e. out of hold, incorrect preservative, out of temp, incorrect containers).