

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
SG5E 001 Rm.138 Sink	9/25/2016 06:51	10/21/2016 17:58	10366467001	Lead	1.2	15	ug/L
SG5E 002 RM.138 Sink Fountain	9/25/2016 00:00	10/21/2016 18:03	10366467002	Lead	0.53	15	ug/L
SG5E 003 RM.138 BathRM Sink	9/25/2016 00:00	10/21/2016 18:04	10366467003	Lead	2.1	15	ug/L
SG5E 004 RM.136 Sink	9/25/2016 00:00	10/21/2016 18:05	10366467004	Lead	1.5	15	ug/L
SG5E 005 RM.136 Sink Fountain	9/25/2016 00:00	10/21/2016 18:06	10366467005	Lead	0.85	15	ug/L
SG5E 006 RM.136 BathRM Sink	9/25/2016 00:00	10/21/2016 18:08	10366467006	Lead	3.4	15	ug/L
SG5E 007 RM.147 Sink	9/25/2016 00:00	10/21/2016 18:09	10366467007	Lead	2.2	15	ug/L
SG5E 008 RM.147 Sink Fountain	9/25/2016 00:00	10/21/2016 18:12	10366467008	Lead	0.91	15	ug/L
SG5E 009 RM.147 BathRM Sink	9/25/2016 00:00	10/21/2016 18:14	10366467009	Lead	0.93	15	ug/L
SG5E 010-RM.145 Sink	9/25/2016 00:00	10/21/2016 18:15	10366467010	Lead	1.3	15	ug/L
SG5E 011-RM.145 Sink Fountain	9/25/2016 00:00	10/21/2016 18:16	10366467011	Lead	0.8	15	ug/L
SG5E 012-RM.145 BathRM Sink	9/25/2016 00:00	10/21/2016 18:18	10366467012	Lead	3.5	15	ug/L
SG5E 013-ConfeanceRM #1 Sink	9/25/2016 00:00	10/21/2016 18:20	10366467013	Lead	28.6	15	ug/L
SG5E 014- RM.141 Sink	9/25/2016 00:00	10/21/2016 18:21	10366467014	Lead	5.3	15	ug/L
SG5E 015- RM.141 BathRM Sink	9/25/2016 00:00	10/21/2016 18:22	10366467015	Lead	6.4	15	ug/L
SG5E 016- Hallway WF #1	9/25/2016 00:00	10/21/2016 18:23	10366467016	Lead	1.4	15	ug/L
SG5E 017-RM 139 Sink	9/25/2016 00:00	10/21/2016 18:29	10366467017	Lead	4.2	15	ug/L
SG5E 018-RM 139 BathRM Sink	9/25/2016 00:00	10/21/2016 18:30	10366467018	Lead	13.4	15	ug/L
SG5E 019-Nurses Office Sink	9/25/2016 00:00	10/21/2016 18:31	10366467019	Lead	1.8	15	ug/L
SG5E 020-Nurses BathRm	9/25/2016 00:00	10/21/2016 18:33	10366467020	Lead	1.6	15	ug/L
SG5E 021- Main Office BathRM	9/25/2016 00:00	10/24/2016 11:45	10366467021	Lead	6.7	15	ug/L
SG5E 022- Hallway WF #2	9/25/2016 00:00	10/24/2016 11:49	10366467022	Lead	1.5	15	ug/L
SG5E 023- RM.130 BathRM Sink	9/25/2016 00:00	10/24/2016 11:50	10366467023	Lead	16.5	15	ug/L
SG5E 024- RM.129 Sink	9/25/2016 00:00	10/24/2016 11:51	10366467024	Lead	71.8	15	ug/L
SG5E 025-Custodian Closet #1	9/25/2016 00:00	10/24/2016 11:52	10366467025	Lead	4.0	15	ug/L
SG5E 026-Cafeteria Stage Sink	9/25/2016 00:00	10/24/2016 11:56	10366467026	Lead	129	15	ug/L
SG5E 027-Cafeteria Water Sink	9/25/2016 00:00	10/24/2016 11:57	10366467027	Lead	1.5	15	ug/L
SG5E 028-Kitchen Sink #1	9/25/2016 00:00	10/24/2016 11:58	10366467028	Lead	38.1	15	ug/L
SG5E 029-Kitchen Sink #2	9/25/2016 00:00	10/24/2016 11:59	10366467029	Lead	54.0	15	ug/L
SG5E 030-Kitchen Sink #3	9/25/2016 00:00	10/24/2016 12:01	10366467030	Lead	14.2	15	ug/L
SG5E 031- Kitchen(Hose) Sink#4	9/25/2016 00:00	10/24/2016 12:02	10366467031	Lead	33.8	15	ug/L
SG5E 032- Kit.(Dusthose)Sink#5	9/25/2016 00:00	10/24/2016 12:04	10366467032	Lead	3.2	15	ug/L
SG5E 033-Mens BathRM #1	9/25/2016 00:00	10/24/2016 12:05	10366467033	Lead	2.4	15	ug/L
SG5E 034- Women BathRm #1	9/25/2016 00:00	10/24/2016 12:06	10366467034	Lead	2.5	15	ug/L
SG5E 035-Library Office RM.127	9/25/2016 00:00	10/24/2016 12:10	10366467035	Lead	1.5	15	ug/L
SG5E 036-Art RM.106 Sink	9/25/2016 00:00	10/24/2016 12:11	10366467036	Lead	1.2	15	ug/L
SG5E 037-Faculty Lounge Sink	9/25/2016 00:00	10/24/2016 12:12	10366467037	Lead	2.9	15	ug/L
SG5E 038-Faculty BathRM Sink	9/25/2016 00:00	10/24/2016 12:13	10366467038	Lead	3.0	15	ug/L
SG5E 039-Faculty BathRM Sink	9/25/2016 00:00	10/24/2016 12:14	10366467039	Lead	10.5	15	ug/L
SG5E 040-Costodial Closet #2	9/25/2016 00:00	10/24/2016 12:15	10366467040	Lead	1.1	15	ug/L
SG5E 041-Hallway WF #4	9/25/2016 00:00	10/25/2016 14:51	10366467041	Lead	0.98	15	ug/L
SG5E 042-Hallway WF #5	9/25/2016 00:00	10/25/2016 14:55	10366467042	Lead	2.7	15	ug/L
SG5E 043-Ladies Bathroom #2	9/25/2016 00:00	10/25/2016 14:56	10366467043	Lead	6.7	15	ug/L
SG5E 044-Girls BathRM1 #1	9/25/2016 00:00	10/25/2016 14:57	10366467044	Lead	5.9	15	ug/L
SG5E 045-Girls BathRM1 #2	9/25/2016 00:00	10/25/2016 14:58	10366467045	Lead	11.0	15	ug/L
SG5E 046-Girls BathRM1 #3	9/25/2016 00:00	10/25/2016 15:02	10366467046	Lead	6.7	15	ug/L
SG5E 047-Girls BathRM1 #4	9/25/2016 00:00	10/25/2016 15:03	10366467047	Lead	5.4	15	ug/L
SG5E 048-Mens BathRM#3 Sink	9/25/2016 00:00	10/25/2016 15:04	10366467048	Lead	5.1	15	ug/L
SG5E 049-Boys BathRM1 #1 Sink	9/25/2016 00:00	10/25/2016 15:05	10366467049	Lead	7.3	15	ug/L
SG5E 050-Boys BathRM1 #2 Sink	9/25/2016 00:00	10/25/2016 15:06	10366467050	Lead	9.3	15	ug/L

SG5E 051-Boys BathRM1 #3 Sink	9/25/2016 00:00	10/25/2016 15:07	10366467051	Lead	13.2	15	ug/L
SG5E 052-Boys BathRM 1 #4 Sink	9/25/2016 00:00	10/25/2016 15:10	10366467052	Lead	11.7	15	ug/L
SG5E 053-Basement ArtRM.114	9/25/2016 00:00	10/25/2016 15:11	10366467053	Lead	11.3	15	ug/L
SG5E 054-Boys BathRM #2	9/25/2016 00:00	10/25/2016 15:12	10366467054	Lead	3.3	15	ug/L
SG5E 055-Boys BathRM #3	9/25/2016 00:00	10/25/2016 15:15	10366467055	Lead	8.3	15	ug/L
SG5E 056-RM.201 Closet Sink	9/25/2016 00:00	10/25/2016 15:17	10366467056	Lead	5.4	15	ug/L
SG5E 057-Hallway Water Foun.#7	9/25/2016 00:00	10/25/2016 15:18	10366467057	Lead	0.78	15	ug/L
SG5E 058-Women BathRM #4	9/25/2016 00:00	10/25/2016 15:19	10366467058	Lead	14.2	15	ug/L
SG5E 059-Girls BathRM #2 #1	9/25/2016 00:00	10/25/2016 15:20	10366467059	Lead	3.8	15	ug/L
SG5E 060-Girls BathRM #2 #2	9/25/2016 00:00	10/25/2016 15:21	10366467060	Lead	11.6	15	ug/L
SG5E 061-Girls BathRM #2 #3	9/25/2016 00:00	10/21/2016 18:34	10366467061	Lead	5.5	15	ug/L
SG5E 062-Girls BathRM #2 #4	9/25/2016 00:00	10/21/2016 18:41	10366467062	Lead	8.6	15	ug/L
SG5E 063-Costodial Closet #3	9/25/2016 00:00	10/21/2016 18:42	10366467063	Lead	63.5	15	ug/L
SG5E 064- Boys BathRM #2 #1	9/25/2016 00:00	10/21/2016 18:43	10366467064	Lead	5.0	15	ug/L
SG5E 065- Boys BathRM #2 #2	9/25/2016 00:00	10/21/2016 18:44	10366467065	Lead	8.3	15	ug/L
SG5E 066- Boys BathRM #2 #3	9/25/2016 00:00	10/21/2016 18:46	10366467066	Lead	10.3	15	ug/L
SG5E 067- Boys BathRM #2 #4	9/25/2016 00:00	10/21/2016 18:47	10366467067	Lead	10.5	15	ug/L
SG5E 068-Hallway Water Foun.#6	9/25/2016 00:00	10/21/2016 18:48	10366467068	Lead	7.0	15	ug/L
SG5E 069-Reading RM.208 Office	9/25/2016 00:00	10/21/2016 18:49	10366467069	Lead	16.7	15	ug/L
SG5E 070- Cust. Closet #3Sink2	9/25/2016 00:00	10/21/2016 18:50	10366467070	Lead	6.4	15	ug/L
SG5E 071- RM 207 BathRM Sink#1	9/25/2016 00:00	10/25/2016 01:18	10366467071	Lead	335	15	ug/L
SG5E 072- RM 207 BathRM Sink#2	9/25/2016 00:00	10/21/2016 18:51	10366467072	Lead	18.3	15	ug/L
SG5E 073-Exterior Faucet #1	9/25/2016 00:00	10/25/2016 01:21	10366467073	Lead	412	15	ug/L
SG5E 074-Exterior Faucet #2	9/25/2016 00:00	10/21/2016 18:58	10366467074	Lead	46.4	15	ug/L
SG5E 075-Exterior Faucet #3	9/25/2016 00:00	10/21/2016 18:59	10366467075	Lead	24.9	15	ug/L
SG5E 076-Field House Sink	9/25/2016 00:00	10/21/2016 19:01	10366467076	Lead	4.7	15	ug/L
SG5E 077-Field House WF	9/25/2016 00:00	10/21/2016 19:02	10366467077	Lead	6.0	15	ug/L

NYSDOH Action Level for Lead of 15 ppb