

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
Librarians office sink	9/25/2016 06:09	10/24/2016 22:05	10366694001	Lead	7.1	15	ug/L
Library bathroom sink	9/25/2016 06:10	10/24/2016 22:17	10366694002	Lead	7.0	15	ug/L
Rm. 92 sink	9/25/2016 06:13	10/24/2016 22:20	10366694003	Lead	29.8	15	ug/L
Rm. 92 bathroom sink	9/25/2016 06:13	10/24/2016 22:23	10366694004	Lead	11.6	15	ug/L
Rm. 94 sink	9/25/2016 06:17	10/24/2016 22:26	10366694005	Lead	13.7	15	ug/L
Rm. 94 Bathroom sink	9/25/2016 06:17	10/24/2016 22:34	10366694006	Lead	17.1	15	ug/L
Rm. 93 sink	9/25/2016 06:22	10/24/2016 22:37	10366694007	Lead	9.3	15	ug/L
Rm. 93 bathroom sink	9/25/2016 06:22	10/24/2016 22:40	10366694008	Lead	30.3	15	ug/L
Rm. 94 fountain	9/25/2016 06:22	10/24/2016 22:43	10366694009	Lead	10.2	15	ug/L
Rm. 95 sink	9/25/2016 06:25	10/24/2016 22:46	10366694010	Lead	6.9	15	ug/L
Rm. 95 bathroom sink	9/25/2016 06:25	10/24/2016 22:49	10366694011	Lead	8.9	15	ug/L
Rm. 96 sink	9/25/2016 06:29	10/24/2016 22:52	10366694012	Lead	1.6	15	ug/L
Rm. 96 bathroom sink	9/25/2016 06:29	10/24/2016 22:55	10366694013	Lead	3.4	15	ug/L
Rm. 96 fountain	9/25/2016 06:29	10/24/2016 22:58	10366694014	Lead	1.0	15	ug/L
Rm. 97 bathroom sink	9/25/2016 06:33	10/24/2016 23:01	10366694015	Lead	9.2	15	ug/L
Rm. 97 fountain	9/25/2016 06:34	10/24/2016 23:10	10366694016	Lead	1.6	15	ug/L
Rm. 97 sink	9/25/2016 06:34	10/24/2016 23:13	10366694017	Lead	1.4	15	ug/L
Rm. 98 bathroom sink	9/25/2016 06:34	10/24/2016 23:16	10366694018	Lead	10.5	15	ug/L
Rm. 98 fountain	9/25/2016 06:39	10/24/2016 23:18	10366694019	Lead	1.1	15	ug/L
Rm. 98 sink	9/25/2016 06:40	10/24/2016 23:21	10366694020	Lead	1.5	15	ug/L
Rm. 99 sink	9/25/2016 06:48	10/25/2016 03:23	10366694021	Lead	1.8	15	ug/L
Rm. 99 bathroom sink	9/25/2016 06:48	10/25/2016 03:35	10366694022	Lead	5.2	15	ug/L
Rm. 99 fountain	9/25/2016 06:49	10/25/2016 03:38	10366694023	Lead	0.81	15	ug/L
Rm. 100 bathroom sink	9/25/2016 06:55	10/25/2016 03:41	10366694024	Lead	12.8	15	ug/L
Rm. 100 sink	9/25/2016 06:56	10/25/2016 03:44	10366694025	Lead	11.8	15	ug/L
Rm. 101 sink	9/25/2016 06:59	10/25/2016 03:47	10366694026	Lead	7.4	15	ug/L
Rm. 101 bathroom sink	9/25/2016 06:59	10/25/2016 03:56	10366694027	Lead	8.3	15	ug/L
Rm. 102 sink	9/25/2016 07:04	10/25/2016 03:59	10366694028	Lead	12.7	15	ug/L
Rm. 102 bathroom sink	9/25/2016 07:05	10/25/2016 04:02	10366694029	Lead	11.4	15	ug/L
Rm. 103 bathroom sink	9/25/2016 07:10	10/25/2016 04:05	10366694030	Lead	8.8	15	ug/L
Rm. 103 sink	9/25/2016 07:10	10/25/2016 04:08	10366694031	Lead	16.6	15	ug/L
Rm. 104 sink	9/25/2016 07:14	10/25/2016 04:11	10366694032	Lead	7.0	15	ug/L
Rm. 104 bathroom sink	9/25/2016 07:15	10/25/2016 04:14	10366694033	Lead	8.3	15	ug/L
Water fountain across library	9/25/2016 07:17	10/25/2016 04:17	10366694034	Lead	1.8	15	ug/L
Rm. 105 sink	9/25/2016 07:20	10/25/2016 04:20	10366694035	Lead	5.8	15	ug/L
Rm. 105 bathroom sink	9/25/2016 07:21	10/25/2016 04:23	10366694036	Lead	7.0	15	ug/L
Rm. 106 sink	9/25/2016 07:25	10/25/2016 04:32	10366694037	Lead	12.4	15	ug/L
Rm. 106 bathroom sink	9/25/2016 07:25	10/25/2016 04:35	10366694038	Lead	11.9	15	ug/L
Center foyer womens bath. sink	9/25/2016 07:30	10/25/2016 04:38	10366694039	Lead	3.7	15	ug/L
Center foyer mens bath. sink	9/25/2016 07:32	10/25/2016 04:41	10366694040	Lead	15.2	15	ug/L
Gym office sink	9/25/2016 07:34	10/25/2016 22:21	10366694041	Lead	20.1	15	ug/L
Center foyer fountain	9/25/2016 07:35	10/25/2016 22:26	10366694042	Lead	4.7	15	ug/L
Womens bathrrom adj. to gym si	9/25/2016 07:40	10/25/2016 22:27	10366694043	Lead	15.1	15	ug/L
Mid-north corridor mens br sin	9/25/2016 07:45	10/25/2016 22:28	10366694044	Lead	13.9	15	ug/L
Mid-north corridor womens br	9/25/2016 07:46	10/25/2016 22:29	10366694045	Lead	6.7	15	ug/L
Mid-north corridor mens br sin	9/25/2016 07:45	10/25/2016 22:30	10366694046	Lead	9.9	15	ug/L
Mid-north corridor womens br	9/25/2016 07:46	10/25/2016 22:31	10366694047	Lead	3.3	15	ug/L
Rm. 107 sink	9/25/2016 07:52	10/25/2016 22:35	10366694048	Lead	21.4	15	ug/L
Rm. 108 sink	9/25/2016 08:00	10/25/2016 22:36	10366694049	Lead	10.3	15	ug/L
Rm. 109 sink	9/25/2016 08:02	10/25/2016 22:37	10366694050	Lead	10.2	15	ug/L

Rm. 110 sink	9/25/2016 08:05	10/25/2016 22:39	10366694051	Lead	6.8	15	ug/L
Rm. 111 sink	9/25/2016 08:07	10/25/2016 22:41	10366694052	Lead	8.5	15	ug/L
Far-north corridor mens br lef	9/25/2016 08:10	10/25/2016 22:42	10366694053	Lead	20.6	15	ug/L
Far-north corridor mens br rig	9/25/2016 08:11	10/25/2016 22:43	10366694054	Lead	16.9	15	ug/L
Rm. 112 sink	9/25/2016 08:13	10/25/2016 22:45	10366694055	Lead	16.8	15	ug/L
Far-north corridor womens br l	9/25/2016 08:15	10/25/2016 22:46	10366694056	Lead	14.5	15	ug/L
Far-north corridor womens br r	9/25/2016 08:16	10/25/2016 22:49	10366694057	Lead	14.0	15	ug/L
Far-north custodial sink	9/25/2016 08:22	10/25/2016 22:50	10366694058	Lead	26.0	15	ug/L
Rm. 113 sink	9/25/2016 08:25	10/25/2016 22:52	10366694059	Lead	16.1	15	ug/L
Center north corridor cutodial	9/25/2016 08:28	10/25/2016 22:53	10366694060	Lead	7.3	15	ug/L
North corridor fountain	9/25/2016 08:32	10/24/2016 19:37	10366694061	Lead	2.2	15	ug/L
Rm 114 sink	9/25/2016 08:35	10/24/2016 19:44	10366694062	Lead	29.4	15	ug/L
Rm 115 sink	9/25/2016 08:37	10/24/2016 19:45	10366694063	Lead	11.5	15	ug/L
Staff lounge mens br sink	9/25/2016 08:40	10/24/2016 19:46	10366694064	Lead	5.1	15	ug/L
Staff lounge womens br sink	9/25/2016 08:41	10/24/2016 19:47	10366694065	Lead	4.7	15	ug/L
Staff lounge sink	9/25/2016 08:42	10/24/2016 19:49	10366694066	Lead	3.8	15	ug/L
Kitchen Handsink Left	9/25/2016 08:45	10/24/2016 19:50	10366694067	Lead	50.9	15	ug/L
Kitchen Doublesink Left	9/25/2016 08:47	10/24/2016 19:51	10366694068	Lead	16.0	15	ug/L
Kitchen Doublesink Right	9/25/2016 08:49	10/24/2016 19:52	10366694069	Lead	9.9	15	ug/L
Kitchen Handsink Right	9/25/2016 08:51	10/24/2016 19:53	10366694070	Lead	16.7	15	ug/L
Cafeteria Fountain	9/25/2016 08:52	10/24/2016 19:56	10366694071	Lead	2.6	15	ug/L
Central foyer custodial sink	9/25/2016 08:55	10/24/2016 19:59	10366694072	Lead	6.7	15	ug/L
Room 206 Bathroom Sink	9/25/2016 08:59	10/24/2016 20:00	10366694073	Lead	17.6	15	ug/L
Nurses office sink	9/25/2016 09:02	10/24/2016 20:01	10366694074	Lead	2.0	15	ug/L
Nurses office bathroom sink	9/25/2016 09:03	10/24/2016 20:02	10366694075	Lead	2.9	15	ug/L
South corridor custodial sink	9/25/2016 09:07	10/24/2016 20:03	10366694076	Lead	32.2	15	ug/L
South corridor exterior spigot	9/25/2016 09:10	10/24/2016 20:04	10366694077	Lead	16.2	15	ug/L
North corridor exterior spigot	9/25/2016 09:12	10/24/2016 20:05	10366694078	Lead	51.4	15	ug/L
Cafeteria exterior spigot	9/25/2016 09:15	10/24/2016 20:06	10366694079	Lead	88.3	15	ug/L
Basement custodial sink	9/25/2016 09:18	10/24/2016 20:10	10366694080	Lead	44.6	15	ug/L

NYSDOH Action Level for Lead of 15 ppb